



Lead and Copper Compliance Report January through June 2015

Table 1 summarizes the District of Columbia Water and Sewer Authority's (DC Water) Lead and Copper compliance results for the monitoring period January through June 2015.

Table 1. Lead and Copper Summary Data

Number of Samples	
Lead and Copper	108
90th Percentile First Draw Concentrations	
Lead mg/L	0.002
Copper mg/L	0.085
Service Line Materials	
Full Lead	83
Partial Lead	25


The appendices and attachments contain the following information and data:

- Appendix A: Lead and Copper Compliance Data
 - Table A.1 First Draw Lead Results
 - Table A.2 First Draw Copper Results

- Appendix B: Additional Monitoring Data
 - Table B.1 Second Draw Lead Results
 - Table B.2 Second Draw Copper Results

- Appendix C: Additional Sampling Information
 - Table C.1 Sample Kit Distribution
 - Table C.2 Sample Kits Not Returned
 - Table C.3 Samples Returned but Rejected for Compliance Analysis
 - Table C.4 Deviations from Sample Kit Distribution Order
 - Table C.5 Sites with Compliance Results from January 2014 – December 2014 and No Results in January – June 2015
 - Table C.6 Customer Notification of Results

- Appendix D: Revisions to Sample Pool
 - Table D.1 Sample Pool for July – December 2015
 - Table D.2 Site Changes – Removed, Added, and Service Line Information
- Attachment 1: Washington Aqueduct Test Results for LCR Compliance
- Attachment 2: Other Additional Monitoring Data:
 - Customer requested tests
 - Post-LSR
 - Lead profiles
- Attachment 3: Certification of Consumer Tap Results for January through June 2015 and Customer Letters



Appendix A: Lead and Copper Compliance Data

Table A.1 First Draw Lead Results

No	Address	Pipe Material	Collection Date	Lead 1 st Draw (mg/L)
1	1003 Otis St NE	Lead	1/28/2015	0.0000
2	1519 Olive St NE	Lead	1/28/2015	0.0000
3	1613 Webster St NW	Lead	1/28/2015	0.0000
4	313 5TH ST NE	Lead	1/28/2015	0.0000
5	331 RALEIGH ST SE	Lead	2/25/2015	0.0000
6	2830 BRENTWOOD RD NE	Lead	2/23/2015	0.0000
7	4627 49th St NW	Lead	4/29/2015	0.0000
8	619 12th St NE	Lead	4/29/2015	0.0000
9	617 6th St NE	Lead	4/29/2015	0.0000
10	6001 33rd St NW	Lead	4/29/2015	0.0000
11	53 P St NW	Partial Lead	4/29/2015	0.0000
12	4806 Kansas Ave NW	Lead	4/29/2015	0.0000
13	5312 ILLINOIS AVE NW	Lead	4/28/2015	0.0000
14	4719 9TH ST NW	Lead	4/28/2015	0.0000
15	522 4TH ST SE	Lead	4/29/2015	0.0000
16	744 9TH ST SE	Partial Lead	4/29/2015	0.0000
17	905 Kent Pl NE	Lead	5/27/2015	0.0000
18	307 7th St NE	Lead	2/25/2015	0.0000
19	3036 P St NW	Partial Lead	2/25/2015	0.0000
20	308 9th St SE	Partial Lead	2/23/2015	0.0000
21	2923 Cathedral AVE NW	Lead	2/24/2015	0.0000
22	309 11TH ST SE	Lead	2/24/2015	0.0000
23	313 10TH ST SE	Partial Lead	2/24/2015	0.0000
24	3309 35TH ST NW	Lead	2/25/2015	0.0000
25	2036 17TH ST NW	Lead	2/25/2015	0.0000
26	2007 37TH ST NW	Lead	3/1/2015	0.0000
27	3913 8TH ST NW	Partial Lead	3/25/2015	0.0000
28	3416 9th St NE	Partial Lead	3/24/2015	0.0000
29	4120 Grant St NE	Lead	3/25/2015	0.0000
30	413 4th St SE	Partial Lead	3/25/2015	0.0000
31	3722 MCKINLEY ST NW	Partial Lead	3/25/2015	0.0000
32	3724 CHESAPEAKE ST NW	Lead	3/24/2015	0.0000
33	4447 HAWTHORNE ST NW	Lead	3/25/2015	0.0000
34	4413 5th St NW	Lead	3/25/2015	0.0000
35	414 G ST NE	Lead	3/26/2015	0.0000
36	4425 14th St NE	Lead	3/25/2015	0.0000
37	4002 ILLINOIS AVE NW	Lead	3/25/2015	0.0000

No	Address	Pipe Material	Collection Date	Lead 1 st Draw (mg/L)
38	3916 5TH ST NW	Lead	3/25/2015	0.0000
39	3405 HOLMEAD PL NW	Lead	3/26/2015	0.0000
40	4214 8th St NW	Lead	3/26/2015	0.0000
41	1412 S St NW	Partial Lead	1/27/2015	0.0000
42	2032 37TH ST NW	Lead	1/28/2015	0.0000
43	1831 MONROE ST NE	Lead	1/28/2015	0.0000
44	1738 ALLISON ST NW	Lead	2/25/2015	0.0000
45	3710 Huntington St NW	Lead	3/25/2015	0.0000
46	4054 GRANT ST NE	Partial Lead	3/25/2015	0.0000
47	1211 Carrollsburg Pl SW	Partial Lead	1/28/2015	0.0000
48	2408 2nd St NE	Partial Lead	2/23/2015	0.0000
49	5301 RENO RD NW	Partial Lead	4/28/2015	0.0000
50	3809 ALTON PL NW	Partial Lead	4/29/2015	0.0000
51	1703 D St NE	Lead	2/24/2015	0.0000
52	4215 39th St NW	Partial Lead	3/24/2015	0.0000
53	1375 MONROE ST NW	Lead	1/27/2015	0.0000
54	1020 INDEPENDENCE AVE SE	Lead	1/26/2015	0.0000
55	228 V ST NE	Lead	2/24/2015	0.0000
56	1706 NEW JERSEY AVE NW	Lead	2/25/2015	0.0000
57	3621 Van Ness St NW	Lead	3/25/2015	0.0000
58	5923 33rd St NW	Lead	4/29/2015	0.0000
59	4811 Illinois Ave NW	Lead	5/4/2015	0.0000
60	3917 8th St NW	Partial Lead	3/25/2015	0.0000
61	3636 13TH ST NW	Lead	3/25/2015	0.0000
62	3755 MCKINLEY ST NW	Lead	1/28/2015	0.0000
63	1850 2ND ST NW	Partial Lead	2/23/2015	0.0000
64	1808 KEARNEY ST NE	Partial Lead	2/25/2015	0.0000
65	804 Delafield Pl NW	Lead	4/29/2015	0.0000
66	6308 8th St NW	Lead	4/28/2015	0.0000
67	1353 JEFFERSON ST NW	Partial Lead	1/27/2015	0.0010
68	502 A ST SE	Lead	4/29/2015	0.0010
69	4921 30th Pl NW	Lead	2/24/2015	0.0010
70	4418 14th St NE	Lead	3/24/2015	0.0010
71	336 Quackenbos St NE	Lead	3/25/2015	0.0010
72	15 MADISON ST NW	Lead	1/29/2015	0.0011
73	322 TENNESSEE AVE NE	Lead	2/25/2015	0.0011
74	926 Hamilton St NW	Lead	5/28/2015	0.0011
75	816 MADISON ST NW	Lead	5/31/2015	0.0011
76	1635 WEBSTER ST NW	Lead	1/29/2015	0.0012
77	5404 39TH ST NW	Partial Lead	4/29/2015	0.0012
78	3625 Albermarle St NW	Lead	3/25/2015	0.0012
79	1222 HAMILTON ST NW	Partial Lead	1/28/2015	0.0013
80	3908 13TH ST NW	Lead	3/26/2015	0.0013
81	6516 8TH ST NW	Lead	4/28/2015	0.0013
82	923 9TH ST NE	Lead	5/26/2015	0.0013
83	1649 HARVARD ST NW	Lead	1/28/2015	0.0014

No	Address	Pipe Material	Collection Date	Lead 1 st Draw (mg/L)
84	12 14TH ST SE	Partial Lead	1/28/2015	0.0014
85	1513 27TH ST NW	Lead	1/29/2015	0.0014
86	3211 Central Ave NE	Lead	2/25/2015	0.0014
87	4131 YUMA ST NW	Lead	3/25/2015	0.0014
88	8 N St SW	Lead	4/27/2015	0.0015
89	87 S St NW	Lead	5/28/2015	0.0015
90	2832 BRENTWOOD RD NE	Lead	2/25/2015	0.0015
91	450 Newton Pl NW	Lead	3/30/2015	0.0016
92	4550 30TH ST NW	Lead	4/20/2015	0.0017
93	3206 38th St NW	Lead	3/2/2015	0.0018
94	2804 6TH ST NE	Lead	2/24/2015	0.0018
95	1659 NEWTON ST NW	Lead	1/30/2015	0.0020
96	1346 F St NE	Lead	1/28/2015	0.0022
97	5234 Illinois Ave NW	Lead	4/28/2015	0.0024
98	2719 O ST NW	Lead	3/24/2015	0.0026
99	125 Madison St NW	Lead	1/28/2015	0.0030
100	119 16TH ST NE	Lead	1/28/2015	0.0032
101	1505 Buchanan St NW	Lead	1/28/2015	0.0034
102	3030 44TH ST NW	Partial Lead	2/25/2015	0.0035
103	5731 3rd Pl NW	Lead	4/30/2015	0.0036
104	4525 15TH ST NW	Lead	3/23/2015	0.0038
105	1529 27TH ST NW	Lead	1/28/2015	0.0039
106	3727 T St NW	Lead	3/25/2015	0.0040
107	1357 C St NE	Lead	1/28/2015	0.0050
108	314 VARNUM ST NW	Lead	6/10/2015	0.0055

Notes:

- 1) All addresses meet Tier 1 criteria under 40 CFR 141.86(a)(3)(ii) as single family structures with either full or partial lead service lines based on DC Water's customer information and service line inventory records.
- 2) Service line material listings are representative of the pipe material known at the time the sample was collected.
- 3) Results expressed as "0.0000" may have been reported by the laboratory as less than 0.001 mg/L or non-detect.

Table A.2 First Draw Copper Results

No	Address	Pipe Material	Collection Date	Copper 1 st Draw (mg/L)
1	4413 5th St NW	Lead	3/25/2015	0.002
2	4002 ILLINOIS AVE NW	Lead	3/25/2015	0.002
3	3416 9th St NE	Partial Lead	3/24/2015	0.003
4	3916 5TH ST NW	Lead	3/25/2015	0.003
5	5731 3rd PI NW	Lead	4/30/2015	0.004
6	5312 ILLINOIS AVE NW	Lead	4/28/2015	0.005
7	308 9th St SE	Partial Lead	2/23/2015	0.005
8	1519 Olive St NE	Lead	1/28/2015	0.006
9	53 P St NW	Partial Lead	4/29/2015	0.006
10	1222 HAMILTON ST NW	Partial Lead	1/28/2015	0.007
11	4214 8th St NW	Lead	3/26/2015	0.008
12	804 Delafield PI NW	Lead	4/29/2015	0.009
13	4921 30th PI NW	Lead	2/24/2015	0.009
14	4719 9TH ST NW	Lead	4/28/2015	0.010
15	1659 NEWTON ST NW	Lead	1/30/2015	0.011
16	322 TENNESSEE AVE NE	Lead	2/25/2015	0.013
17	309 11TH ST SE	Lead	2/24/2015	0.013
18	4120 Grant St NE	Lead	3/25/2015	0.013
19	414 G ST NE	Lead	3/26/2015	0.013
20	1635 WEBSTER ST NW	Lead	1/29/2015	0.014
21	313 5TH ST NE	Lead	1/28/2015	0.014
22	3710 Huntington St NW	Lead	3/25/2015	0.014
23	1346 F St NE	Lead	1/28/2015	0.015
24	619 12th St NE	Lead	4/29/2015	0.015
25	522 4TH ST SE	Lead	4/29/2015	0.015
26	87 S St NW	Lead	5/28/2015	0.015
27	2923 Cathedral AVE NW	Lead	2/24/2015	0.015
28	2804 6TH ST NE	Lead	2/24/2015	0.015
29	12 14TH ST SE	Partial Lead	1/28/2015	0.017
30	744 9TH ST SE	Partial Lead	4/29/2015	0.017
31	905 Kent PI NE	Lead	5/27/2015	0.017
32	816 MADISON ST NW	Lead	5/31/2015	0.018
33	4131 YUMA ST NW	Lead	3/25/2015	0.018
34	125 Madison St NW	Lead	1/28/2015	0.019
35	1529 27TH ST NW	Lead	1/28/2015	0.019
36	5234 Illinois Ave NW	Lead	4/28/2015	0.019
37	331 RALEIGH ST SE	Lead	2/25/2015	0.020
38	5404 39TH ST NW	Partial Lead	4/29/2015	0.020
39	1703 D St NE	Lead	2/24/2015	0.020
40	1020 INDEPENDENCE AVE SE	Lead	1/26/2015	0.021
41	336 Quackenbos St NE	Lead	3/25/2015	0.021
42	2719 O ST NW	Lead	3/24/2015	0.022
43	3809 ALTON PL NW	Partial Lead	4/29/2015	0.023
44	413 4th St SE	Partial Lead	3/25/2015	0.023

No	Address	Pipe Material	Collection Date	Copper 1 st Draw (mg/L)
45	3206 38th St NW	Lead	3/2/2015	0.025
46	1357 C St NE	Lead	1/28/2015	0.026
47	3636 13TH ST NW	Lead	3/25/2015	0.026
48	228 V ST NE	Lead	2/24/2015	0.027
49	3913 8TH ST NW	Partial Lead	3/25/2015	0.027
50	450 Newton Pl NW	Lead	3/30/2015	0.027
51	4525 15TH ST NW	Lead	3/23/2015	0.027
52	2408 2nd St NE	Partial Lead	2/23/2015	0.028
53	4550 30TH ST NW	Lead	4/20/2015	0.029
54	5301 RENO RD NW	Partial Lead	4/28/2015	0.029
55	926 Hamilton St NW	Lead	5/28/2015	0.029
56	314 VARNUM ST NW	Lead	6/10/2015	0.029
57	3727 T St NW	Lead	3/25/2015	0.030
58	3625 Albermarle St NW	Lead	3/25/2015	0.032
59	3030 44TH ST NW	Partial Lead	2/25/2015	0.034
60	307 7th St NE	Lead	2/25/2015	0.034
61	2036 17TH ST NW	Lead	2/25/2015	0.035
62	313 10TH ST SE	Partial Lead	2/24/2015	0.036
63	1649 HARVARD ST NW	Lead	1/28/2015	0.037
64	6001 33rd St NW	Lead	4/29/2015	0.037
65	1831 MONROE ST NE	Lead	1/28/2015	0.039
66	3405 HOLMEAD PL NW	Lead	3/26/2015	0.039
67	4418 14th St NE	Lead	3/24/2015	0.039
68	1738 ALLISON ST NW	Lead	2/25/2015	0.040
69	119 16TH ST NE	Lead	1/28/2015	0.042
70	4447 HAWTHORNE ST NW	Lead	3/25/2015	0.042
71	1706 NEW JERSEY AVE NW	Lead	2/25/2015	0.043
72	4425 14th St NE	Lead	3/25/2015	0.043
73	1353 JEFFERSON ST NW	Partial Lead	1/27/2015	0.045
74	502 A ST SE	Lead	4/29/2015	0.045
75	15 MADISON ST NW	Lead	1/29/2015	0.048
76	4215 39th St NW	Partial Lead	3/24/2015	0.049
77	1613 Webster St NW	Lead	1/28/2015	0.051
78	1850 2ND ST NW	Partial Lead	2/23/2015	0.054
79	3908 13TH ST NW	Lead	3/26/2015	0.054
80	4627 49th St NW	Lead	4/29/2015	0.059
81	1375 MONROE ST NW	Lead	1/27/2015	0.061
82	4054 GRANT ST NE	Partial Lead	3/25/2015	0.061
83	3036 P St NW	Partial Lead	2/25/2015	0.062
84	2032 37TH ST NW	Lead	1/28/2015	0.066
85	6308 8th St NW	Lead	4/28/2015	0.066
86	2830 BRENTWOOD RD NE	Lead	2/23/2015	0.069
87	3917 8th St NW	Partial Lead	3/25/2015	0.069
88	3755 MCKINLEY ST NW	Lead	1/28/2015	0.072
89	2832 BRENTWOOD RD NE	Lead	2/25/2015	0.072
90	3724 CHESAPEAKE ST NW	Lead	3/24/2015	0.073

No	Address	Pipe Material	Collection Date	Copper 1 st Draw (mg/L)
91	1412 S St NW	Partial Lead	1/27/2015	0.074
92	1513 27TH ST NW	Lead	1/29/2015	0.075
93	617 6th St NE	Lead	4/29/2015	0.077
94	6516 8TH ST NW	Lead	4/28/2015	0.080
95	3309 35TH ST NW	Lead	2/25/2015	0.081
96	923 9TH ST NE	Lead	5/26/2015	0.084
97	1505 Buchanan St NW	Lead	1/28/2015	0.085
98	1808 KEARNEY ST NE	Partial Lead	2/25/2015	0.099
99	4811 Illinois Ave NW	Lead	5/4/2015	0.103
100	3621 Van Ness St NW	Lead	3/25/2015	0.106
101	1211 Carrollsburg Pl SW	Partial Lead	1/28/2015	0.109
102	3211 Central Ave NE	Lead	2/25/2015	0.109
103	2007 37TH ST NW	Lead	3/1/2015	0.111
104	4806 Kansas Ave NW	Lead	4/29/2015	0.131
105	3722 MCKINLEY ST NW	Partial Lead	3/25/2015	0.135
106	8 N St SW	Lead	4/27/2015	0.138
107	5923 33rd St NW	Lead	4/29/2015	0.151
108	1003 Otis St NE	Lead	1/28/2015	0.181

Notes:

- 1) All addresses meet Tier 1 criteria under 40 CFR 141.86(a)(3)(ii) as single family structures with either full or partial lead service lines based on DC Water's customer information and service line inventory records.
- 2) Service line material listings are representative of the pipe material known at the time the sample was collected.
- 3) Results expressed as "0.000" may have been reported by the laboratory as less than 0.001 mg/L or non-detect.

Appendix B: Additional Monitoring Data

Tables B.1 and B.2 present results from the second draw samples collected at the time of the Lead and Copper Rule compliance sampling. Additional monitoring data presented in Attachment 2 to this report contains sample data collected from other DC Water programs that focused on lead, copper, or other metals that included lead sample results. A description of the program followed by the data set is included in Attachment 2.

Table B.1 Second Draw Lead Results

No	Address	Pipe Material	Collection Date	Lead 2 nd Draw (mg/L)
1	1613 Webster St NW	Lead	1/28/2015	0.0000
2	12 14TH ST SE	Partial Lead	1/28/2015	0.0000
3	313 5TH ST NE	Lead	1/28/2015	0.0000
4	619 12th St NE	Lead	4/29/2015	0.0000
5	617 6th St NE	Lead	4/29/2015	0.0000
6	53 P St NW	Partial Lead	4/29/2015	0.0000
7	5312 ILLINOIS AVE NW	Lead	4/28/2015	0.0000
8	4719 9TH ST NW	Lead	4/28/2015	0.0000
9	522 4TH ST SE	Lead	4/29/2015	0.0000
10	744 9TH ST SE	Partial Lead	4/29/2015	0.0000
11	905 Kent Pl NE	Lead	5/27/2015	0.0000
12	307 7th St NE	Lead	2/25/2015	0.0000
13	3036 P St NW	Partial Lead	2/25/2015	0.0000
14	2923 Cathedral AVE NW	Lead	2/24/2015	0.0000
15	309 11TH ST SE	Lead	2/24/2015	0.0000
16	3913 8TH ST NW	Partial Lead	3/25/2015	0.0000
17	3416 9th St NE	Partial Lead	3/24/2015	0.0000
18	336 Quackenbos St NE	Lead	3/25/2015	0.0000
19	3724 CHESAPEAKE ST NW	Lead	3/24/2015	0.0000
20	414 G ST NE	Lead	3/26/2015	0.0000
21	1635 WEBSTER ST NW	Lead	1/29/2015	0.0000
22	1412 S St NW	Partial Lead	1/27/2015	0.0000
23	4627 49th St NW	Lead	4/29/2015	0.0000
24	4447 HAWTHORNE ST NW	Lead	3/25/2015	0.0000
25	2830 BRENTWOOD RD NE	Lead	2/23/2015	0.0000
26	3405 HOLMEAD PL NW	Lead	3/26/2015	0.0000
27	308 9th St SE	Partial Lead	2/23/2015	0.0000
28	3309 35TH ST NW	Lead	2/25/2015	0.0000
29	2007 37TH ST NW	Lead	3/1/2015	0.0000
30	3917 8th St NW	Partial Lead	3/25/2015	0.0000
31	413 4th St SE	Partial Lead	3/25/2015	0.0000
32	3625 Albermarle St NW	Lead	3/25/2015	0.0000
33	4413 5th St NW	Lead	3/25/2015	0.0000
34	1519 Olive St NE	Lead	1/28/2015	0.0000
35	1020 INDEPENDENCE AVE SE	Lead	1/26/2015	0.0000
36	331 RALEIGH ST SE	Lead	2/25/2015	0.0000

No	Address	Pipe Material	Collection Date	Lead 2 nd Draw (mg/L)
37	1706 NEW JERSEY AVE NW	Lead	2/25/2015	0.0000
38	4806 Kansas Ave NW	Lead	4/29/2015	0.0000
39	2036 17TH ST NW	Lead	2/25/2015	0.0000
40	4120 Grant St NE	Lead	3/25/2015	0.0000
41	4214 8th St NW	Lead	3/26/2015	0.0000
42	4425 14th St NE	Lead	3/25/2015	0.0000
43	313 10TH ST SE	Partial Lead	2/24/2015	0.0000
44	1003 Otis St NE	Lead	1/28/2015	0.0000
45	5301 RENO RD NW	Partial Lead	4/28/2015	0.0000
46	502 A ST SE	Lead	4/29/2015	0.0000
47	1738 ALLISON ST NW	Lead	2/25/2015	0.0000
48	2408 2nd St NE	Partial Lead	2/23/2015	0.0000
49	3908 13TH ST NW	Lead	3/26/2015	0.0000
50	6308 8th St NW	Lead	4/28/2015	0.0000
51	1703 D St NE	Lead	2/24/2015	0.0000
52	3809 ALTON PL NW	Partial Lead	4/29/2015	0.0000
53	5404 39TH ST NW	Partial Lead	4/29/2015	0.0000
54	4215 39th St NW	Partial Lead	3/24/2015	0.0000
55	3916 5TH ST NW	Lead	3/25/2015	0.0000
56	1211 Carrollsburg Pl SW	Partial Lead	1/28/2015	0.0000
57	1808 KEARNEY ST NE	Partial Lead	2/25/2015	0.0000
58	125 Madison St NW	Lead	1/28/2015	0.0010
59	5923 33rd St NW	Lead	4/29/2015	0.0010
60	119 16TH ST NE	Lead	1/28/2015	0.0011
61	1353 JEFFERSON ST NW	Partial Lead	1/27/2015	0.0011
62	1375 MONROE ST NW	Lead	1/27/2015	0.0011
63	228 V ST NE	Lead	2/24/2015	0.0011
64	804 Delafield Pl NW	Lead	4/29/2015	0.0011
65	2832 BRENTWOOD RD NE	Lead	2/25/2015	0.0011
66	3710 Huntington St NW	Lead	3/25/2015	0.0012
67	1649 HARVARD ST NW	Lead	1/28/2015	0.0013
68	6516 8TH ST NW	Lead	4/28/2015	0.0013
69	923 9TH ST NE	Lead	5/26/2015	0.0013
70	15 MADISON ST NW	Lead	1/29/2015	0.0015
71	1659 NEWTON ST NW	Lead	1/30/2015	0.0016
72	3621 Van Ness St NW	Lead	3/25/2015	0.0016
73	4054 GRANT ST NE	Partial Lead	3/25/2015	0.0016
74	1222 HAMILTON ST NW	Partial Lead	1/28/2015	0.0017
75	5234 Illinois Ave NW	Lead	4/28/2015	0.0017
76	4418 14th St NE	Lead	3/24/2015	0.0018
77	4002 ILLINOIS AVE NW	Lead	3/25/2015	0.0018
78	6001 33rd St NW	Lead	4/29/2015	0.0020
79	87 S St NW	Lead	5/28/2015	0.0021
80	4550 30TH ST NW	Lead	4/20/2015	0.0023
81	1831 MONROE ST NE	Lead	1/28/2015	0.0024
82	2032 37TH ST NW	Lead	1/28/2015	0.0025

No	Address	Pipe Material	Collection Date	Lead 2 nd Draw (mg/L)
83	1850 2ND ST NW	Partial Lead	2/23/2015	0.0025
84	5731 3rd PI NW	Lead	4/30/2015	0.0025
85	450 Newton PI NW	Lead	3/30/2015	0.0025
86	4525 15TH ST NW	Lead	3/23/2015	0.0025
87	4811 Illinois Ave NW	Lead	5/4/2015	0.0026
88	2719 O ST NW	Lead	3/24/2015	0.0028
89	3206 38th St NW	Lead	3/2/2015	0.0032
90	3030 44TH ST NW	Partial Lead	2/25/2015	0.0034
91	3636 13TH ST NW	Lead	3/25/2015	0.0036
92	1529 27TH ST NW	Lead	1/28/2015	0.0038
93	3211 Central Ave NE	Lead	2/25/2015	0.0041
94	816 MADISON ST NW	Lead	5/31/2015	0.0042
95	4131 YUMA ST NW	Lead	3/25/2015	0.0048
96	1505 Buchanan St NW	Lead	1/28/2015	0.0052
97	8 N St SW	Lead	4/27/2015	0.0053
98	3727 T St NW	Lead	3/25/2015	0.0060
99	314 VARNUM ST NW	Lead	6/10/2015	0.0079
100	1346 F St NE	Lead	1/28/2015	0.0080
101	1357 C St NE	Lead	1/28/2015	0.0101
102	1513 27TH ST NW	Lead	1/29/2015	0.0106
103	3755 MCKINLEY ST NW	Lead	1/28/2015	0.0243

Notes:

- 1) Service line material listings are representative of the pipe material at the time the sample was collected.
- 2) Results expressed as “0.0000” may have been reported by the laboratory as less than 0.001 mg/L or non-detect.
- 3) The second draw samples were rejected due to sampling errors:
926 Hamilton St NW
2804 6TH ST NE
4921 30th PI NW
3722 MCKINLEY ST NW
322 TENNESSEE AVE NE

Table B.2 Second Draw Copper Results

No	Address	Pipe Material	Collection Date	Copper 2nd Draw (mg/L)
1	4413 5th St NW	Lead	3/25/2015	0.001
2	2923 Cathedral AVE NW	Lead	2/24/2015	0.002
3	5731 3rd PI NW	Lead	4/30/2015	0.003
4	5312 ILLINOIS AVE NW	Lead	4/28/2015	0.003
5	3416 9th St NE	Partial Lead	3/24/2015	0.003
6	3625 Albermarle St NW	Lead	3/25/2015	0.003
7	4002 ILLINOIS AVE NW	Lead	3/25/2015	0.003
8	3916 5TH ST NW	Lead	3/25/2015	0.003
9	119 16TH ST NE	Lead	1/28/2015	0.004
10	125 Madison St NW	Lead	1/28/2015	0.004
11	1020 INDEPENDENCE AVE SE	Lead	1/26/2015	0.004
12	804 Delafield PI NW	Lead	4/29/2015	0.004
13	6001 33rd St NW	Lead	4/29/2015	0.004
14	816 MADISON ST NW	Lead	5/31/2015	0.004
15	4214 8th St NW	Lead	3/26/2015	0.004
16	1659 NEWTON ST NW	Lead	1/30/2015	0.005
17	313 5TH ST NE	Lead	1/28/2015	0.005
18	4550 30TH ST NW	Lead	4/20/2015	0.005
19	53 P St NW	Partial Lead	4/29/2015	0.005
20	4719 9TH ST NW	Lead	4/28/2015	0.005
21	744 9TH ST SE	Partial Lead	4/29/2015	0.005
22	4131 YUMA ST NW	Lead	3/25/2015	0.005
23	1346 F St NE	Lead	1/28/2015	0.006
24	331 RALEIGH ST SE	Lead	2/25/2015	0.006
25	308 9th St SE	Partial Lead	2/23/2015	0.006
26	3913 8TH ST NW	Partial Lead	3/25/2015	0.006
27	1519 Olive St NE	Lead	1/28/2015	0.007
28	3727 T St NW	Lead	3/25/2015	0.007
29	228 V ST NE	Lead	2/24/2015	0.008
30	3710 Huntington St NW	Lead	3/25/2015	0.008
31	336 Quackenbos St NE	Lead	3/25/2015	0.008
32	3636 13TH ST NW	Lead	3/25/2015	0.008
33	2719 O ST NW	Lead	3/24/2015	0.008
34	1513 27TH ST NW	Lead	1/29/2015	0.009
35	3211 Central Ave NE	Lead	2/25/2015	0.009
36	617 6th St NE	Lead	4/29/2015	0.009
37	905 Kent PI NE	Lead	5/27/2015	0.009
38	314 VARNUM ST NW	Lead	6/10/2015	0.009
39	414 G ST NE	Lead	3/26/2015	0.009
40	3621 Van Ness St NW	Lead	3/25/2015	0.010
41	5301 RENO RD NW	Partial Lead	4/28/2015	0.010
42	6516 8TH ST NW	Lead	4/28/2015	0.010
43	3036 P St NW	Partial Lead	2/25/2015	0.010
44	309 11TH ST SE	Lead	2/24/2015	0.010

No	Address	Pipe Material	Collection Date	Copper 2nd Draw (mg/L)
45	4418 14th St NE	Lead	3/24/2015	0.010
46	4120 Grant St NE	Lead	3/25/2015	0.010
47	1529 27TH ST NW	Lead	1/28/2015	0.011
48	313 10TH ST SE	Partial Lead	2/24/2015	0.011
49	3309 35TH ST NW	Lead	2/25/2015	0.011
50	1635 WEBSTER ST NW	Lead	1/29/2015	0.012
51	1505 Buchanan St NW	Lead	1/28/2015	0.012
52	619 12th St NE	Lead	4/29/2015	0.012
53	8 N St SW	Lead	4/27/2015	0.012
54	522 4TH ST SE	Lead	4/29/2015	0.012
55	1222 HAMILTON ST NW	Partial Lead	1/28/2015	0.013
56	2032 37TH ST NW	Lead	1/28/2015	0.013
57	1831 MONROE ST NE	Lead	1/28/2015	0.013
58	4215 39th St NW	Partial Lead	3/24/2015	0.013
59	3206 38th St NW	Lead	3/2/2015	0.014
60	3809 ALTON PL NW	Partial Lead	4/29/2015	0.014
61	307 7th St NE	Lead	2/25/2015	0.014
62	5234 Illinois Ave NW	Lead	4/28/2015	0.015
63	1357 C St NE	Lead	1/28/2015	0.016
64	1703 D St NE	Lead	2/24/2015	0.016
65	87 S St NW	Lead	5/28/2015	0.017
66	4425 14th St NE	Lead	3/25/2015	0.017
67	1375 MONROE ST NW	Lead	1/27/2015	0.018
68	4525 15TH ST NW	Lead	3/23/2015	0.018
69	5404 39TH ST NW	Partial Lead	4/29/2015	0.019
70	3030 44TH ST NW	Partial Lead	2/25/2015	0.020
71	2408 2nd St NE	Partial Lead	2/23/2015	0.020
72	1738 ALLISON ST NW	Lead	2/25/2015	0.021
73	1706 NEW JERSEY AVE NW	Lead	2/25/2015	0.022
74	1613 Webster St NW	Lead	1/28/2015	0.023
75	1850 2ND ST NW	Partial Lead	2/23/2015	0.024
76	1649 HARVARD ST NW	Lead	1/28/2015	0.027
77	3755 MCKINLEY ST NW	Partial Lead	1/28/2015	0.027
78	2007 37TH ST NW	Lead	3/1/2015	0.027
79	450 Newton Pl NW	Lead	3/30/2015	0.028
80	1353 JEFFERSON ST NW	Partial Lead	1/27/2015	0.029
81	4811 Illinois Ave NW	Lead	5/4/2015	0.030
82	3908 13TH ST NW	Lead	3/26/2015	0.031
83	12 14TH ST SE	Partial Lead	1/28/2015	0.033
84	413 4th St SE	Partial Lead	3/25/2015	0.036
85	3724 CHESAPEAKE ST NW	Lead	3/24/2015	0.036
86	4447 HAWTHORNE ST NW	Lead	3/25/2015	0.039
87	3405 HOLMEAD PL NW	Lead	3/26/2015	0.042
88	15 MADISON ST NW	Lead	1/29/2015	0.043
89	2832 BRENTWOOD RD NE	Lead	2/25/2015	0.043
90	3917 8th St NW	Partial Lead	3/25/2015	0.044

No	Address	Pipe Material	Collection Date	Copper 2nd Draw (mg/L)
91	502 A ST SE	Lead	4/29/2015	0.045
92	4627 49th St NW	Lead	4/29/2015	0.047
93	2830 BRENTWOOD RD NE	Lead	2/23/2015	0.048
94	4054 GRANT ST NE	Partial Lead	3/25/2015	0.050
95	1211 Carrollsburg Pl SW	Partial Lead	1/28/2015	0.065
96	2036 17TH ST NW	Lead	2/25/2015	0.065
97	1808 KEARNEY ST NE	Partial Lead	2/25/2015	0.075
98	923 9TH ST NE	Lead	5/26/2015	0.076
99	6308 8th St NW	Lead	4/28/2015	0.081
100	4806 Kansas Ave NW	Lead	4/29/2015	0.096
101	5923 33rd St NW	Lead	4/29/2015	0.112
102	1412 S St NW	Partial Lead	1/27/2015	0.124
103	1003 Otis St NE	Lead	1/28/2015	0.151

Notes:

- 1) Service line material listings are representative of the pipe material at the time the sample was collected.
- 2) Results expressed as “0.000” may have been reported by the laboratory as less than 0.001 mg/L or non-detect.
- 3) The second draw samples were rejected due to sampling errors:
926 Hamilton St NW
2804 6TH ST NE
4921 30th Pl NW
3722 MCKINLEY ST NW
322 TENNESSEE AVE NE

Appendix C – Additional Sampling Information

Table C.1 Sample Kit Distribution

No	Address	Bottle Delivery Date
1	10 S St NW	1/26/2015
2	1003 Otis St NE	1/26/2015
3	1003 Quebec Pl NW	1/26/2015
4	1010 10th St NE	1/26/2015
5	1011 Taylor St NE	1/26/2015
6	1020 INDEPENDENCE AVE SE	1/26/2015
7	109 19th St SE	1/26/2015
8	1113 STAPLES ST NE	1/26/2015
9	119 16TH ST NE	1/26/2015
10	12 14TH ST SE	1/26/2015
11	1211 Carrollsborg Pl SW	1/26/2015
12	1222 HAMILTON ST NW	1/26/2015
13	123 TENNESSEE AVE NE	1/26/2015
14	125 Madison St NW	1/26/2015
15	1262 COLUMBIA RD NW	1/26/2015
16	1305 TAYLOR ST NW	1/26/2015
17	1315 FRANKLIN ST NE	1/26/2015
18	1319 POTOMAC AVE SE	1/26/2015
19	1331 Irving St NE	1/26/2015
20	1339 CHILDRESS ST NE	1/26/2015
21	1346 F St NE	1/26/2015
22	1353 JEFFERSON ST NW	1/26/2015
23	1357 C St NE	1/26/2015
24	1375 MONROE ST NW	1/26/2015
25	1410 ALLISON ST NW	1/26/2015
26	1412 S St NW	1/26/2015
27	1412 Shepherd St NW	1/26/2015
28	1420 Hamlin St NE	1/26/2015
29	1420 INGRAHAM ST NW	1/26/2015
30	1424 S ST NW	1/26/2015
31	1428 VARNUM ST NW	1/26/2015
32	1436 S St NW	1/26/2015
33	1453 S St NW	1/26/2015
34	15 MADISON ST NW	1/26/2015
35	15 Milmarson Pl NW	1/26/2015
36	1505 Buchanan St NW	1/26/2015
37	1508 GOOD HOPE RD SE	1/26/2015
38	1513 27TH ST NW	1/26/2015
39	1519 Olive St NE	1/26/2015
40	1529 27TH ST NW	1/26/2015
41	1529 UPSHUR ST NW	2/23/2015
42	1603 Massachusetts Ave SE	1/26/2015
43	1613 Webster St NW	1/26/2015

No	Address	Bottle Delivery Date
44	1620 Webster St NW	1/26/2015
45	1627 Gales St NE	1/26/2015
46	1635 WEBSTER ST NW	1/26/2015
47	1649 HARVARD ST NW	1/26/2015
48	1659 NEWTON ST NW	1/26/2015
49	714 4th ST NE	1/26/2015
50	1671 Rosedale St NE	2/23/2015
51	1703 D St NE	2/23/2015
52	1705 D St NE	2/23/2015
53	1706 NEW JERSEY AVE NW	2/23/2015
54	1715 IRVING ST NE	2/23/2015
55	1736 Bay St SE	2/23/2015
56	1738 ALLISON ST NW	2/23/2015
57	1808 KEARNEY ST NE	2/23/2015
58	1826 Jackson St NE	2/23/2015
59	1831 MONROE ST NE	1/26/2015
60	1850 2ND ST NW	2/23/2015
61	1916 PARK RD NW	2/23/2015
62	2007 37TH ST NW	2/23/2015
63	2032 37TH ST NW	1/26/2015
64	2036 17TH ST NW	2/23/2015
65	2107 2nd St NE	2/23/2015
66	2121 3RD ST NE	2/23/2015
67	213 49th St NE	2/23/2015
68	2212 38th St NW	2/23/2015
69	223 14th PI NE	2/23/2015
70	228 V ST NE	2/23/2015
71	230 G St NE	2/23/2015
72	231 K St NE	2/23/2015
73	24 Evarts St NE	2/23/2015
74	2408 2nd St NE	2/23/2015
75	2435 33RD ST SE	2/23/2015
76	2719 O ST NW	3/23/2015
77	2804 6TH ST NE	2/23/2015
78	2830 BRENTWOOD RD NE	2/23/2015
79	2832 BRENTWOOD RD NE	2/23/2015
80	2904 P ST SE	2/23/2015
81	2913 Brandywine St NW	2/23/2015
82	2923 Cathedral AVE NW	2/23/2015
83	302 RITTENHOUSE ST NW	2/23/2015
84	3030 44TH ST NW	2/23/2015
85	3033 CAMBRIDGE PL NW	2/23/2015
86	3036 P St NW	2/23/2015
87	307 7th St NE	2/23/2015
88	308 9th St SE	2/23/2015
89	309 11TH ST SE	2/23/2015
90	313 10TH ST SE	2/23/2015

No	Address	Bottle Delivery Date
91	313 5TH ST NE	1/26/2015
92	314 VARNUM ST NW ¹	11/17/2014
93	317 9th St SE	2/23/2015
94	3202 38TH ST NW	2/23/2015
95	3206 38th St NW	2/23/2015
96	3211 Central Ave NE	2/23/2015
97	3218 MACOMB ST NW	2/23/2015
98	3218 MORRISON ST NW	2/23/2015
99	322 TENNESSEE AVE NE	2/23/2015
100	3301 BROWN St NW	2/23/2015
101	3309 35TH ST NW	2/23/2015
102	331 RALEIGH ST SE	2/23/2015
103	333 34th St NE	2/23/2015
104	336 Quackenbos St NE	3/23/2015
105	3361 Stuyvesant Pl NW	3/23/2015
106	3405 HOLMEAD PL NW	3/23/2015
107	3416 9th St NE	3/23/2015
108	3510 QUESADA ST NW	3/23/2015
109	36 Florida Ave NW	3/23/2015
110	3601 WARREN ST NW	3/23/2015
111	3621 Van Ness St NW	3/23/2015
112	3625 Albermarle St NW	3/23/2015
113	3636 13TH ST NW	3/23/2015
114	37 U ST NE	3/23/2015
115	3706 35th St NW	3/23/2015
116	3710 Huntington St NW	3/23/2015
117	3722 MCKINLEY ST NW	3/23/2015
118	3724 CHESAPEAKE ST NW	3/23/2015
119	3727 T St NW	3/23/2015
120	3755 MCKINLEY ST NW	1/26/2015
121	3761 W ST NW	3/23/2015
122	3807 KANAWHA ST NW	3/23/2015
123	3809 ALTON PL NW	3/23/2015
124	3809 ALTON PL NW	4/27/2015
125	3907 13th St NW	3/23/2015
126	3908 13TH ST NW	3/23/2015
127	3913 8TH ST NW	3/23/2015
128	3916 5TH ST NW	3/23/2015
129	3917 8th St NW	3/23/2015
130	4002 ILLINOIS AVE NW	3/23/2015
131	4014 Grant St NE	3/23/2015
132	4054 GRANT ST NE	3/23/2015
133	412 BRANDYWINE ST SE	3/23/2015
134	4120 Grant St NE	3/23/2015
135	413 4th St SE	3/23/2015
136	4131 YUMA ST NW	3/23/2015
137	414 G ST NE	3/23/2015

No	Address	Bottle Delivery Date
138	420 Kenyon St NW	3/23/2015
139	421 Hamilton St NW	3/23/2015
140	4214 8th St NW	3/23/2015
141	4215 39th St NW	3/23/2015
142	4233 JENIFER ST NW	3/23/2015
143	424 Luray PI NW	3/23/2015
144	4307 CHESAPEAKE ST NW	3/23/2015
145	4408 HAYES ST NE	3/23/2015
146	4409 Lowell St NW	3/23/2015
147	4413 5th St NW	3/23/2015
148	4418 14th St NE	3/23/2015
149	4425 14th St NE	3/23/2015
150	4447 HAWTHORNE ST NW	3/23/2015
151	449 S St NW	3/23/2015
152	450 Newton PI NW	3/23/2015
153	4525 15TH ST NW	3/23/2015
154	4550 30TH ST NW	3/23/2015
155	4610 KANSAS AVE NW	3/23/2015
156	4627 49th St NW	4/27/2015
157	4703 Macarthur Blvd NW	4/27/2015
158	4719 9TH ST NW	4/27/2015
159	4806 Kansas Ave NW	4/27/2015
160	4811 Illinois Ave NW	4/27/2015
161	4818 8th ST NW	4/27/2015
162	4921 30th PI NW	2/23/2015
163	4926 Glenbrook Rd NW	4/27/2015
164	5003 7TH ST NW	4/27/2015
165	5007 13TH ST NW	4/27/2015
166	501 Webster St NW	4/27/2015
167	502 A ST SE	4/27/2015
168	5024 7th St NW	4/27/2015
169	522 4TH ST SE	4/27/2015
170	5220 CHEVY CHASE PKWY NW	4/27/2015
171	5223 KANSAS AVE NW	4/27/2015
172	5226 7th St NW	4/27/2015
173	5234 Illinois Ave NW	4/27/2015
174	53 P St NW	4/27/2015
175	53 V St NW	4/27/2015
176	5301 RENO RD NW	4/27/2015
177	531 Tennessee Ave NE	4/27/2015
178	5312 ILLINOIS AVE NW	4/27/2015
179	5318 9TH ST NW	4/27/2015
180	5404 39TH ST NW	4/27/2015
181	5517 7th St NW	4/27/2015
182	5731 3rd PI NW	4/27/2015
183	580 49th PI NE	4/27/2015
184	5812 7TH ST NW	4/27/2015

No	Address	Bottle Delivery Date
185	5923 33rd St NW	4/27/2015
186	6001 33rd St NW	4/27/2015
187	605 ROCK CRK CHURCH RD NW	4/27/2015
188	609 49TH PL NE	4/27/2015
189	6105 Dix St NE	4/27/2015
190	617 6th St NE	4/27/2015
191	617 M St NE	4/27/2015
192	619 12th St NE	4/27/2015
193	620 44TH ST NE	4/27/2015
194	6205 14TH ST NW	4/27/2015
195	621 Upshur St NW	4/27/2015
196	6210 8th St NW	4/27/2015
197	6213 7TH ST NW	4/27/2015
198	6308 8th St NW	4/27/2015
199	636 ROCK CRK CHURCH RD NW	4/27/2015
200	641 Gallatin St NW	4/27/2015
201	6516 8TH ST NW	4/27/2015
202	702 9th St SE	4/27/2015
203	744 9TH ST SE	4/27/2015
204	75 Bates St NW	4/27/2015
205	8 N St SW	4/27/2015
206	804 Delafield PI NW	4/27/2015
207	807 Buchanan St NW	5/26/2015
208	816 MADISON ST NW	5/26/2015
209	834 Delafield PI NW	5/26/2015
210	87 S St NW	5/26/2015
211	905 Kent PI NE	5/26/2015
212	910 Farragut St NW	5/26/2015
213	912 Emerson St NW	5/26/2015
214	913 Hamlin St NE	5/26/2015
215	923 9TH ST NE	5/26/2015
216	926 Hamilton St NW	5/26/2015

Notes:

- 1) This address was randomly selected and added to the Sample Pool in 2014 but did not return bottles during the semester and subsequently dropped from the 2015 Sample Pool. The address returned bottles this semester. This address was also added to Table C.4.

Table C.2 Sample Kits Not Returned

No	Address	Bottle Delivery Date
1	714 4th ST NE	1/26/2015
2	1319 POTOMAC AVE SE	1/26/2015
3	1424 S ST NW	1/26/2015
4	1315 FRANKLIN ST NE	1/26/2015
5	1436 S St NW	1/26/2015
6	1003 Quebec PI NW	1/26/2015
7	1412 Shepherd St NW	1/26/2015
8	1603 Massachusetts Ave SE	1/26/2015
9	1010 10th St NE	1/26/2015
10	1331 Irving St NE	1/26/2015
11	1420 Hamlin St NE	1/26/2015
12	10 S St NW	1/26/2015
13	1620 Webster St NW	1/26/2015
14	1453 S St NW	1/26/2015
15	109 19th St SE	1/26/2015
16	1627 Gales St NE	1/26/2015
17	1428 VARNUM ST NW	1/26/2015
18	123 TENNESSEE AVE NE	1/26/2015
19	1508 GOOD HOPE RD SE	1/26/2015
20	1420 INGRAHAM ST NW	1/26/2015
21	1113 STAPLES ST NE	1/26/2015
22	1410 ALLISON ST NW	1/26/2015
23	1339 CHILDRESS ST NE	1/26/2015
24	3202 38TH ST NW	2/23/2015
25	3218 MACOMB ST NW	2/23/2015
26	3301 BROWN St NW	2/23/2015
27	3218 MORRISON ST NW	2/23/2015
28	2435 33RD ST SE	2/23/2015
29	302 RITTENHOUSE ST NW	2/23/2015
30	2212 38th St NW	2/23/2015
31	317 9th St SE	2/23/2015
32	1736 Bay St SE	2/23/2015
33	230 G St NE	2/23/2015
34	231 K St NE	2/23/2015
35	1671 Rosedale St NE	2/23/2015
36	2107 2nd St NE	2/23/2015
37	1826 Jackson St NE	2/23/2015
38	223 14th PI NE	2/23/2015
39	213 49th St NE	2/23/2015
40	333 34th St NE	2/23/2015
41	2913 Brandywine St NW	2/23/2015
42	1705 D St NE	2/23/2015
43	2904 P ST SE	2/23/2015
44	1529 UPSHUR ST NW	2/23/2015
45	2121 3RD ST NE	2/23/2015

No	Address	Bottle Delivery Date
46	1715 IRVING ST NE	2/23/2015
47	1916 PARK RD NW	2/23/2015
48	4307 CHESAPEAKE ST NW	3/23/2015
49	3601 WARREN ST NW	3/23/2015
50	420 Kenyon St NW	3/23/2015
51	424 Luray Pl NW	3/23/2015
52	3907 13th St NW	3/23/2015
53	4409 Lowell St NW	3/23/2015
54	3706 35th St NW	3/23/2015
55	3361 Stuyvesant Pl NW	3/23/2015
56	421 Hamilton St NW	3/23/2015
57	3761 W ST NW	3/23/2015
58	3510 QUESADA ST NW	3/23/2015
59	37 U ST NE	3/23/2015
60	4610 KANSAS AVE NW	3/23/2015
61	4408 HAYES ST NE	3/23/2015
62	4233 JENIFER ST NW	3/23/2015
63	3807 KANAWHA ST NW	3/23/2015
64	4014 Grant St NE	3/23/2015
65	6213 7TH ST NW	4/27/2015
66	4818 8th ST NW	4/27/2015
67	5318 9TH ST NW	4/27/2015
68	605 ROCK CRK CHURCH RD NW	4/27/2015
69	641 Gallatin St NW	4/27/2015
70	53 V St NW	4/27/2015
71	636 ROCK CRK CHURCH RD NW	4/27/2015
72	702 9th St SE	4/27/2015
73	617 M St NE	4/27/2015
74	580 49th Pl NE	4/27/2015
75	5024 7th St NW	4/27/2015
76	6210 8th St NW	4/27/2015
77	5517 7th St NW	4/27/2015
78	5226 7th St NW	4/27/2015
79	501 Webster St NW	4/27/2015
80	621 Upshur St NW	4/27/2015
81	531 Tennessee Ave NE	4/27/2015
82	5812 7TH ST NW	4/27/2015
83	609 49TH PL NE	4/27/2015
84	5007 13TH ST NW	4/27/2015
85	6205 14TH ST NW	4/27/2015
86	5220 CHEVY CHASE PKWY NW	4/27/2015
87	620 44TH ST NE	4/27/2015
88	834 Delafield Pl NW	5/26/2015
89	910 Farragut St NW	5/26/2015
90	807 Buchanan St NW	5/26/2015
91	913 Hamlin St NE	5/26/2015

Table C.3 Samples Returned but Rejected for Compliance Analysis

No	Address	Bottle Delivery Date	Reject Reason
1	1011 Taylor St NE	1/26/2015	Incomplete chain of custody – usage not identified
2	1262 COLUMBIA RD NW	1/26/2015	No chain of custody provided
3	1305 TAYLOR ST NW	1/26/2015	Customer noted probable plumbing leak on chain of custody. Ice maker on
4	15 Milmarson Pl NW	1/26/2015	Incomplete chain of custody. Ice maker on
5	24 Evarts St NE	2/23/2015	Bottles not labeled No chain of custody provided
6	3033 CAMBRIDGE PL NW	2/23/2015	Ice maker on
7	36 Florida Ave NW	3/23/2015	Stagnation greater than 18 hours
8	3809 ALTON PL NW	3/23/2015	Leak in plumbing
9	412 BRANDYWINE ST SE	3/23/2015	Sampling error - bottle not full
10	449 S St NW	3/23/2015	Incomplete chain of custody – usage not identified
11	4703 Macarthur Blvd NW	4/27/2015	Stagnation less than 6 hours
12	4926 Glenbrook Rd NW	4/27/2015	Stagnation less than 6 hours
13	5003 7TH ST NW	4/27/2015	No stagnation period - Ice maker on, Sprinkler system on, Humidifier on
14	5223 KANSAS AVE NW	4/27/2015	Private service line replacement date unknown
15	6105 Dix St NE	4/27/2015	Stagnation less than 6 hours
16	75 Bates St NW	4/27/2015	Leak in plumbing
17	912 Emerson St NW	5/26/2015	No chain of custody provided

Table C.4 Deviations from Sample Order

No	Address	Scheduled Month	Deviation Reason
1	1911 P ST SE	Feb	Customer did not want to participate this semester
2	2719 O ST NW	Feb	Customer not home in February, requested bottle drop in March
3	3706 35th St NW	Mar	Customer did not want to participate this semester
4	3809 ALTON PL NW	Mar	Customer discovered leak, requested bottle drop in April
5	3755 MCKINLEY ST NW	Jan	Requested to be added to Pool ¹
6	2032 37TH ST NW	Jan	Requested to be added to Pool ¹
7	1831 MONROE ST NE	Jan	Requested to be added to Pool ¹
8	714 4TH ST NE	Jan	Requested to be added to Pool ¹
9	4921 30th PI NW	Feb	Requested to be added to Pool ¹
10	3621 Van Ness St NW	Mar	Requested to be added to Pool ¹
11	314 VARNUM ST NW	Nov 2014	Randomly selected in 2014, did not return bottles during semester. Returned bottles in following 2015 semester

Notes:

- 1) New participant: Customer contacted DC Water to request a lead test, and agreed to participate in the Lead and Copper Monitoring Program. DC Water confirmed that the address met Tier 1 criteria under 40 CFR 141.86(a)(3)(ii) as single family structure with a full lead service line based on DC Water’s customer information and service line inventory records.

Table C.5 Sites with Compliance Results from January 2014 through December 2014 and No Results in January through June 2015

No	Address	Reason
1	10 S St NW	Did not return bottles; See Table C.2
2	1010 10th St NE	Did not return bottles; See Table C.2
3	1011 Taylor St NE	Sample Rejected; See Table C.3
4	109 19th St SE	Did not return bottles; See Table C.2
5	1113 STAPLES ST NE	Did not return bottles; See Table C.2
6	120 VARNUM ST NW	Removed from Sample Pool prior to 2015
7	1305 TAYLOR ST NW	Sample Rejected; See Table C.3
8	1315 FRANKLIN ST NE	Did not return bottles; See Table C.2
9	1318 Wallach Pl NW	Removed from Sample Pool prior to 2015
10	1319 POTOMAC AVE SE	Did not return bottles; See Table C.2
11	1339 CHILDRESS ST NE	Did not return bottles; See Table C.2
12	1412 Shepherd St NW	Did not return bottles; See Table C.2
13	1436 S St NW	Did not return bottles; See Table C.2
14	1453 S St NW	Did not return bottles; See Table C.2
15	15 Milmarson Pl NW	Sample Rejected; See Table C.3
16	1508 GOOD HOPE RD SE	Did not return bottles; See Table C.2
17	1620 Webster St NW	Did not return bottles; See Table C.2
18	1715 IRVING ST NE	Did not return bottles; See Table C.2
19	1736 Bay St SE	Did not return bottles; See Table C.2
20	1826 Jackson St NE	Did not return bottles; See Table C.2
21	2121 3RD ST NE	Did not return bottles; See Table C.2
22	2212 38th St NW	Did not return bottles; See Table C.2
23	223 14th Pl NE	Did not return bottles; See Table C.2
24	231 K St NE	Did not return bottles; See Table C.2
25	2435 33RD ST SE	Did not return bottles; See Table C.2
26	2904 P ST SE	Did not return bottles; See Table C.2
27	2913 Brandywine St NW	Did not return bottles; See Table C.2
28	3218 MORRISON ST NW	Did not return bottles; See Table C.2
29	333 34th St NE	Did not return bottles; See Table C.2
30	3510 QUESADA ST NW	Did not return bottles; See Table C.2
31	36 Florida Ave NW	Sample Rejected; See Table C.3
32	3761 W ST NW	Did not return bottles; See Table C.2
33	3807 KANAWHA ST NW	Did not return bottles; See Table C.2
34	3907 13th St NW	Did not return bottles; See Table C.2
35	4014 Grant St NE	Did not return bottles; See Table C.2
36	412 BRANDYWINE ST SE	Sample Rejected; See Table C.3
37	421 Hamilton St NW	Did not return bottles; See Table C.2
38	4233 JENIFER ST NW	Did not return bottles; See Table C.2
39	4310 37 th St NW	Removed from Sample Pool prior to 2015
40	4401 5TH S NW	Removed from Sample Pool prior to 2015
41	4409 Lowell St NW	Did not return bottles; See Table C.2
42	4703 Macarthur Blvd NW	Sample Rejected; See Table C.3
43	4818 8th ST NW	Did not return bottles; See Table C.2

No	Address	Reason
44	4926 Glenbrook Rd NW	Sample Rejected; See Table C.3
45	5007 13TH ST NW	Did not return bottles; See Table C.2
46	501 Webster St NW	Did not return bottles; See Table C.2
47	5220 CHEVY CHASE PKWY NW	Did not return bottles; See Table C.2
48	5223 KANSAS AVE NW	Sample Rejected; See Table C.3
49	609 49TH PL NE	Did not return bottles; See Table C.2
50	6205 14TH ST NW	Did not return bottles; See Table C.2
51	6209 30TH ST NW	Removed from Sample Pool prior to 2015
52	621 Upshur St NW	Did not return bottles; See Table C.2
53	6210 8th St NW	Did not return bottles; See Table C.2
54	702 9th St SE	Did not return bottles; See Table C.2
55	75 Bates St NW	Sample Rejected; See Table C.3
56	807 Buchanan St NW	Did not return bottles; See Table C.2
57	822 ALLISON ST NW	Removed from Sample Pool prior to 2015
58	912 Emerson St NW	Sample Rejected; See Table C.3
59	913 Hamlin St NE	Did not return bottles; See Table C.2

Table C.6 Customer Notification of Results

No	Address	Collection Date	Date Received from WAD Lab	Date Letter Sent to Customer
1	1635 WEBSTER ST NW	1/29/2015	2/23/2015	2 /27/2015
2	119 16TH ST NE	1/28/2015	2/23/2015	2 /27/2015
3	1649 HARVARD ST NW	1/28/2015	2/23/2015	2 /27/2015
4	1222 HAMILTON ST NW	1/28/2015	2/23/2015	2 /27/2015
5	1353 JEFFERSON ST NW	1/27/2015	2/23/2015	2 /27/2015
6	1412 S St NW	1/27/2015	2/23/2015	2 /27/2015
7	125 Madison St NW	1/28/2015	2/23/2015	2 /27/2015
8	1211 Carrollsburg Pl SW	1/28/2015	2/23/2015	2 /27/2015
9	1357 C St NE	1/28/2015	2/23/2015	2 /27/2015
10	1003 Otis St NE	1/28/2015	2/23/2015	2 /27/2015
11	1519 Olive St NE	1/28/2015	2/23/2015	2 /27/2015
12	1505 Buchanan St NW	1/28/2015	2/23/2015	2 /27/2015
13	1346 F St NE	1/28/2015	2/23/2015	2 /27/2015
14	1613 Webster St NW	1/28/2015	2/23/2015	2 /27/2015
15	12 14TH ST SE	1/28/2015	2/23/2015	2 /27/2015
16	1659 NEWTON ST NW	1/30/2015	2/23/2015	2 /27/2015
17	1513 27TH ST NW	1/29/2015	2/23/2015	2 /27/2015
18	1375 MONROE ST NW	1/27/2015	2/23/2015	2 /27/2015
19	1020 INDEPENDENCE AVE SE	1/26/2015	2/23/2015	2 /27/2015
20	15 MADISON ST NW	1/29/2015	2/23/2015	2 /27/2015
21	1529 27TH ST NW	1/28/2015	2/23/2015	2 /27/2015
22	313 5TH ST NE	1/28/2015	2/23/2015	2 /27/2015
23	3755 MCKINLEY ST NW	1/28/2015	2/23/2015	2 /27/2015
24	2032 37TH ST NW	1/28/2015	2/23/2015	2 /27/2015
25	1831 MONROE ST NE	1/28/2015	2/23/2015	2 /27/2015
26	322 TENNESSEE AVE NE	2/25/2015	3/13/2015	3 /17/2015
27	1850 2ND ST NW	2/23/2015	3/13/2015	3 /17/2015
28	3030 44TH ST NW	2/25/2015	3/13/2015	3 /17/2015
29	1808 KEARNEY ST NE	2/25/2015	3/13/2015	3 /17/2015
30	331 RALEIGH ST SE	2/25/2015	3/13/2015	3 /17/2015
31	228 V ST NE	2/24/2015	3/13/2015	3 /17/2015
32	2830 BRENTWOOD RD NE	2/23/2015	3/13/2015	3 /17/2015
33	1706 NEW JERSEY AVE NW	2/25/2015	3/13/2015	3 /17/2015
34	3206 38th St NW	3/2/2015	3/13/2015	3 /17/2015
35	2408 2nd St NE	2/23/2015	3/13/2015	3 /17/2015
36	3211 Central Ave NE	2/25/2015	3/13/2015	3 /17/2015
37	1703 D St NE	2/24/2015	3/13/2015	3 /17/2015
38	307 7th St NE	2/25/2015	3/13/2015	3 /17/2015
39	3036 P St NW	2/25/2015	3/13/2015	3 /17/2015
40	308 9th St SE	2/23/2015	3/13/2015	3 /17/2015
41	2923 Cathedral AVE NW	2/24/2015	3/13/2015	3 /17/2015
42	309 11TH ST SE	2/24/2015	3/13/2015	3 /17/2015
43	2832 BRENTWOOD RD NE	2/25/2015	3/13/2015	3 /17/2015
44	1738 ALLISON ST NW	2/25/2015	3/13/2015	3 /17/2015

No	Address	Collection Date	Date Received from WAD Lab	Date Letter Sent to Customer
45	313 10TH ST SE	2/24/2015	3/13/2015	3 /17/2015
46	2804 6TH ST NE	2/24/2015	3/13/2015	3 /17/2015
47	3309 35TH ST NW	2/25/2015	3/13/2015	3 /17/2015
48	2036 17TH ST NW	2/25/2015	3/13/2015	3 /17/2015
49	4921 30th PI NW	2/24/2015	3/13/2015	3 /17/2015
50	2007 37TH ST NW	3/1/2015	4/2/2015	4 /2 /2015
51	3908 13TH ST NW	3/26/2015	4/24/2015	4 /24/2015
52	3405 HOLMEAD PL NW	3/26/2015	4/6/2015	4 /8 /2015
53	3621 Van Ness St NW	3/25/2015	4/6/2015	4 /8 /2015
54	3913 8TH ST NW	3/25/2015	4/6/2015	4 /8 /2015
55	4131 YUMA ST NW	3/25/2015	4/6/2015	4 /8 /2015
56	3917 8th St NW	3/25/2015	4/6/2015	4 /8 /2015
57	3710 Huntington St NW	3/25/2015	4/6/2015	4 /8 /2015
58	4215 39th St NW	3/24/2015	4/6/2015	4 /8 /2015
59	3416 9th St NE	3/24/2015	4/6/2015	4 /8 /2015
60	4418 14th St NE	3/24/2015	4/6/2015	4 /8 /2015
61	4120 Grant St NE	3/25/2015	4/6/2015	4 /8 /2015
62	336 Quackenbos St NE	3/25/2015	4/6/2015	4 /8 /2015
63	4214 8th St NW	3/26/2015	4/6/2015	4 /8 /2015
64	3727 T St NW	3/25/2015	4/6/2015	4 /8 /2015
65	413 4th St SE	3/25/2015	4/6/2015	4 /8 /2015
66	3625 Albermarle St NW	3/25/2015	4/6/2015	4 /8 /2015
67	450 Newton PI NW	3/30/2015	4/6/2015	4 /8 /2015
68	3636 13TH ST NW	3/25/2015	4/6/2015	4 /8 /2015
69	3722 MCKINLEY ST NW	3/25/2015	4/6/2015	4 /8 /2015
70	3724 CHESAPEAKE ST NW	3/24/2015	4/6/2015	4 /8 /2015
71	2719 O ST NW	3/24/2015	4/6/2015	4 /8 /2015
72	4447 HAWTHORNE ST NW	3/25/2015	4/6/2015	4 /8 /2015
73	4413 5th St NW	3/25/2015	4/6/2015	4 /8 /2015
74	414 G ST NE	3/26/2015	4/6/2015	4 /8 /2015
75	4054 GRANT ST NE	3/25/2015	4/6/2015	4 /8 /2015
76	4525 15TH ST NW	3/23/2015	4/6/2015	4 /8 /2015
77	4425 14th St NE	3/25/2015	4/6/2015	4 /8 /2015
78	4002 ILLINOIS AVE NW	3/25/2015	4/6/2015	4 /8 /2015
79	3916 5TH ST NW	3/25/2015	4/6/2015	4 /8 /2015
80	4550 30TH ST NW	4/20/2015	5/14/2015	5 /15/2015
81	5301 RENO RD NW	4/28/2015	5/22/2015	5 /27/2015
82	3809 ALTON PL NW	4/29/2015	5/22/2015	5 /27/2015
83	5404 39TH ST NW	4/29/2015	5/22/2015	5 /27/2015
84	804 Delafield PI NW	4/29/2015	5/22/2015	5 /27/2015
85	4627 49th St NW	4/29/2015	5/22/2015	5 /27/2015
86	619 12th St NE	4/29/2015	5/22/2015	5 /27/2015
87	617 6th St NE	4/29/2015	5/22/2015	5 /27/2015
88	6001 33rd St NW	4/29/2015	5/22/2015	5 /27/2015
89	5923 33rd St NW	4/29/2015	5/22/2015	5 /27/2015
90	5731 3rd PI NW	4/30/2015	5/22/2015	5 /27/2015

No	Address	Collection Date	Date Received from WAD Lab	Date Letter Sent to Customer
91	5234 Illinois Ave NW	4/28/2015	5/22/2015	5 /27/2015
92	6308 8th St NW	4/28/2015	5/22/2015	5 /27/2015
93	53 P St NW	4/29/2015	5/22/2015	5 /27/2015
94	8 N St SW	4/27/2015	5/22/2015	5 /27/2015
95	4806 Kansas Ave NW	4/29/2015	5/22/2015	5 /27/2015
96	5312 ILLINOIS AVE NW	4/28/2015	5/22/2015	5 /27/2015
97	4719 9TH ST NW	4/28/2015	5/22/2015	5 /27/2015
98	6516 8TH ST NW	4/28/2015	5/22/2015	5 /27/2015
99	522 4TH ST SE	4/29/2015	5/22/2015	5 /27/2015
100	502 A ST SE	4/29/2015	5/22/2015	5 /27/2015
101	744 9TH ST SE	4/29/2015	5/22/2015	5 /27/2015
102	905 Kent Pl NE	5/27/2015	6/17/2015	6 /18/2015
103	87 S St NW	5/28/2015	6/17/2015	6 /18/2015
104	4811 Illinois Ave NW	5/4/2015	6/17/2015	6 /18/2015
105	923 9TH ST NE	5/26/2015	6/17/2015	6 /18/2015
106	926 Hamilton St NW	5/28/2015	6/22/2015	6 /22/2015
107	816 MADISON ST NW	5/31/2015	6/22/2015	6 /22/2015
108	314 VARNUM ST NW	6/10/2015	6/22/2015	6 /22/2015

Appendix D – Sample Pool for July Through December 2015

Table D.1 Sample Pool

No	Address	Pipe Material
1	10 S St NW	Lead
2	1003 Otis St NE	Lead
3	1003 Quebec Pl NW	Lead
4	1010 10th St NE	Lead
5	1011 Taylor St NE	Lead
6	1020 INDEPENDENCE AVE SE	Lead
7	109 19th St SE	Lead
8	1113 STAPLES ST NE	Lead
9	119 16TH ST NE	Lead
10	123 TENNESSEE AVE NE	Lead
11	125 Madison St NW	Lead
12	1262 COLUMBIA RD NW	Lead
13	1305 TAYLOR ST NW	Lead
14	1315 FRANKLIN ST NE	Lead
15	1331 Irving St NE	Lead
16	1339 CHILDRESS ST NE	Lead
17	1346 F St NE	Lead
18	1357 C St NE	Lead
19	1375 MONROE ST NW	Lead
20	1410 ALLISON ST NW	Lead
21	1420 INGRAHAM ST NW	Lead
22	1424 S ST NW	Lead
23	1428 VARNUM ST NW	Lead
24	1453 S St NW	Lead
25	15 MADISON ST NW	Lead
26	15 Milmarson Pl NW	Lead
27	1505 Buchanan St NW	Lead
28	1508 GOOD HOPE RD SE	Lead
29	1513 27TH ST NW	Lead
30	1519 Olive St NE	Lead
31	1529 27TH ST NW	Lead
32	1529 UPSHUR ST NW	Lead
33	1613 Webster St NW	Lead
34	1620 Webster St NW	Lead
35	1627 Gales St NE	Lead
36	1635 WEBSTER ST NW	Lead
37	1649 HARVARD ST NW	Lead
38	1659 NEWTON ST NW	Lead

No	Address	Pipe Material
39	1703 D St NE	Lead
40	1705 D St NE	Lead
41	1706 NEW JERSEY AVE NW	Lead
42	1715 IRVING ST NE	Lead
43	1738 ALLISON ST NW	Lead
44	1826 Jackson St NE	Lead
45	1831 MONROE ST NE	Lead
46	1911 P ST SE	Lead
47	1916 PARK RD NW	Lead
48	2007 37TH ST NW	Lead
49	2032 37TH ST NW	Lead
50	2036 17TH ST NW	Lead
51	2107 2nd St NE	Lead
52	2121 3RD ST NE	Lead
53	2212 38th St NW	Lead
54	228 V ST NE	Lead
55	2435 33RD ST SE	Lead
56	2719 O ST NW	Lead
57	2804 6TH ST NE	Lead
58	2830 BRENTWOOD RD NE	Lead
59	2832 BRENTWOOD RD NE	Lead
60	2904 P ST SE	Lead
61	2913 Brandywine St NW	Lead
62	2923 Cathedral AVE NW	Lead
63	3033 CAMBRIDGE PL NW	Lead
64	307 7th St NE	Lead
65	309 11TH ST SE	Lead
66	313 5TH ST NE	Lead
67	314 VARNUM ST NW	Lead
68	3206 38th St NW	Lead
69	3211 Central Ave NE	Lead
70	3218 MACOMB ST NW	Lead
71	3218 MORRISON ST NW	Lead
72	322 TENNESSEE AVE NE	Lead
73	3309 35TH ST NW	Lead
74	336 Quackenbos St NE	Lead
75	3405 HOLMEAD PL NW	Lead
76	3510 QUESADA ST NW	Lead
77	3621 Van Ness St NW	Lead
78	3625 Albermarle St NW	Lead
79	3636 13TH ST NW	Lead
80	37 U ST NE	Lead

No	Address	Pipe Material
81	3706 35th St NW	Lead
82	3710 Huntington St NW	Lead
83	3724 CHESAPEAKE ST NW	Lead
84	3727 T St NW	Lead
85	3761 W ST NW	Lead
86	3908 13TH ST NW	Lead
87	3916 5TH ST NW	Lead
88	4002 ILLINOIS AVE NW	Lead
89	4014 Grant St NE	Lead
90	412 BRANDYWINE ST SE	Lead
91	4120 Grant St NE	Lead
92	4131 YUMA ST NW	Lead
93	414 G ST NE	Lead
94	421 Hamilton St NW	Lead
95	4214 8th St NW	Lead
96	4233 JENIFER ST NW	Lead
97	424 Luray Pl NW	Lead
98	4408 HAYES ST NE	Lead
99	4409 Lowell St NW	Lead
100	4413 5th St NW	Lead
101	4418 14th St NE	Lead
102	4425 14th St NE	Lead
103	4447 HAWTHORNE ST NW	Lead
104	449 S St NW	Lead
105	450 Newton Pl NW	Lead
106	4525 15TH ST NW	Lead
107	4550 30TH ST NW	Lead
108	4610 KANSAS AVE NW	Lead
109	4627 49th St NW	Lead
110	4703 Macarthur Blvd NW	Lead
111	4719 9TH ST NW	Lead
112	4806 Kansas Ave NW	Lead
113	4811 Illinois Ave NW	Lead
114	4921 30th Pl NW	Lead
115	4926 Glenbrook Rd NW	Lead
116	5007 13TH ST NW	Lead
117	502 A ST SE	Lead
118	5024 7th St NW	Lead
119	522 4TH ST SE	Lead
120	5220 CHEVY CHASE PKWY NW	Lead
121	5223 KANSAS AVE NW	Lead
122	5234 Illinois Ave NW	Lead

No	Address	Pipe Material
123	531 Tennessee Ave NE	Lead
124	5312 ILLINOIS AVE NW	Lead
125	5318 9TH ST NW	Lead
126	5731 3rd PI NW	Lead
127	5923 33rd St NW	Lead
128	6001 33rd St NW	Lead
129	609 49TH PL NE	Lead
130	6105 Dix St NE	Lead
131	617 6th St NE	Lead
132	619 12th St NE	Lead
133	620 44TH ST NE	Lead
134	6205 14TH ST NW	Lead
135	6308 8th St NW	Lead
136	636 ROCK CRK CHURCH RD NW	Lead
137	6516 8TH ST NW	Lead
138	702 9th St SE	Lead
139	714 4th St NE	Lead
140	75 Bates St NW	Lead
141	8 N St SW	Lead
142	804 Delafield PI NW	Lead
143	807 Buchanan St NW	Lead
144	816 MADISON ST NW	Lead
145	87 S St NW	Lead
146	905 Kent PI NE	Lead
147	912 Emerson St NW	Lead
148	923 9TH ST NE	Lead
149	926 Hamilton St NW	Lead
150	12 14TH ST SE	Partial Lead
151	1211 Carrollsburg PI SW	Partial Lead
152	1222 HAMILTON ST NW	Partial Lead
153	1319 POTOMAC AVE SE	Partial Lead
154	1353 JEFFERSON ST NW	Partial Lead
155	1412 S St NW	Partial Lead
156	1420 Hamlin St NE	Partial Lead
157	1436 S St NW	Partial Lead
158	1671 Rosedale St NE	Partial Lead
159	1736 Bay St SE	Partial Lead
160	1808 KEARNEY ST NE	Partial Lead
161	1850 2ND ST NW	Partial Lead
162	223 14th PI NE	Partial Lead
163	231 K St NE	Partial Lead
164	2408 2nd St NE	Partial Lead

No	Address	Pipe Material
165	3030 44TH ST NW	Partial Lead
166	3036 P St NW	Partial Lead
167	308 9th St SE	Partial Lead
168	313 10TH ST SE	Partial Lead
169	317 9th St SE	Partial Lead
170	3202 38TH ST NW	Partial Lead
171	3301 BROWN St NW	Partial Lead
172	333 34th St NE	Partial Lead
173	3416 9th St NE	Partial Lead
174	36 Florida Ave NW	Partial Lead
175	3722 MCKINLEY ST NW	Partial Lead
176	3809 ALTON PL NW	Partial Lead
177	3907 13th St NW	Partial Lead
178	3913 8TH ST NW	Partial Lead
179	3917 8th St NW	Partial Lead
180	413 4th St SE	Partial Lead
181	420 Kenyon St NW	Partial Lead
182	4215 39th St NW	Partial Lead
183	4818 8th ST NW	Partial Lead
184	5003 7TH ST NW	Partial Lead
185	53 P St NW	Partial Lead
186	53 V St NW	Partial Lead
187	5301 RENO RD NW	Partial Lead
188	5404 39TH ST NW	Partial Lead
189	605 ROCK CRK CHURCH RD NW	Partial Lead
190	6213 7TH ST NW	Partial Lead
191	744 9TH ST SE	Partial Lead

Table D.2 Site Changes

No	Address	Change
1	1831 MONROE ST NE	Customer requested lead test and added to Sample Pool in 2015
2	2032 37TH ST NW	Customer requested lead test and added to Sample Pool in 2015
3	3621 Van Ness St NW	Customer requested lead test and added to Sample Pool in 2015
4	4921 30th PI NW	Customer requested lead test and added to Sample Pool in 2015
5	714 4th St NE	Customer requested lead test and added to Sample Pool in 2015
6	314 Varnum St NW	Customer previously removed from Sample Pool and returned bottles this semester; see Table C.4
7	1603 Massachusetts Ave SE	Removed; did not return valid samples in last four sample events
8	213 49th St NE	Removed; did not return valid samples in last four sample events
9	230 G St NE	Removed; did not return valid samples in last four sample events
10	24 Evarts St NE	Removed; did not return valid samples in last four sample events
11	302 RITTENHOUSE ST NW	Removed; did not return valid samples in last four sample events
12	3601 WARREN ST NW	Removed; did not return valid samples in last four sample events
13	4307 CHESAPEAKE ST NW	Removed; did not return valid samples in last four sample events
14	5226 7th St NW	Removed; did not return valid samples in last four sample events
15	5517 7th St NW	Removed; did not return valid samples in last four sample events
16	580 49th PI NE	Removed; did not return valid samples in last four sample events
17	5812 7TH ST NW	Removed; did not return valid samples in last four sample events
18	617 M St NE	Removed; did not return valid samples in last four sample events
19	641 Gallatin St NW	Removed; did not return valid samples in last four sample events
20	834 Delafield PI NW	Removed; did not return valid samples in last four sample events
21	3807 KANAWHA ST NW	Removed; no lead, full service line replacement 3/25/2015
22	3755 MCKINLEY ST NW	Removed; no lead, full service line replacement 4/30/2015
23	4054 GRANT ST NE	Removed; no lead, replaced lead service on public side 4/21/2015 and connected to copper
24	331 RALEIGH ST SE	Removed; no lead, test pit copper on 3/16/2015
25	1412 Shepherd St NW	Removed; request no participation
26	3361 Stuyvesant PI NW	Removed; request no participation
27	501 Webster St NW	Removed; request no participation
28	621 Upshur St NW	Removed; request no participation
29	6210 8th St NW	Removed; request no participation
30	910 Farragut St NW	Removed; request no participation
31	913 Hamlin St NE	Removed; request no participation
32	744 9TH ST SE	Pipe material description changed from full Lead to Partial Lead; customer reported on May 2015 chain of custody that they changed the private portion in 2000.

Attachment 1

Washington Aqueduct Test Results for LCR Compliance Samples

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1501200-001


SAMPLE INFORMATION

Sample Number: 1501200-001 Customer Sample Number: 3002494 Project: LCR
Location: 1st draw 1412 S ST NW Type: Dist.

Collection Date: 1/27/2015 Collection Time: 9:30 Sampler: HOME OWNER Received Date and Time: 1/30/2015 8:30:25 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.013 mg/L	2/2/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.074 mg/L	2/2/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0006 mg/L	2/2/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1501200-002


SAMPLE INFORMATION

Sample Number: 1501200-002 Customer Sample Number: 3002494 Project: LCR
Location: 2nd draw 1412 S ST NW Type: Dist.

Collection Date: 1/27/2015 Collection Time: 9:30 Sampler: HOME OWNER Received Date and Time: 1/30/2015 8:30:25 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.020 mg/L	2/2/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.124 mg/L	2/2/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0002 mg/L	2/2/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1501200-003


SAMPLE INFORMATION

Sample Number: 1501200-003 Customer Sample Number: 3049333 Project: LCR
Location: 1st draw 1353 JEFFERSON ST. NW Type: Dist.

Collection Date: 1/27/2015 Collection Time: 7:25 Sampler: HOME OWNER Received Date and Time: 1/30/2015 8:30:25 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	2/2/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.045 mg/L	2/2/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0010 mg/L	2/2/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Robert P. Hoffa, Acting Laboratory Manager

2/23/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1501200-004


SAMPLE INFORMATION

Sample Number: 1501200-004 Customer Sample Number: 3049333 Project: LCR
Location: 2nd draw 1353 JEFFERSON ST. NW Type: Dist.

Collection Date: 1/27/2015 Collection Time: 7:27 Sampler: HOME OWNER Received Date and Time: 1/30/2015 8:30:25 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	2/2/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.029 mg/L	2/2/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0011 mg/L	2/2/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Robert P. Hoffa, Acting Laboratory Manager

2/23/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1501200-005


SAMPLE INFORMATION

Sample Number: 1501200-005 Customer Sample Number: 3034000 Project: LCR
Location: 1st draw 1649 HARVARD ST NW Type: Dist.

Collection Date: 1/28/2015 Collection Time: 7:25 Sampler: HOME OWNER Received Date and Time: 1/30/2015 8:30:25 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.306 mg/L	2/2/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.037 mg/L	2/2/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0014 mg/L	2/2/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Robert P. Hoffa, Acting Laboratory Manager

2/23/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1501200-006


SAMPLE INFORMATION

Sample Number: 1501200-006 Customer Sample Number: 3034000 Project: LCR
Location: 2nd draw 1649 HARVARD ST NW Type: Dist.

Collection Date: 1/28/2015 Collection Time: 7:27 Sampler: HOME OWNER Received Date and Time: 1/30/2015 8:30:25 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.166 mg/L	2/2/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.027 mg/L	2/2/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0013 mg/L	2/2/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Robert P. Hoffa, Acting Laboratory Manager

2/23/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1501200-007


SAMPLE INFORMATION

Sample Number: 1501200-007 Customer Sample Number: 3009928 Project: LCR
Location: 1st draw 2032 37TH ST., NW Type: Dist.

Collection Date: 1/28/2015 Collection Time: 5:39 Sampler: HOME OWNER Received Date and Time: 1/30/2015 8:30:25 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	2/2/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.066 mg/L	2/2/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0006 mg/L	2/2/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1501200-008

SAMPLE INFORMATION

Sample Number: 1501200-008 Customer Sample Number: 3009928 Project: LCR
Location: 2nd draw 2032 37TH ST., NW Type: Dist.


Collection Date: 1/28/2015 Collection Time: 5:40 Sampler: HOME OWNER Received Date and Time: 1/30/2015 8:30:25 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.051 mg/L	2/2/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.013 mg/L	2/2/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0025 mg/L	2/2/2015	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1501200-009


SAMPLE INFORMATION

Sample Number: 1501200-009 Customer Sample Number: 3029985 Project: LCR
Location: 1st draw 1375 MONROE ST NW Type: Dist.

Collection Date: 1/27/2015 Collection Time: 6:32 Sampler: HOME OWNER Received Date and Time: 1/30/2015 8:30:25 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.014 mg/L	2/2/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.061 mg/L	2/2/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0008 mg/L	2/2/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1501200-010

SAMPLE INFORMATION

Sample Number: 1501200-010 Customer Sample Number: 3029985 Project: LCR
Location: 2nd draw 1375 MONROE ST NW Type: Dist.


Collection Date: 1/27/2015 Collection Time: 6:33 Sampler: HOME OWNER Received Date and Time: 1/30/2015 8:30:25 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.021 mg/L	2/2/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.018 mg/L	2/2/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0011 mg/L	2/2/2015	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502027-001


SAMPLE INFORMATION

Sample Number: 1502027-001 Customer Sample Number: 3073669 Project: LCR
Location: 1st draw 1020 INDEPENDENCE AVE SE Type: Dist.

Collection Date: 1/26/2015 Collection Time: 20:00 Sampler: HOME OWNER Received Date and Time: 2/4/2015 12:38:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.021 mg/L	2/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.021 mg/L	2/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0008 mg/L	2/12/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Robert P. Hoffa, Acting Laboratory Manager

2/23/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502027-002


SAMPLE INFORMATION

Sample Number: 1502027-002 Customer Sample Number: 3073669 Project: LCR
Location: 2nd draw 1020 INDEPENDENCE AVE SE Type: Dist.

Collection Date: 1/26/2015 Collection Time: 20:00 Sampler: HOME OWNER Received Date and Time: 2/4/2015 12:38:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.014 mg/L	2/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.004 mg/L	2/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0004 mg/L	2/12/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502027-003


SAMPLE INFORMATION

Sample Number: 1502027-003 Customer Sample Number: 3029171 Project: LCR
Location: 1st draw 1613 WEBSTER ST. NW Type: Dist.

Collection Date: 1/28/2015 Collection Time: 7:13 Sampler: HOME OWNER Received Date and Time: 2/4/2015 12:38:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.014 mg/L	2/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.051 mg/L	2/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0003 mg/L	2/12/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Robert P. Hoffa, Acting Laboratory Manager

2/23/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502027-004


SAMPLE INFORMATION

Sample Number: 1502027-004 Customer Sample Number: 3029171 Project: LCR
Location: 2nd draw 1613 WEBSTER ST. NW Type: Dist.

Collection Date: 1/28/2015 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 2/4/2015 12:38:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.016 mg/L	2/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.023 mg/L	2/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	2/12/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Robert P. Hoffa, Acting Laboratory Manager

2/23/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502027-005


SAMPLE INFORMATION

Sample Number: 1502027-005 Customer Sample Number: 3092716 Project: LCR
Location: 1st draw 1211 CARROLLSBURG PL SW Type: Dist.

Collection Date: 1/28/2015 Collection Time: 8:37 Sampler: HOME OWNER Received Date and Time: 2/4/2015 12:38:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.019 mg/L	2/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.109 mg/L	2/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0007 mg/L	2/12/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Robert P. Hoffa, Acting Laboratory Manager

2/23/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502027-006

SAMPLE INFORMATION

Sample Number: 1502027-006 Customer Sample Number: 3092716 Project: LCR
Location: 2nd draw 1211 CARROLLSBURG PL SW Type: Dist.

Collection Date: 1/28/2015 Collection Time: 8:39 Sampler: HOME OWNER Received Date and Time: 2/4/2015 12:38:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.033 mg/L	2/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.065 mg/L	2/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0009 mg/L	2/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502027-007


SAMPLE INFORMATION

Sample Number: 1502027-007 Customer Sample Number: 3075175 Project: LCR
Location: 1st draw 12 14TH ST SE Type: Dist.

Collection Date: 1/28/2015 Collection Time: 7:45 Sampler: HOME OWNER Received Date and Time: 2/4/2015 12:38:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	2/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.017 mg/L	2/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0014 mg/L	2/12/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502027-008


SAMPLE INFORMATION

Sample Number: 1502027-008 Customer Sample Number: 3075175 Project: LCR
Location: 2nd draw 12 14TH ST SE Type: Dist.

Collection Date: 1/28/2015 Collection Time: 7:48 Sampler: HOME OWNER Received Date and Time: 2/4/2015 12:38:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	2/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.033 mg/L	2/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	2/12/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502027-009

SAMPLE INFORMATION

Sample Number: 1502027-009 Customer Sample Number: 3111360 Project: LCR
Location: 1st draw 1519 OLIVE ST NE Type: Dist.


Collection Date: 1/28/2015 Collection Time: 6:11 Sampler: HOME OWNER Received Date and Time: 2/4/2015 12:38:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.068 mg/L	2/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.006 mg/L	2/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0005 mg/L	2/12/2015	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502027-010

SAMPLE INFORMATION

Sample Number: 1502027-010 Customer Sample Number: 3111360 Project: LCR
Location: 2nd draw 1519 OLIVE ST NE Type: Dist.

Collection Date: 1/28/2015 Collection Time: 6:12 Sampler: HOME OWNER Received Date and Time: 2/4/2015 12:38:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.061 mg/L	2/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.007 mg/L	2/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0004 mg/L	2/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502027-011


SAMPLE INFORMATION

Sample Number: 1502027-011 Customer Sample Number: 3121346 Project: LCR
Location: 1st draw 313 5TH ST NE Type: Dist.

Collection Date: 1/28/2015 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 2/4/2015 12:38:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.035 mg/L	2/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.014 mg/L	2/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0004 mg/L	2/12/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502027-012


SAMPLE INFORMATION

Sample Number: 1502027-012 Customer Sample Number: 3121346 Project: LCR
Location: 2nd draw 313 5TH ST NE Type: Dist.

Collection Date: 1/28/2015 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 2/4/2015 12:38:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.070 mg/L	2/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.005 mg/L	2/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	2/12/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502027-013

SAMPLE INFORMATION

Sample Number: 1502027-013 Customer Sample Number: 3049889 Project: LCR
Location: 1st draw 1222 HAMILTON ST NW Type: Dist.

Collection Date: 1/28/2015 Collection Time: 9:00 Sampler: HOME OWNER Received Date and Time: 2/4/2015 12:38:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.020 mg/L	2/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.007 mg/L	2/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0013 mg/L	2/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502027-014

SAMPLE INFORMATION

Sample Number: 1502027-014 Customer Sample Number: 3049889 Project: LCR
Location: 2nd draw 1222 HAMILTON ST NW Type: Dist.


Collection Date: 1/28/2015 Collection Time: 9:05 Sampler: HOME OWNER Received Date and Time: 2/4/2015 12:38:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.060 mg/L	2/20/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.013 mg/L	2/20/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0017 mg/L	2/20/2015	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502027-015


SAMPLE INFORMATION

Sample Number: 1502027-015 Customer Sample Number: 3039377 Project: LCR
Location: 1st draw 3755 MCKINLEY ST NW Type: Dist.

Collection Date: 1/28/2015 Collection Time: 6:16 Sampler: HOME OWNER Received Date and Time: 2/4/2015 12:38:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.315 mg/L	2/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.072 mg/L	2/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0009 mg/L	2/12/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502027-016

SAMPLE INFORMATION

Sample Number: 1502027-016 Customer Sample Number: 3039377 Project: LCR
Location: 2nd draw 3755 MCKINLEY ST NW Type: Dist.

Collection Date: 1/28/2015 Collection Time: 6:18 Sampler: HOME OWNER Received Date and Time: 2/4/2015 12:38:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	3.74 mg/L	2/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.027 mg/L	2/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0243 mg/L	2/12/2015	RHoffa

Comment: 10x dilution


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502027-017


SAMPLE INFORMATION

Sample Number: 1502027-017 Customer Sample Number: 3007212 Project: LCR
Location: 1st draw 1529 27TH ST NW Type: Dist.

Collection Date: 1/28/2015 Collection Time: 8:30 Sampler: HOME OWNER Received Date and Time: 2/4/2015 12:38:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.021 mg/L	2/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.019 mg/L	2/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0039 mg/L	2/12/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Robert P. Hoffa, Acting Laboratory Manager

2/23/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502027-018


SAMPLE INFORMATION

Sample Number: 1502027-018 Customer Sample Number: 3007212 Project: LCR
Location: 2nd draw 1529 27TH ST NW Type: Dist.

Collection Date: 1/28/2015 Collection Time: 8:31 Sampler: HOME OWNER Received Date and Time: 2/4/2015 12:38:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.030 mg/L	2/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.011 mg/L	2/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0038 mg/L	2/12/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Robert P. Hoffa, Acting Laboratory Manager

2/23/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502027-019


SAMPLE INFORMATION

Sample Number: 1502027-019 Customer Sample Number: 3100201 Project: LCR
Location: 1st draw 1357 C ST NE Type: Dist.

Collection Date: 1/28/2015 Collection Time: 18:10 Sampler: HOME OWNER Received Date and Time: 2/4/2015 12:38:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	2/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.026 mg/L	2/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0050 mg/L	2/12/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Robert P. Hoffa, Acting Laboratory Manager

2/23/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502027-020

SAMPLE INFORMATION

Sample Number: 1502027-020 Customer Sample Number: 3100201 Project: LCR
Location: 2nd draw 1357 C ST NE Type: Dist.


Collection Date: 1/28/2015 Collection Time: 18:12 Sampler: HOME OWNER Received Date and Time: 2/4/2015 12:38:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	2/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.016 mg/L	2/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0101 mg/L	2/12/2015	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502027-021


SAMPLE INFORMATION

Sample Number: 1502027-021 Customer Sample Number: 3111849 Project: LCR
Location: 1st draw 119 16TH ST NE Type: Dist.

Collection Date: 1/28/2015 Collection Time: 7:20 Sampler: HOME OWNER Received Date and Time: 2/4/2015 12:38:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.016 mg/L	2/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.042 mg/L	2/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0032 mg/L	2/12/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502027-022


SAMPLE INFORMATION

Sample Number: 1502027-022 Customer Sample Number: 3111849 Project: LCR
Location: 2nd draw 119 16TH ST NE Type: Dist.

Collection Date: 1/28/2015 Collection Time: 7:25 Sampler: HOME OWNER Received Date and Time: 2/4/2015 12:38:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.021 mg/L	2/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.004 mg/L	2/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0011 mg/L	2/12/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502027-023


SAMPLE INFORMATION

Sample Number: 1502027-023 Customer Sample Number: 3025494 Project: LCR
Location: 1st draw 125 MADISON ST NW Type: Dist.

Collection Date: 1/28/2015 Collection Time: 5:40 Sampler: HOME OWNER Received Date and Time: 2/4/2015 12:38:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.127 mg/L	2/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.019 mg/L	2/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0030 mg/L	2/12/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Robert P. Hoffa, Acting Laboratory Manager

2/23/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502027-024

SAMPLE INFORMATION

Sample Number: 1502027-024 Customer Sample Number: 3025494 Project: LCR
Location: 2nd draw 125 MADISON ST NW Type: Dist.

Collection Date: 1/28/2015 Collection Time: 5:44 Sampler: HOME OWNER Received Date and Time: 2/4/2015 12:38:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.243 mg/L	2/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.004 mg/L	2/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0010 mg/L	2/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502027-025

SAMPLE INFORMATION


Sample Number: 1502027-025 Customer Sample Number: 3100684 Project: LCR
Location: 1st draw 1346 F ST NE Type: Dist.

Collection Date: 1/28/2015 Collection Time: 6:50 Sampler: HOME OWNER Received Date and Time: 2/4/2015 12:38:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.047 mg/L	2/20/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.015 mg/L	2/20/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0022 mg/L	2/20/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502027-026

SAMPLE INFORMATION

Sample Number: 1502027-026 Customer Sample Number: 3100684 Project: LCR
Location: 2nd draw 1346 F ST NE Type: Dist.


Collection Date: 1/28/2015 Collection Time: 6:58 Sampler: HOME OWNER Received Date and Time: 2/4/2015 12:38:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.049 mg/L	2/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.006 mg/L	2/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0080 mg/L	2/12/2015	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502027-027

SAMPLE INFORMATION

Sample Number: 1502027-027 Customer Sample Number: 3105759 Project: LCR
Location: 1st draw 1831 MONROE ST NE Type: Dist.

Collection Date: 1/28/2015 Collection Time: 5:25 Sampler: HOME OWNER Received Date and Time: 2/4/2015 12:38:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.041 mg/L	2/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.039 mg/L	2/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0006 mg/L	2/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502027-028

SAMPLE INFORMATION

Sample Number: 1502027-028 Customer Sample Number: 3105759 Project: LCR
Location: 2nd draw 1831 MONROE ST NE Type: Dist.

Collection Date: 1/28/2015 Collection Time: 5:27 Sampler: HOME OWNER Received Date and Time: 2/4/2015 12:38:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.042 mg/L	2/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.013 mg/L	2/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0024 mg/L	2/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502027-029

SAMPLE INFORMATION

Sample Number: 1502027-029 Customer Sample Number: 3027905 Project: LCR
Location: 1st draw 1505 BUCHANAN ST NW Type: Dist.

Collection Date: 1/28/2015 Collection Time: 7:20 Sampler: HOME OWNER Received Date and Time: 2/4/2015 12:38:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.025 mg/L	2/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.085 mg/L	2/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0034 mg/L	2/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502027-030

SAMPLE INFORMATION

Sample Number: 1502027-030 Customer Sample Number: 3027905 Project: LCR
Location: 2nd draw 1505 BUCHANAN ST NW Type: Dist.

Collection Date: 1/28/2015 Collection Time: 7:20 Sampler: HOME OWNER Received Date and Time: 2/4/2015 12:38:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.019 mg/L	2/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.012 mg/L	2/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0052 mg/L	2/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502027-031

SAMPLE INFORMATION

Sample Number: 1502027-031 Customer Sample Number: 3026151 Project: LCR
Location: 1st draw 15 MADISON ST NW Type: Dist.

Collection Date: 1/29/2015 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 2/4/2015 12:38:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.027 mg/L	2/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.048 mg/L	2/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0011 mg/L	2/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502027-032

SAMPLE INFORMATION

Sample Number: 1502027-032 Customer Sample Number: 3026151 Project: LCR
Location: 2nd draw 15 MADISON ST NW Type: Dist.

Collection Date: 1/29/2015 Collection Time: 6:32 Sampler: HOME OWNER Received Date and Time: 2/4/2015 12:38:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.036 mg/L	2/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.043 mg/L	2/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0015 mg/L	2/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502027-033


SAMPLE INFORMATION

Sample Number: 1502027-033 Customer Sample Number: 3007205 Project: LCR
Location: 1st draw 1513 27TH ST NW Type: Dist.

Collection Date: 1/29/2015 Collection Time: 7:25 Sampler: HOME OWNER Received Date and Time: 2/4/2015 12:38:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.017 mg/L	2/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.075 mg/L	2/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0014 mg/L	2/12/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502027-034


SAMPLE INFORMATION

Sample Number: 1502027-034 Customer Sample Number: 3007205 Project: LCR
Location: 2nd draw 1513 27TH ST NW Type: Dist.

Collection Date: 1/29/2015 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 2/4/2015 12:38:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.023 mg/L	2/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.009 mg/L	2/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0106 mg/L	2/12/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502048-001

SAMPLE INFORMATION

Sample Number: 1502048-001 Customer Sample Number: 3029182 Project: LCR
Location: 1st draw 1635 WEBSTER ST NW Type: Dist.

Collection Date: 1/29/2015 Collection Time: 7:50 Sampler: HOME OWNER Received Date and Time: 2/6/2015 9:05:30 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.215 mg/L	2/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.014 mg/L	2/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0012 mg/L	2/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502048-002

SAMPLE INFORMATION

Sample Number: 1502048-002 Customer Sample Number: 3029182 Project: LCR
Location: 2nd draw 1635 WEBSTER ST NW Type: Dist.

Collection Date: 1/29/2015 Collection Time: 7:55 Sampler: HOME OWNER Received Date and Time: 2/6/2015 9:05:30 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.022 mg/L	2/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.012 mg/L	2/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0002 mg/L	2/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502048-003

SAMPLE INFORMATION

Sample Number: 1502048-003 Customer Sample Number: 3113400 Project: LCR
Location: 1st draw 1003 OTIS ST NE Type: Dist.


Collection Date: 1/28/2015 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 2/6/2015 9:05:30 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.016 mg/L	2/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.181 mg/L	2/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0005 mg/L	2/12/2015	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502048-004

SAMPLE INFORMATION

Sample Number: 1502048-004 Customer Sample Number: 3113400 Project: LCR
Location: 2nd draw 1003 OTIS ST NE Type: Dist.

Collection Date: 1/28/2015 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 2/6/2015 9:05:30 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.108 mg/L	2/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.151 mg/L	2/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0006 mg/L	2/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502086-001


SAMPLE INFORMATION

Sample Number: 1502086-001 Customer Sample Number: 3030778 Project: LCR
Location: 1st draw 1659 NEWTON ST., NW Type: Dist.

Collection Date: 1/30/2015 Collection Time: 7:05 Sampler: HOME OWNER Received Date and Time: 2/11/2015 12:01:08 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	2/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.011 mg/L	2/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0020 mg/L	2/12/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Robert P. Hoffa, Acting Laboratory Manager

2/23/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502086-002


SAMPLE INFORMATION

Sample Number: 1502086-002 Customer Sample Number: 3030778 Project: LCR
Location: 2nd draw 1659 NEWTON ST., NW Type: Dist.

Collection Date: 1/30/2015 Collection Time: 7:05 Sampler: HOME OWNER Received Date and Time: 2/11/2015 12:01:08 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	2/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.005 mg/L	2/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0016 mg/L	2/12/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Robert P. Hoffa, Acting Laboratory Manager

2/23/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503007-001

SAMPLE INFORMATION

Sample Number: 1503007-001 Customer Sample Number: 3029133 Project: LCR
Location: 1st draw 1738 ALLISON ST NW Type: Dist.

Collection Date: 2/25/2015 Collection Time: 7:40 Sampler: HOME OWNER Received Date and Time: 3/2/2015 11:48:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.019 mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.040 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0006 mg/L	3/10/2015	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:

Robert P. Hoffa
Robert P. Hoffa * Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503007-002


SAMPLE INFORMATION

Sample Number: 1503007-002 Customer Sample Number: 3029133 Project: LCR
Location: 2nd draw 1738 ALLISON ST NW Type: Dist.

Collection Date: 2/25/2015 Collection Time: 7:45 Sampler: HOME OWNER Received Date and Time: 3/2/2015 11:48:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.017 mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.021 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0006 mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  3/13/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503007-003

SAMPLE INFORMATION

Sample Number: 1503007-003 Customer Sample Number: 3006211 Project: LCR
Location: 1st draw 1706 NEW JERSEY AVE NW Type: Dist.

Collection Date: 2/25/2015 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 3/2/2015 11:48:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.043 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0008 mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:

Robert P. Hoffa
Ü[à^!óÜP[~-afBç * Åca[|æ[i^ Å ç æ^!

3/13/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503007-004


SAMPLE INFORMATION

Sample Number: 1503007-004 Customer Sample Number: 3006211 Project: LCR
Location: 2nd draw 1706 NEW JERSEY AVE NW Type: Dist.

Collection Date: 2/25/2015 Collection Time: 7:03 Sampler: HOME OWNER Received Date and Time: 3/2/2015 11:48:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.022 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0004 mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 

Ü[à^!óÜP[~-afBç * Åca[|æ[!^ Å ç æ ^!

3/13/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503007-005


SAMPLE INFORMATION

Sample Number: 1503007-005 Customer Sample Number: 3103161 Project: LCR
Location: 1st draw 2408 2ND ST NE Type: Dist.

Collection Date: 2/23/2015 Collection Time: 17:48 Sampler: HOME OWNER Received Date and Time: 3/2/2015 11:48:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.028 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0007 mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  3/13/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503007-006

SAMPLE INFORMATION


Sample Number: 1503007-006 Customer Sample Number: 3103161 Project: LCR
Location: 2nd draw 2408 2ND ST NE Type: Dist.

Collection Date: 2/23/2015 Collection Time: 17:50 Sampler: HOME OWNER Received Date and Time: 3/2/2015 11:48:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.020 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0007 mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Ü[à^!óÜP[~a^Bç * Åca[|a[i^ Á a] æ^!

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503007-007


SAMPLE INFORMATION

Sample Number: 1503007-007 Customer Sample Number: 3073397 Project: LCR
Location: 1st draw 309 11TH ST SE Type: Dist.

Collection Date: 2/24/2015 Collection Time: 18:15 Sampler: HOME OWNER Received Date and Time: 3/2/2015 11:48:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.036 mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.013 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0002 mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  3/13/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503007-008

SAMPLE INFORMATION

Sample Number: 1503007-008 Customer Sample Number: 3073397 Project: LCR
Location: 2nd draw 309 11TH ST SE Type: Dist.

Collection Date: 2/24/2015 Collection Time: 18:17 Sampler: HOME OWNER Received Date and Time: 3/2/2015 11:48:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.035 mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.010 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:

Robert P. Hoffa
Ü[à^!óÜË[~-afBç * Åca[|æ[i^ Å ç æ^!

3/13/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503007-009

SAMPLE INFORMATION

Sample Number: 1503007-009 Customer Sample Number: 3001351 Project: LCR
Location: 1st draw 2036 17TH ST NW Type: Dist.

Collection Date: 2/25/2015 Collection Time: 8:50 Sampler: HOME OWNER Received Date and Time: 3/2/2015 11:48:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.029 mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.035 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:

Robert P. Hoffa
Ü[à^!óÜË[~-afBç * Åca[|æ[!^ Å ç æ^!

3/13/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503007-010

SAMPLE INFORMATION


Sample Number: 1503007-010 Customer Sample Number: 3001351 Project: LCR
Location: 2nd draw 2036 17TH ST NW Type: Dist.

Collection Date: 2/25/2015 Collection Time: 8:50 Sampler: HOME OWNER Received Date and Time: 3/2/2015 11:48:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.019 mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.065 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0004 mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Ü[à^!óÜË[~-afBç * Åca[|æ[!^ Å ç æ^!

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503007-011


SAMPLE INFORMATION

Sample Number: 1503007-011 Customer Sample Number: 3041754 Project: LCR
Location: 1st draw 3309 35TH ST NW Type: Dist.

Collection Date: 2/25/2015 Collection Time: 6:15 Sampler: HOME OWNER Received Date and Time: 3/2/2015 11:48:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.036 mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.081 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0003 mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  3/13/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503007-012


SAMPLE INFORMATION

Sample Number: 1503007-012 Customer Sample Number: 3041754 Project: LCR
Location: 2nd draw 3309 35TH ST NW Type: Dist.

Collection Date: 2/25/2015 Collection Time: 6:17 Sampler: HOME OWNER Received Date and Time: 3/2/2015 11:48:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.071 mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.011 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0003 mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 

Ü[à^!óÜÉ[~-afBç * Åca[|æ[!^ Å ç æ ^!

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503007-013


SAMPLE INFORMATION

Sample Number: 1503007-013 Customer Sample Number: 3111675 Project: LCR
Location: 1st draw 307 7TH ST NE Type: Dist.

Collection Date: 2/25/2015 Collection Time: 6:35 Sampler: HOME OWNER Received Date and Time: 3/2/2015 11:48:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.029 mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.034 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0003 mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 

Ü[à^!óÜP[~af!Bç * Åca[|æ[!^ Å ç æ ^!

3/13/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503007-014

SAMPLE INFORMATION

Sample Number: 1503007-014 Customer Sample Number: 3111675 Project: LCR
Location: 2nd draw 307 7TH ST NE Type: Dist.

Collection Date: 2/25/2015 Collection Time: 6:37 Sampler: HOME OWNER Received Date and Time: 3/2/2015 11:48:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.029 mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.014 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:

Robert P. Hoffa
Ü[à^!óÜÉ[~-afBç * Åca[|æ[!^ Å ç æ^!

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503007-015


SAMPLE INFORMATION

Sample Number: 1503007-015 Customer Sample Number: 3106057 Project: LCR
Location: 1st draw 1808 KEARNY ST NE Type: Dist.

Collection Date: 2/25/2015 Collection Time: 6:45 Sampler: HOME OWNER Received Date and Time: 3/2/2015 11:48:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.037 mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.099 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0009 mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 

Ü[à^!óÜË[~-afBç * Åca[|æ[!^ Å ç æ ^!

3/13/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503007-016


SAMPLE INFORMATION

Sample Number: 1503007-016 Customer Sample Number: 3106057 Project: LCR
Location: 2nd draw 1808 KEARNY ST NE Type: Dist.

Collection Date: 2/25/2015 Collection Time: 6:48 Sampler: HOME OWNER Received Date and Time: 3/2/2015 11:48:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.036 mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.075 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0009 mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  3/13/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503007-017


SAMPLE INFORMATION

Sample Number: 1503007-017 Customer Sample Number: 3008069 Project: LCR
Location: 1st draw 3036 P ST NW Type: Dist.

Collection Date: 2/25/2015 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 3/2/2015 11:48:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.019 mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.062 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 

Ü[à^!óÜP[~-afBç * Åca[|æ[i^ Å ç æ^!

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503007-018


SAMPLE INFORMATION

Sample Number: 1503007-018 Customer Sample Number: 3008069 Project: LCR
Location: 2nd draw 3036 P ST NW Type: Dist.

Collection Date: 2/25/2015 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 3/2/2015 11:48:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.017 mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.010 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  3/13/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503007-019

SAMPLE INFORMATION

Sample Number: 1503007-019 Customer Sample Number: 3073211 Project: LCR
Location: 1st draw 308 9TH ST SE Type: Dist.

Collection Date: 2/23/2015 Collection Time: 17:05 Sampler: HOME OWNER Received Date and Time: 3/2/2015 11:48:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.038 mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.005 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0002 mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:

Robert P. Hoffa
Ü[à^!óÜË[~-af!Bç * Åca[|æ[i^ Å ç æ^!

3/13/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503007-020

SAMPLE INFORMATION

Sample Number: 1503007-020 Customer Sample Number: 3073211 Project: LCR
Location: 2nd draw 308 9TH ST SE Type: Dist.

Collection Date: 2/23/2015 Collection Time: 17:06 Sampler: HOME OWNER Received Date and Time: 3/2/2015 11:48:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.047 mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.006 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0003 mg/L	3/10/2015	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:

Robert P. Hoffa
Ü[à^!óÜË[~-af!Bç * Åca[|æ[i^ Å ç æ^!

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503007-021


SAMPLE INFORMATION

Sample Number: 1503007-021 Customer Sample Number: 3122315 Project: LCR
Location: 1st draw 322 TENNESSEE AVE NE Type: Dist.

Collection Date: 2/25/2015 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 3/2/2015 11:48:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.066 mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.013 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0011 mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  3/13/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503007-022

SAMPLE INFORMATION

Sample Number: 1503007-022 Customer Sample Number: 3107490 Project: LCR
Location: 1st draw 2830 BRENTWOOD RD NE Type: Dist.


Collection Date: 2/23/2015 Collection Time: 19:00 Sampler: HOME OWNER Received Date and Time: 3/2/2015 11:48:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.059 mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.069 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0004 mg/L	3/10/2015	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Ü[à^!óÜÉ[~-afBç * Áca[|æ[i^ Á ç æ^!

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503007-023

SAMPLE INFORMATION

Sample Number: 1503007-023 Customer Sample Number: 3107490 Project: LCR
Location: 2nd draw 2830 BRENTWOOD RD NE Type: Dist.

Collection Date: 2/23/2015 Collection Time: 19:05 Sampler: HOME OWNER Received Date and Time: 3/2/2015 11:48:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.091 mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.048 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0003 mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:

Robert P. Hoffa
Ü[à^!óÜË[~-afBç * Åca[|æ[i^ Å ç æ^!

3/13/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503007-024

SAMPLE INFORMATION

Sample Number: 1503007-024 Customer Sample Number: 3073239 Project: LCR
Location: 1st draw 313 10TH ST SE Type: Dist.

Collection Date: 2/24/2015 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 3/2/2015 11:48:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.015 mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.036 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0004 mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:

Robert P. Hoffa
Ü[à^!óÜP[~-afBç * Sca[|æ[i^ Á a] æ^!

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503007-025


SAMPLE INFORMATION

Sample Number: 1503007-025 Customer Sample Number: 3073239 Project: LCR
Location: 2nd draw 313 10TH ST SE Type: Dist.

Collection Date: 2/24/2015 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 3/2/2015 11:48:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.019 mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.011 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0005 mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 

Ü[à^!óÜË[~-afBç * Åca[|æ[!^ Å ç æ ^!

3/13/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503007-026


SAMPLE INFORMATION

Sample Number: 1503007-026 Customer Sample Number: 3070403 Project: LCR
Location: 1st draw 331 RALEIGH ST SE Type: Dist.

Collection Date: 2/25/2015 Collection Time: 5:32 Sampler: HOME OWNER Received Date and Time: 3/2/2015 11:48:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.013 mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.020 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0003 mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  3/13/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503007-027


SAMPLE INFORMATION

Sample Number: 1503007-027 Customer Sample Number: 3070403 Project: LCR
Location: 2nd draw 331 RALEIGH ST SE Type: Dist.

Collection Date: 2/25/2015 Collection Time: 5:35 Sampler: HOME OWNER Received Date and Time: 3/2/2015 11:48:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.014 mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.006 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0004 mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  3/13/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503007-028


SAMPLE INFORMATION

Sample Number: 1503007-028 Customer Sample Number: 3100985 Project: LCR
Location: 1st draw 1703 D ST NE Type: Dist.

Collection Date: 2/24/2015 Collection Time: 17:10 Sampler: HOME OWNER Received Date and Time: 3/2/2015 11:48:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.020 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0007 mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  3/13/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503007-029

SAMPLE INFORMATION


Sample Number: 1503007-029 Customer Sample Number: 3100985 Project: LCR
Location: 2nd draw 1703 D ST NE Type: Dist.

Collection Date: 2/24/2015 Collection Time: 17:13 Sampler: HOME OWNER Received Date and Time: 3/2/2015 11:48:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.016 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0007 mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Ü[à^!óÜP[~af!Bç * Sca[|a[i^ Á a] æ^!

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503007-030

SAMPLE INFORMATION


Sample Number: 1503007-030 Customer Sample Number: 3037083 Project: LCR
Location: 1st draw 4921 30TH PL NW Type: Dist.

Collection Date: 2/24/2015 Collection Time: 5:00 Sampler: HOME OWNER Received Date and Time: 3/2/2015 11:48:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.065 mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.009 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0010 mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Ü[à^!óÜË[~-afBç * Åca[|æ[i^ Å ç æ^!

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503036-001


SAMPLE INFORMATION

Sample Number: 1503036-001 Customer Sample Number: 3018911 Project: LCR
Location: 1st draw 1850 2ND ST NW Type: Dist.

Collection Date: 2/23/2015 Collection Time: 19:00 Sampler: HOME OWNER Received Date and Time: 3/4/2015 3:47:07 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.054 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0009 mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 

Ü[à^!óÜÉ[~-afBç * Áca[|æ[!^ Á ç æ ^!

3/13/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503036-002


SAMPLE INFORMATION

Sample Number: 1503036-002 Customer Sample Number: 3018911 Project: LCR
Location: 2nd draw 1850 2ND ST NW Type: Dist.

Collection Date: 2/23/2015 Collection Time: 19:00 Sampler: HOME OWNER Received Date and Time: 3/4/2015 3:47:07 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.024 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0025 mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 

Ü[à^!óÜP[~af!Bç * Áca[|a[i^ Á a] a^!

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503036-003


SAMPLE INFORMATION

Sample Number: 1503036-003 Customer Sample Number: 3124875 Project: LCR
Location: 1st draw 228 V ST NE Type: Dist.

Collection Date: 2/24/2015 Collection Time: 19:27 Sampler: HOME OWNER Received Date and Time: 3/4/2015 3:47:07 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.018 mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.027 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0008 mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 

Ü[à^!óÜË[~-afBç * Åca[|æ[!^ Å ç æ ^!

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503036-004


SAMPLE INFORMATION

Sample Number: 1503036-004 Customer Sample Number: 3124875 Project: LCR
Location: 2nd draw 228 V ST NE Type: Dist.

Collection Date: 2/24/2015 Collection Time: 19:31 Sampler: HOME OWNER Received Date and Time: 3/4/2015 3:47:07 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.021 mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.008 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0011 mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 

Ü[à^!óÜË[~-afBç * Åca[|æ[!^ Å ç æ^!

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503036-005

SAMPLE INFORMATION


Sample Number: 1503036-005 Customer Sample Number: 3035494 Project: LCR
Location: 1st draw 2923 CATHEDRAL AVE NW Type: Dist.

Collection Date: 2/24/2015 Collection Time: 9:00 Sampler: HOME OWNER Received Date and Time: 3/4/2015 3:47:07 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.020 mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.015 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Ü[à^!óÜË[~-afBç * Åca[|æ[!^ Å ç æ^!

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503036-006

SAMPLE INFORMATION


Sample Number: 1503036-006 Customer Sample Number: 3035494 Project: LCR
Location: 2nd draw 2923 CATHEDRAL AVE NW Type: Dist.

Collection Date: 2/24/2015 Collection Time: 9:03 Sampler: HOME OWNER Received Date and Time: 3/4/2015 3:47:07 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.026 mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.002 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Ü[à^!óÜË[~-afBç * Åca[|æ[i^ Å ç æ^!

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503036-007

SAMPLE INFORMATION


Sample Number: 1503036-007 Customer Sample Number: 3107442 Project: LCR
Location: 1st draw 3211 CENTRAL AVE NE Type: Dist.

Collection Date: 2/25/2015 Collection Time: 4:21 Sampler: HOME OWNER Received Date and Time: 3/4/2015 3:47:07 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.055 mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.109 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0014 mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Ü[à^!óÜË[~-afBç * Åca[|æ[!^ Å ç æ ^!

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503036-008


SAMPLE INFORMATION

Sample Number: 1503036-008 Customer Sample Number: 3107442 Project: LCR
Location: 2nd draw 3211 CENTRAL AVE NE Type: Dist.

Collection Date: 2/25/2015 Collection Time: 4:28 Sampler: HOME OWNER Received Date and Time: 3/4/2015 3:47:07 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.009 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0041 mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  3/13/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503036-009

SAMPLE INFORMATION


Sample Number: 1503036-009 Customer Sample Number: 3107489 Project: LCR
Location: 1st draw 2832 BRENTWOOD RD NE Type: Dist.

Collection Date: 2/25/2015 Collection Time: 6:21 Sampler: HOME OWNER Received Date and Time: 3/4/2015 3:47:07 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.050 mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.072 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0015 mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Ü[à^!óÜP[~af!Bç * Sca[|a[i^ Á a] æ^!

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503036-010

SAMPLE INFORMATION

Sample Number: 1503036-010 Customer Sample Number: 3107489 Project: LCR
Location: 2nd draw 2832 BRENTWOOD RD NE Type: Dist.

Collection Date: 2/25/2015 Collection Time: 6:25 Sampler: HOME OWNER Received Date and Time: 3/4/2015 3:47:07 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.100 mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.043 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0011 mg/L	3/10/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:

Robert P. Hoffa
Ü[à^!óÜP[~-afBç * Åca[|æ[i^ Å ç æ^!

3/13/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503036-011

SAMPLE INFORMATION


Sample Number: 1503036-011 Customer Sample Number: 3055102 Project: LCR
Location: 1st draw 3030 44TH ST NW Type: Dist.

Collection Date: 2/25/2015 Collection Time: 6:45 Sampler: HOME OWNER Received Date and Time: 3/4/2015 3:47:07 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.042 mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.034 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0035 mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Ü[à^!óÜÉ[~-afBç * Åca[|æ[!^ Å ç æ ^!

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503036-012

SAMPLE INFORMATION


Sample Number: 1503036-012 Customer Sample Number: 3055102 Project: LCR
Location: 2nd draw 3030 44TH ST NW Type: Dist.

Collection Date: 2/25/2015 Collection Time: 6:47 Sampler: HOME OWNER Received Date and Time: 3/4/2015 3:47:07 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.037 mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.020 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0034 mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Ü[à^!óÜP[~af!Bç * Áca[|a[i^ Á a] æ^!

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503036-013

SAMPLE INFORMATION

Sample Number: 1503036-013 Customer Sample Number: 3035196 Project: LCR
Location: 1st draw 3206 38TH ST NW Type: Dist.

Collection Date: 3/2/2015 Collection Time: 7:05 Sampler: HOME OWNER Received Date and Time: 3/4/2015 3:47:07 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.397 mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.025 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0018 mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:

Robert P. Hoffa
Ü[à^!óÜË[~-afBç * Åca[|æ[!^ Å ç æ^!

3/13/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503036-014


SAMPLE INFORMATION

Sample Number: 1503036-014 Customer Sample Number: 3035196 Project: LCR
Location: 2nd draw 3206 38TH ST NW Type: Dist.

Collection Date: 3/2/2015 Collection Time: 7:10 Sampler: HOME OWNER Received Date and Time: 3/4/2015 3:47:07 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.073 mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.014 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0032 mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 

Ü[à^!óÜÉ[~-afBç * Sca[|æ[i^ Á ç æ^!

3/13/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503036-015

SAMPLE INFORMATION


Sample Number: 1503036-015 Customer Sample Number: 3103275 Project: LCR
Location: 1st draw 2804 6TH ST NE Type: Dist.

Collection Date: 2/24/2015 Collection Time: 9:00 Sampler: HOME OWNER Received Date and Time: 3/4/2015 3:47:07 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.070 mg/L	3/10/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.015 mg/L	3/10/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0018 mg/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Ü[à^!óÜË[~-afBç * Åca[|æ[!^ Å ç æ ^!

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503102-001

SAMPLE INFORMATION


Sample Number: 1503102-001 Customer Sample Number: 3009912 Project: LCR
Location: 1st Draw 2007 37TH ST NW Type: Dist.

Collection Date: 3/1/2015 Collection Time: 7:17 Sampler: HOME OWNER Received Date and Time: 3/13/2015 4:03:31 PM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	10 ug/L	0.01 mg/L	0.011 mg/L	3/27/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.2 ug/L	0.0002 mg/L	0.111 mg/L	3/27/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.2 ug/L	0.0002 mg/L	0.0004 mg/L	3/27/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503102-002


SAMPLE INFORMATION

Sample Number: 1503102-002 Customer Sample Number: 3009912 Project: LCR
Location: 2nd Draw 2007 37TH ST NW Type: Dist.

Collection Date: 3/1/2015 Collection Time: 7:18 Sampler: HOME OWNER Received Date and Time: 3/13/2015 4:03:31 PM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	10 ug/L	0.01 mg/L	ND mg/L	3/27/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	0.2 ug/L	0.0002 mg/L	0.027 mg/L	3/27/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	0.2 ug/L	0.0002 mg/L	0.0003 mg/L	3/27/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  4/2/2015
Robert P. Hoffa, Acting Laboratory Manager Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503223-001

SAMPLE INFORMATION


Sample Number: 1503223-001 Customer Sample Number: 3114988 Project: LCR
Location: 1st Draw 4425 14TH ST NE Type: Dist.

Collection Date: 3/25/2015 Collection Time: 5:40 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:32:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.164 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.043 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0004 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa * Laboratory Manager

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503223-002

SAMPLE INFORMATION


Sample Number: 1503223-002 Customer Sample Number: 3114988 Project: LCR
Location: 2nd Draw 4425 14TH ST NE Type: Dist.

Collection Date: 3/25/2015 Collection Time: 5:40 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:32:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.017 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0004 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Ü[à^!óÜP[~a^Bç * Åca[|a[i^ Á a] æ^!

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503223-003


SAMPLE INFORMATION

Sample Number: 1503223-003 Customer Sample Number: 3020685 Project: LCR
Location: 1st Draw 3913 8TH ST NW Type: Dist.

Collection Date: 3/25/2015 Collection Time: 19:45 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:32:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	1.50 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.027 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0002 mg/L	4/3/2015	RHoffa

Comment: 10 X dilution
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  4/6/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503223-004


SAMPLE INFORMATION

Sample Number: 1503223-004 Customer Sample Number: 3020685 Project: LCR
Location: 2nd Draw 3913 8TH ST NW Type: Dist.

Collection Date: 3/25/2015 Collection Time: 19:50 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:32:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.059 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.006 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  4/6/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503223-005

SAMPLE INFORMATION


Sample Number: 1503223-005 Customer Sample Number: 3021581 Project: LCR
Location: 1st Draw 4413 5TH ST NW Type: Dist.

Collection Date: 3/25/2015 Collection Time: 7:20 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:32:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.002 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0005 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Ü[à^!óÜP[~af!Bç * Åca[|af |' Å ç Å^!

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503223-006

SAMPLE INFORMATION


Sample Number: 1503223-006 Customer Sample Number: 3021581 Project: LCR
Location: 2nd Draw 4413 5TH ST NW Type: Dist.

Collection Date: 3/25/2015 Collection Time: 7:20 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:32:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.001 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0003 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Ü[à^!óÜË[~-af!Bç * Åca[|æ[!^ Å ç æ^!

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503223-007


SAMPLE INFORMATION

Sample Number: 1503223-007 Customer Sample Number: 3029819 Project: LCR
Location: 1st Draw 3405 HOLMEAD PL NW Type: Dist.

Collection Date: 3/26/2015 Collection Time: 5:40 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:32:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.093 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.039 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0005 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  4/6/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503223-008


SAMPLE INFORMATION

Sample Number: 1503223-008 Customer Sample Number: 3029819 Project: LCR
Location: 2nd Draw 3405 HOLMEAD PL NW Type: Dist.

Collection Date: 3/26/2015 Collection Time: 5:42 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:32:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.056 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.042 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0003 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  4/6/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503223-009


SAMPLE INFORMATION

Sample Number: 1503223-009 Customer Sample Number: 3056809 Project: LCR
Location: 1st Draw 4214 8TH ST NW Type: Dist.

Collection Date: 3/26/2015 Collection Time: 6:04 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:32:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.057 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.008 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0005 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  4/6/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503223-010


SAMPLE INFORMATION

Sample Number: 1503223-010 Customer Sample Number: 3056809 Project: LCR
Location: 2nd Draw 4214 8TH ST NW Type: Dist.

Collection Date: 3/26/2015 Collection Time: 6:05 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:32:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.044 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.004 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0004 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  4/6/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503223-011


SAMPLE INFORMATION

Sample Number: 1503223-011 Customer Sample Number: 3010741 Project: LCR
Location: 1st Draw 3727 T ST NW Type: Dist.

Collection Date: 3/25/2015 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:32:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.149 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.030 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0040 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  4/6/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503223-012


SAMPLE INFORMATION

Sample Number: 1503223-012 Customer Sample Number: 3010741 Project: LCR
Location: 2nd Draw 3727 T ST NW Type: Dist.

Collection Date: 3/25/2015 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:32:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.218 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.007 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0060 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  4/6/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503223-013


SAMPLE INFORMATION

Sample Number: 1503223-013 Customer Sample Number: 3051041 Project: LCR
Location: 1st Draw 4002 ILLINOIS AVE NW Type: Dist.

Collection Date: 3/25/2015 Collection Time: 4:42 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:32:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.022 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.002 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0003 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  4/6/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503223-014

SAMPLE INFORMATION

Sample Number: 1503223-014 Customer Sample Number: 3051041 Project: LCR
Location: 2nd Draw 4002 ILLINOIS AVE NW Type: Dist.

Collection Date: 3/25/2015 Collection Time: 4:44 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:32:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.020 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.003 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0018 mg/L	4/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: *Robert P. Hoffa* 4/6/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503223-015


SAMPLE INFORMATION

Sample Number: 1503223-015 Customer Sample Number: 3072261 Project: LCR
Location: 1st Draw 413 4TH ST SE Type: Dist.

Collection Date: 3/25/2015 Collection Time: 6:09 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:32:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.023 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.023 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0002 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  4/6/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503223-016


SAMPLE INFORMATION

Sample Number: 1503223-016 Customer Sample Number: 3072261 Project: LCR
Location: 2nd Draw 413 4TH ST SE Type: Dist.

Collection Date: 3/25/2015 Collection Time: 6:11 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:32:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.029 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.036 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0003 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  4/6/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503223-017

SAMPLE INFORMATION


Sample Number: 1503223-017 Customer Sample Number: 3117544 Project: LCR
Location: 1st Draw 336 QUACKENBOS ST. NE Type: Dist.

Collection Date: 3/25/2015 Collection Time: 5:44 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:32:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.295 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.021 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0010 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Ü[à^!óÜP[~af!Bç * Åca[|æ[!^ Å ç æ^!

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503223-018

SAMPLE INFORMATION

Sample Number: 1503223-018 Customer Sample Number: 3117544 Project: LCR
Location: 2nd Draw 336 QUACKENBOS ST. NE Type: Dist.

Collection Date: 3/25/2015 Collection Time: 5:46 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:32:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.252 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.008 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: *Robert P. Hoffa* 4/6/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503223-019


SAMPLE INFORMATION

Sample Number: 1503223-019 Customer Sample Number: 3007249 Project: LCR
Location: 1st Draw 2719 O ST NW Type: Dist.

Collection Date: 3/24/2015 Collection Time: 5:35 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:32:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.022 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0026 mg/L	4/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  4/6/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503223-020


SAMPLE INFORMATION

Sample Number: 1503223-020 Customer Sample Number: 3007249 Project: LCR
Location: 2nd Draw 2719 O ST NW Type: Dist.

Collection Date: 3/24/2015 Collection Time: 5:40 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:32:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.015 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.008 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0028 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  4/6/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503223-021


SAMPLE INFORMATION

Sample Number: 1503223-021 Customer Sample Number: 3020687 Project: LCR
Location: 1st Draw 3917 8TH ST NW Type: Dist.

Collection Date: 3/25/2015 Collection Time: 7:08 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:32:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.044 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.069 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0008 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  4/6/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503223-022


SAMPLE INFORMATION

Sample Number: 1503223-022 Customer Sample Number: 3020687 Project: LCR
Location: 2nd Draw 3917 8TH ST NW Type: Dist.

Collection Date: 3/25/2015 Collection Time: 7:09 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:32:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.035 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.044 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0003 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  4/6/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503223-023

SAMPLE INFORMATION


Sample Number: 1503223-023 Customer Sample Number: 3041503 Project: LCR
Location: 1st Draw 3621 VAN NESS ST NW Type: Dist.

Collection Date: 3/25/2015 Collection Time: 5:45 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:32:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.070 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.106 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0008 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503223-024

SAMPLE INFORMATION

Sample Number: 1503223-024 Customer Sample Number: 3041503 Project: LCR
Location: 2nd Draw 3621 VAN NESS ST NW Type: Dist.


Collection Date: 3/25/2015 Collection Time: 5:46 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:32:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.099 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.010 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0016 mg/L	4/3/2015	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Ü[à^!óÜP[~af!Bç * Åca[|æ[i' Å ç æ^!

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503223-025

SAMPLE INFORMATION


Sample Number: 1503223-025 Customer Sample Number: 3027830 Project: LCR
Location: 1st Draw 4525 15TH ST NW Type: Dist.

Collection Date: 3/23/2015 Collection Time: 19:45 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:32:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.067 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.027 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0038 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Ü[à^!óÜP[~af!Bá * Áca[|af |^ Á a] a^!]

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503223-026

SAMPLE INFORMATION


Sample Number: 1503223-026 Customer Sample Number: 3027830 Project: LCR
Location: 2nd Draw 4525 15TH ST NW Type: Dist.

Collection Date: 3/23/2015 Collection Time: 19:45 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:32:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.051 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.018 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0025 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Ü[à^!óÜË[~-afBç * Åca[|æ[i' Å ç Æ^!

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503223-027

SAMPLE INFORMATION


Sample Number: 1503223-027 Customer Sample Number: 3036642 Project: LCR
Location: 1st Draw 3625 ALBEMARLE ST NW Type: Dist.

Collection Date: 3/25/2015 Collection Time: 7:03 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:32:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.022 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.032 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0012 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Ü[à^!óÜP[~af!Bç * Åca[|æ[i' Å ç æ^!

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503223-028

SAMPLE INFORMATION


Sample Number: 1503223-028 Customer Sample Number: 3036642 Project: LCR
Location: 2nd Draw 3625 ALBEMARLE ST NW Type: Dist.

Collection Date: 3/25/2015 Collection Time: 7:07 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:32:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.031 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.003 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0003 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Ü[à^!óÜË[~-afBç * Åca[|æ[i^ Á ç æ^!

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503223-029

SAMPLE INFORMATION


Sample Number: 1503223-029 Customer Sample Number: 3040894 Project: LCR
Location: 1st Draw 3724 CHESAPEAKE ST NW Type: Dist.

Collection Date: 3/24/2015 Collection Time: 7:05 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:32:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.026 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.073 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503223-030

SAMPLE INFORMATION


Sample Number: 1503223-030 Customer Sample Number: 3040894 Project: LCR
Location: 2nd Draw 3724 CHESAPEAKE ST NW Type: Dist.

Collection Date: 3/24/2015 Collection Time: 7:08 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:32:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.031 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.036 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	4/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Ü[à^!óÜP[~af!Bç * Åca[|æ[!^ Å ç æ^!

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503223-031

SAMPLE INFORMATION


Sample Number: 1503223-031 Customer Sample Number: 3041124 Project: LCR
Location: 1st Draw 4215 39TH ST NW Type: Dist.

Collection Date: 3/24/2015 Collection Time: 15:30 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:32:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.049 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0007 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503223-032

SAMPLE INFORMATION

Sample Number: 1503223-032 Customer Sample Number: 3041124 Project: LCR
Location: 2nd Draw 4215 39TH ST NW Type: Dist.

Collection Date: 3/24/2015 Collection Time: 15:31 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:32:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.011 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.013 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0008 mg/L	4/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: Robert P. Hoffa 4/6/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503223-033


SAMPLE INFORMATION

Sample Number: 1503223-033 Customer Sample Number: 3020804 Project: LCR
Location: 1st Draw 3916 5TH ST NW Type: Dist.

Collection Date: 3/25/2015 Collection Time: 7:11 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:32:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.019 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.003 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0003 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  4/6/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503223-034


SAMPLE INFORMATION

Sample Number: 1503223-034 Customer Sample Number: 3020804 Project: LCR
Location: 2nd Draw 3916 5TH ST NW Type: Dist.

Collection Date: 3/25/2015 Collection Time: 7:13 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:32:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.019 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.003 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0008 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  4/6/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503223-035

SAMPLE INFORMATION

Sample Number: 1503223-035 Customer Sample Number: 3039291 Project: LCR
Location: 1st Draw 3722 MCKINLEY ST NW Type: Dist.

Collection Date: 3/25/2015 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:32:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.135 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0004 mg/L	4/3/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Ü[à^!óÜP[~-afBç * Åca[|æ[i^ Å ç æ^!

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1504002-001


SAMPLE INFORMATION

Sample Number: 1504002-001 Customer Sample Number: 3103403 Project: LCR
Location: 1st draw 3416 9TH ST NE Type: Dist.

Collection Date: 3/24/2015 Collection Time: 6:50 Sampler: HOME OWNER Received Date and Time: 4/1/2015 9:52:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.028 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.003 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  4/6/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1504002-002

SAMPLE INFORMATION


Sample Number: 1504002-002 Customer Sample Number: 3103403 Project: LCR
Location: 2nd draw 3416 9TH ST NE Type: Dist.

Collection Date: 3/24/2015 Collection Time: 6:51 Sampler: HOME OWNER Received Date and Time: 4/1/2015 9:52:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.032 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.003 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1504002-003

SAMPLE INFORMATION


Sample Number: 1504002-003 Customer Sample Number: 3052487 Project: LCR
Location: 1st draw 450 NEWTON PL NW Type: Dist.

Collection Date: 3/30/2015 Collection Time: 6:26 Sampler: HOME OWNER Received Date and Time: 4/1/2015 9:52:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.051 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.027 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0016 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1504002-004


SAMPLE INFORMATION

Sample Number: 1504002-004 Customer Sample Number: 3052487 Project: LCR
Location: 2nd draw 450 NEWTON PL NW Type: Dist.

Collection Date: 3/30/2015 Collection Time: 6:28 Sampler: HOME OWNER Received Date and Time: 4/1/2015 9:52:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.080 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.028 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0025 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  4/6/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1504002-005


SAMPLE INFORMATION

Sample Number: 1504002-005 Customer Sample Number: 3127684 Project: LCR
Location: 1st draw 414 G ST NE Type: Dist.

Collection Date: 3/26/2015 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 4/1/2015 9:52:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.441 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.013 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  4/6/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1504002-006


SAMPLE INFORMATION

Sample Number: 1504002-006 Customer Sample Number: 3127684 Project: LCR
Location: 2nd draw 414 G ST NE Type: Dist.

Collection Date: 3/26/2015 Collection Time: 7:02 Sampler: HOME OWNER Received Date and Time: 4/1/2015 9:52:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.419 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.009 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  4/6/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1504002-007


SAMPLE INFORMATION

Sample Number: 1504002-007 Customer Sample Number: 3029605 Project: LCR
Location: 1st draw 3636 13TH ST NW Type: Dist.

Collection Date: 3/25/2015 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 4/1/2015 9:52:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.019 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.026 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0008 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  4/6/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1504002-008

SAMPLE INFORMATION


Sample Number: 1504002-008 Customer Sample Number: 3029605 Project: LCR
Location: 2nd draw 3636 13TH ST NW Type: Dist.

Collection Date: 3/25/2015 Collection Time: 7:16 Sampler: HOME OWNER Received Date and Time: 4/1/2015 9:52:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.019 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.008 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0036 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1504002-009


SAMPLE INFORMATION

Sample Number: 1504002-009 Customer Sample Number: 3040552 Project: LCR
Location: 1st draw 3710 HUNTINGTON ST NW Type: Dist.

Collection Date: 3/25/2015 Collection Time: 6:34 Sampler: HOME OWNER Received Date and Time: 4/1/2015 9:52:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.010 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.014 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0006 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  4/6/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1504002-010

SAMPLE INFORMATION


Sample Number: 1504002-010 Customer Sample Number: 3040552 Project: LCR
Location: 2nd draw 3710 HUNTINGTON ST NW Type: Dist.

Collection Date: 3/25/2015 Collection Time: 6:39 Sampler: HOME OWNER Received Date and Time: 4/1/2015 9:52:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.012 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.008 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0012 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Ü[à^!óÜË[~-afBç * Åca[|æ[i' Å ç æ^!

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1504002-011

SAMPLE INFORMATION


Sample Number: 1504002-011 Customer Sample Number: 3108722 Project: LCR
Location: 1st draw 4120 GRANT ST NE Type: Dist.

Collection Date: 3/25/2015 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 4/1/2015 9:52:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.043 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.013 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Ü[à^!óÜP[~-afBç * Åca[|æ[i' Å ç æ^!

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1504002-012


SAMPLE INFORMATION

Sample Number: 1504002-012 Customer Sample Number: 3108722 Project: LCR
Location: 2nd draw 4120 GRANT ST NE Type: Dist.

Collection Date: 3/25/2015 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 4/1/2015 9:52:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.067 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.010 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0004 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  4/6/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1504002-013


SAMPLE INFORMATION

Sample Number: 1504002-013 Customer Sample Number: 3108727 Project: LCR
Location: 1st draw 4054 GRANT ST NE Type: Dist.

Collection Date: 3/25/2015 Collection Time: 10:00 Sampler: HOME OWNER Received Date and Time: 4/1/2015 9:52:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.054 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.061 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0006 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  4/6/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1504002-014


SAMPLE INFORMATION

Sample Number: 1504002-014 Customer Sample Number: 3108727 Project: LCR
Location: 2nd draw 4054 GRANT ST NE Type: Dist.

Collection Date: 3/25/2015 Collection Time: 10:10 Sampler: HOME OWNER Received Date and Time: 4/1/2015 9:52:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.171 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.050 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0016 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  4/6/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1504002-015


SAMPLE INFORMATION

Sample Number: 1504002-015 Customer Sample Number: 3042399 Project: LCR
Location: 1st draw 4131 YUMA ST NW Type: Dist.

Collection Date: 3/25/2015 Collection Time: 5:45 Sampler: HOME OWNER Received Date and Time: 4/1/2015 9:52:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.018 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0014 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  4/6/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1504002-016


SAMPLE INFORMATION

Sample Number: 1504002-016 Customer Sample Number: 3042399 Project: LCR
Location: 2nd draw 4131 YUMA ST NW Type: Dist.

Collection Date: 3/25/2015 Collection Time: 5:50 Sampler: HOME OWNER Received Date and Time: 4/1/2015 9:52:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.005 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0048 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  4/6/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1504002-017


SAMPLE INFORMATION

Sample Number: 1504002-017 Customer Sample Number: 3044259 Project: LCR
Location: 1st draw 4447 HAWTHORNE ST NW Type: Dist.

Collection Date: 3/25/2015 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 4/1/2015 9:52:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.068 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.042 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0003 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  4/6/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1504002-018

SAMPLE INFORMATION

Sample Number: 1504002-018 Customer Sample Number: 3044259 Project: LCR
Location: 2nd draw 4447 HAWTHORNE ST NW Type: Dist.


Collection Date: 3/25/2015 Collection Time: 6:05 Sampler: HOME OWNER Received Date and Time: 4/1/2015 9:52:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.100 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.039 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0002 mg/L	4/3/2015	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Ü[à^!óÜP[~-afBç * Åca[|æ[i^ Å ç æ^!

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1504002-019


SAMPLE INFORMATION

Sample Number: 1504002-019 Customer Sample Number: 3104746 Project: LCR
Location: 1st draw 4418 14TH ST. NE Type: Dist.

Collection Date: 3/24/2015 Collection Time: 6:15 Sampler: HOME OWNER Received Date and Time: 4/1/2015 9:52:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.018 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.039 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0010 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  4/6/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1504002-020


SAMPLE INFORMATION

Sample Number: 1504002-020 Customer Sample Number: 3104746 Project: LCR
Location: 2nd draw 4418 14TH ST. NE Type: Dist.

Collection Date: 3/24/2015 Collection Time: 6:17 Sampler: HOME OWNER Received Date and Time: 4/1/2015 9:52:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.054 mg/L	4/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.010 mg/L	4/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0018 mg/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  4/6/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: LC-W1504025-001

SAMPLE INFORMATION

Sample Number: 1504025-001 Customer Sample Number: 3028753 Project: LCR
Location: 1st Draw 3908 13TH ST NW Type: Dist.

Collection Date: 3/26/2015 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 4/3/2015 10:45:29 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.044 mg/L	4/6/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.054 mg/L	4/6/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0013 mg/L	4/6/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: LC-W1504025-002


SAMPLE INFORMATION

Sample Number: 1504025-002 Customer Sample Number: 3028753 Project: LCR
Location: 2nd Draw 3908 13TH ST NW Type: Dist.

Collection Date: 3/26/2015 Collection Time: 7:18 Sampler: HOME OWNER Received Date and Time: 4/3/2015 10:45:29 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.070 mg/L	4/6/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.031 mg/L	4/6/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0007 mg/L	4/6/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Robert P. Hoffa, Acting Laboratory Manager

4/24/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/14/2015
Report Number: LC-W1504180-001


SAMPLE INFORMATION

Sample Number: 1504180-001 Customer Sample Number: 3058406 Project: LCR
Location: 1st Draw 4550 30TH ST NW Type: Dist.

Collection Date: 4/20/2015 Collection Time: 5:40 Sampler: HOME OWNER Received Date and Time: 4/24/2015 9:02:17 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	5/5/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.029 mg/L	5/5/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0017 mg/L	5/5/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Robert P. Hoffa, Laboratory Manager

5/14/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/14/2015
Report Number: LC-W1504180-002

SAMPLE INFORMATION

Sample Number: 1504180-002 Customer Sample Number: 3058406 Project: LCR
Location: 2nd Draw 4550 30TH ST NW Type: Dist.

Collection Date: 4/20/2015 Collection Time: 5:43 Sampler: HOME OWNER Received Date and Time: 4/24/2015 9:02:17 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	5/5/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.005 mg/L	5/5/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0023 mg/L	5/5/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/14/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-001

SAMPLE INFORMATION

Sample Number: 1505035-001 Customer Sample Number: 3039963 Project: LCR
Location: 1st draw 5404 39TH ST NW Type: Dist.

Collection Date: 4/29/2015 Collection Time: 6:21 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.023 mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.020 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0012 mg/L	5/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-002

SAMPLE INFORMATION

Sample Number: 1505035-002 Customer Sample Number: 3039963 Project: LCR
Location: 2nd draw 5404 39TH ST NW Type: Dist.

Collection Date: 4/29/2015 Collection Time: 6:22 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.063 mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.019 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0008 mg/L	5/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-003

SAMPLE INFORMATION

Sample Number: 1505035-003 Customer Sample Number: 3039888 Project: LCR
Location: 1st draw 5301 RENO RD NW Type: Dist.

Collection Date: 4/28/2015 Collection Time: 6:06 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.029 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0007 mg/L	5/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-004


SAMPLE INFORMATION

Sample Number: 1505035-004 Customer Sample Number: 3039888 Project: LCR
Location: 2nd draw 5301 RENO RD NW Type: Dist.

Collection Date: 4/28/2015 Collection Time: 6:12 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.010 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0006 mg/L	5/12/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Robert P. Hoffa, Laboratory Manager

5/22/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-005

SAMPLE INFORMATION

Sample Number: 1505035-005 Customer Sample Number: 3073506 Project: LCR
Location: 1st draw 744 9TH ST SE Type: Dist.

Collection Date: 4/29/2015 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.024 mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.017 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0003 mg/L	5/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-006

SAMPLE INFORMATION

Sample Number: 1505035-006 Customer Sample Number: 3073506 Project: LCR
Location: 2nd draw 744 9TH ST SE Type: Dist.


Collection Date: 4/29/2015 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.034 mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.005 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	5/12/2015	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-007

SAMPLE INFORMATION

Sample Number: 1505035-007 Customer Sample Number: 3051524 Project: LCR
Location: 1st draw 5312 ILLINOIS AVE NW Type: Dist.


Collection Date: 4/28/2015 Collection Time: 6:38 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.147 mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.005 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0003 mg/L	5/12/2015	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-008


SAMPLE INFORMATION

Sample Number: 1505035-008 Customer Sample Number: 3051524 Project: LCR
Location: 2nd draw 5312 ILLINOIS AVE NW Type: Dist.

Collection Date: 4/28/2015 Collection Time: 6:40 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.030 mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.003 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	5/12/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Robert P. Hoffa, Laboratory Manager

5/22/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-009

SAMPLE INFORMATION

Sample Number: 1505035-009 Customer Sample Number: 3041213 Project: LCR
Location: 1st draw 3809 ALTON PL NW Type: Dist.

Collection Date: 4/29/2015 Collection Time: 6:36 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.018 mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.023 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0007 mg/L	5/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-010

SAMPLE INFORMATION

Sample Number: 1505035-010 Customer Sample Number: 3041213 Project: LCR
Location: 2nd draw 3809 ALTON PL NW Type: Dist.

Collection Date: 4/29/2015 Collection Time: 6:37 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.020 mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.014 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0008 mg/L	5/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-011

SAMPLE INFORMATION

Sample Number: 1505035-011 Customer Sample Number: 3024835 Project: LCR
Location: 1st draw 5731 3RD PL NW Type: Dist.

Collection Date: 4/30/2015 Collection Time: 7:14 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.312 mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.004 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0036 mg/L	5/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-012

SAMPLE INFORMATION

Sample Number: 1505035-012 Customer Sample Number: 3024835 Project: LCR
Location: 2nd draw 5731 3RD PL NW Type: Dist.

Collection Date: 4/30/2015 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.112 mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.003 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0025 mg/L	5/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-013

SAMPLE INFORMATION

Sample Number: 1505035-013 Customer Sample Number: 3027236 Project: LCR
Location: 1st draw 6516 8TH ST NW Type: Dist.


Collection Date: 4/28/2015 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.019 mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.080 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0013 mg/L	5/12/2015	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-014

SAMPLE INFORMATION

Sample Number: 1505035-014 Customer Sample Number: 3027236 Project: LCR
Location: 2nd draw 6516 8TH ST NW Type: Dist.


Collection Date: 4/28/2015 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.010 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0013 mg/L	5/12/2015	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-015

SAMPLE INFORMATION

Sample Number: 1505035-015 Customer Sample Number: 3043835 Project: LCR
Location: 1st draw 4627 49TH ST NW Type: Dist.

Collection Date: 4/29/2015 Collection Time: 6:10 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.059 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0003 mg/L	5/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-016

SAMPLE INFORMATION

Sample Number: 1505035-016 Customer Sample Number: 3043835 Project: LCR
Location: 2nd draw 4627 49TH ST NW Type: Dist.

Collection Date: 4/29/2015 Collection Time: 6:10 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.047 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0002 mg/L	5/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-017

SAMPLE INFORMATION

Sample Number: 1505035-017 Customer Sample Number: 3051579 Project: LCR
Location: 1st draw 5234 ILLINOIS AVE NW Type: Dist.

Collection Date: 4/28/2015 Collection Time: 22:16 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.015 mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.019 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0024 mg/L	5/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-018

SAMPLE INFORMATION

Sample Number: 1505035-018 Customer Sample Number: 3051579 Project: LCR
Location: 2nd draw 5234 ILLINOIS AVE NW Type: Dist.

Collection Date: 4/28/2015 Collection Time: 22:18 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.015 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0017 mg/L	5/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-019


SAMPLE INFORMATION

Sample Number: 1505035-019 Customer Sample Number: 3038949 Project: LCR
Location: 1st draw 6001 33RD ST NW Type: Dist.

Collection Date: 4/29/2015 Collection Time: 6:52 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.022 mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.037 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0003 mg/L	5/12/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Robert P. Hoffa, Laboratory Manager

5/22/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-020

SAMPLE INFORMATION

Sample Number: 1505035-020 Customer Sample Number: 3038949 Project: LCR
Location: 2nd draw 6001 33RD ST NW Type: Dist.


Collection Date: 4/29/2015 Collection Time: 6:53 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.021 mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.004 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0020 mg/L	5/12/2015	RHoffa

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-021

SAMPLE INFORMATION

Sample Number: 1505035-021 Customer Sample Number: 3026885 Project: LCR
Location: 1st draw 6308 8TH ST NW Type: Dist.

Collection Date: 4/28/2015 Collection Time: 17:55 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.018 mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.066 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0009 mg/L	5/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-022

SAMPLE INFORMATION

Sample Number: 1505035-022 Customer Sample Number: 3026885 Project: LCR
Location: 2nd draw 6308 8TH ST NW Type: Dist.

Collection Date: 4/28/2015 Collection Time: 17:57 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.020 mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.081 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0007 mg/L	5/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-023


SAMPLE INFORMATION

Sample Number: 1505035-023 Customer Sample Number: 3022277 Project: LCR
Location: 1st draw 804 DELAFIELD PL. NW Type: Dist.

Collection Date: 4/29/2015 Collection Time: 5:14 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.015 mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.009 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0009 mg/L	5/12/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Robert P. Hoffa, Laboratory Manager

5/22/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-024

SAMPLE INFORMATION

Sample Number: 1505035-024 Customer Sample Number: 3022277 Project: LCR
Location: 2nd draw 804 DELAFIELD PL. NW Type: Dist.

Collection Date: 4/29/2015 Collection Time: 5:16 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.017 mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.004 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0011 mg/L	5/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-025


SAMPLE INFORMATION

Sample Number: 1505035-025 Customer Sample Number: 3092217 Project: LCR
Location: 1st draw 8 N ST SW Type: Dist.

Collection Date: 4/27/2015 Collection Time: 19:36 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.138 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0015 mg/L	5/12/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Robert P. Hoffa, Laboratory Manager

5/22/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-026

SAMPLE INFORMATION

Sample Number: 1505035-026 Customer Sample Number: 3092217 Project: LCR
Location: 2nd draw 8 N ST SW Type: Dist.

Collection Date: 4/27/2015 Collection Time: 19:40 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.012 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0053 mg/L	5/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-027

SAMPLE INFORMATION

Sample Number: 1505035-027 Customer Sample Number: 3086628 Project: LCR
Location: 1st draw 502 A ST SE Type: Dist.

Collection Date: 4/29/2015 Collection Time: 5:55 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.045 mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.045 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0010 mg/L	5/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-028

SAMPLE INFORMATION

Sample Number: 1505035-028 Customer Sample Number: 3086628 Project: LCR
Location: 2nd draw 502 A ST SE Type: Dist.

Collection Date: 4/29/2015 Collection Time: 5:58 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.028 mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.045 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0006 mg/L	5/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-029


SAMPLE INFORMATION

Sample Number: 1505035-029 Customer Sample Number: 3038936 Project: LCR
Location: 1st draw 5923 33RD ST NW Type: Dist.

Collection Date: 4/29/2015 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.151 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0008 mg/L	5/12/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Robert P. Hoffa, Laboratory Manager

5/22/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-030

SAMPLE INFORMATION

Sample Number: 1505035-030 Customer Sample Number: 3038936 Project: LCR
Location: 2nd draw 5923 33RD ST NW Type: Dist.

Collection Date: 4/29/2015 Collection Time: 7:05 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.112 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0010 mg/L	5/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-031

SAMPLE INFORMATION


Sample Number: 1505035-031 Customer Sample Number: 3006873 Project: LCR
Location: 1st draw 53 P ST NW Type: Dist.

Collection Date: 4/29/2015 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.006 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	5/12/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-032

SAMPLE INFORMATION

Sample Number: 1505035-032 Customer Sample Number: 3006873 Project: LCR
Location: 2nd draw 53 P ST NW Type: Dist.

Collection Date: 4/29/2015 Collection Time: 7:01 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.005 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	5/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-033

SAMPLE INFORMATION

Sample Number: 1505035-033 Customer Sample Number: 3058437 Project: LCR
Location: 1st draw 4806 KANSAS AVE NW Type: Dist.

Collection Date: 4/29/2015 Collection Time: 7:12 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.131 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0003 mg/L	5/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-034

SAMPLE INFORMATION

Sample Number: 1505035-034 Customer Sample Number: 3058437 Project: LCR
Location: 2nd draw 4806 KANSAS AVE NW Type: Dist.

Collection Date: 4/29/2015 Collection Time: 7:14 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.096 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0004 mg/L	5/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-035

SAMPLE INFORMATION

Sample Number: 1505035-035 Customer Sample Number: 3072035 Project: LCR
Location: 1st draw 522 4TH ST SE Type: Dist.

Collection Date: 4/29/2015 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.066 mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.015 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0003 mg/L	5/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-036

SAMPLE INFORMATION

Sample Number: 1505035-036 Customer Sample Number: 3072035 Project: LCR
Location: 2nd draw 522 4TH ST SE Type: Dist.

Collection Date: 4/29/2015 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.116 mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.012 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	5/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-037

SAMPLE INFORMATION

Sample Number: 1505035-037 Customer Sample Number: 3022216 Project: LCR
Location: 1st draw 4719 9TH ST NW Type: Dist.

Collection Date: 4/28/2015 Collection Time: 13:00 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.014 mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.010 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0003 mg/L	5/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-038


SAMPLE INFORMATION

Sample Number: 1505035-038 Customer Sample Number: 3022216 Project: LCR
Location: 2nd draw 4719 9TH ST NW Type: Dist.

Collection Date: 4/28/2015 Collection Time: 13:01 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.015 mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.005 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	5/12/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Robert P. Hoffa, Laboratory Manager

5/22/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-039

SAMPLE INFORMATION

Sample Number: 1505035-039 Customer Sample Number: 3127230 Project: LCR
Location: 1st draw 617 6TH ST NE Type: Dist.

Collection Date: 4/29/2015 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.077 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0003 mg/L	5/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-040

SAMPLE INFORMATION

Sample Number: 1505035-040 Customer Sample Number: 3127230 Project: LCR
Location: 2nd draw 617 6TH ST NE Type: Dist.

Collection Date: 4/29/2015 Collection Time: 7:20 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.009 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	5/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-041

SAMPLE INFORMATION

Sample Number: 1505035-041 Customer Sample Number: 3099778 Project: LCR
Location: 1st draw 619 12TH ST NE Type: Dist.

Collection Date: 4/29/2015 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.011 mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.015 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0003 mg/L	5/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505035-042

SAMPLE INFORMATION

Sample Number: 1505035-042 Customer Sample Number: 3099778 Project: LCR
Location: 2nd draw 619 12TH ST NE Type: Dist.

Collection Date: 4/29/2015 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 5/6/2015 1:42:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.018 mg/L	5/12/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.012 mg/L	5/12/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	5/12/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: LC-W1505108-001

SAMPLE INFORMATION

Sample Number: 1505108-001 Customer Sample Number: 3058525 Project: LCR
Location: 1st draw 4811 ILLINOIS AVE NW Type: Dist.

Collection Date: 5/4/2015 Collection Time: 18:15 Sampler: HOME OWNER Received Date and Time: 5/15/2015 11:28:53 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.017 mg/L	6/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.103 mg/L	6/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0008 mg/L	6/3/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: LC-W1505108-002


SAMPLE INFORMATION

Sample Number: 1505108-002 Customer Sample Number: 3058525 Project: LCR
Location: 2nd draw 4811 ILLINOIS AVE NW Type: Dist.

Collection Date: 5/4/2015 Collection Time: 18:15 Sampler: HOME OWNER Received Date and Time: 5/15/2015 11:28:53 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.016 mg/L	6/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.030 mg/L	6/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0026 mg/L	6/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Robert P. Hoffa, Laboratory Manager

6/17/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: LC-W1505191-001


SAMPLE INFORMATION

Sample Number: 1505191-001 Customer Sample Number: 3122857 Project: LCR
Location: 1st draw 923 9TH ST., NE Type: Dist.

Collection Date: 5/26/2015 Collection Time: 20:34 Sampler: HOME OWNER Received Date and Time: 5/29/2015 11:22:43 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	6/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.084 mg/L	6/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0013 mg/L	6/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Robert P. Hoffa, Laboratory Manager

6/17/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: LC-W1505191-002


SAMPLE INFORMATION

Sample Number: 1505191-002 Customer Sample Number: 3122857 Project: LCR
Location: 2nd draw 923 9TH ST., NE Type: Dist.

Collection Date: 5/26/2015 Collection Time: 20:36 Sampler: HOME OWNER Received Date and Time: 5/29/2015 11:22:43 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	6/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.076 mg/L	6/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0013 mg/L	6/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Robert P. Hoffa, Laboratory Manager

6/17/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: LC-W1505191-003

SAMPLE INFORMATION

Sample Number: 1505191-003 Customer Sample Number: 3122831 Project: LCR
Location: 1st draw 905 KENT PL NE Type: Dist.

Collection Date: 5/27/2015 Collection Time: 16:48 Sampler: HOME OWNER Received Date and Time: 5/29/2015 11:22:43 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.054 mg/L	6/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.017 mg/L	6/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	6/3/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: LC-W1505191-004

SAMPLE INFORMATION

Sample Number: 1505191-004 Customer Sample Number: 3122831 Project: LCR
Location: 2nd draw 905 KENT PL NE Type: Dist.

Collection Date: 5/27/2015 Collection Time: 16:50 Sampler: HOME OWNER Received Date and Time: 5/29/2015 11:22:43 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.053 mg/L	6/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.009 mg/L	6/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	ND mg/L	6/3/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: LC-W1506008-001


SAMPLE INFORMATION

Sample Number: 1506008-001 Customer Sample Number: 3017981 Project: LCR
Location: 1st draw 87 S ST. NW Type: Dist.

Collection Date: 5/28/2015 Collection Time: 19:15 Sampler: HOME OWNER Received Date and Time: 6/1/2015 11:43:38 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	6/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.015 mg/L	6/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0015 mg/L	6/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Robert P. Hoffa, Laboratory Manager

6/17/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: LC-W1506008-002

SAMPLE INFORMATION


Sample Number: 1506008-002 Customer Sample Number: 3017981 Project: LCR
Location: 2nd draw 87 S ST. NW Type: Dist.

Collection Date: 5/28/2015 Collection Time: 19:15 Sampler: HOME OWNER Received Date and Time: 6/1/2015 11:43:38 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	6/3/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.017 mg/L	6/3/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0021 mg/L	6/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/22/2015
Report Number: LC-W1506054-001

SAMPLE INFORMATION

Sample Number: 1506054-001 Customer Sample Number: 3024404 Project: LCR
Location: 1st draw 816 MADISON ST NW Type: Dist.

Collection Date: 5/31/2015 Collection Time: 22:41 Sampler: HOME OWNER Received Date and Time: 6/8/2015 12:47:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.046 mg/L	6/9/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.018 mg/L	6/9/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0011 mg/L	6/9/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/22/2015
Report Number: LC-W1506054-002

SAMPLE INFORMATION

Sample Number: 1506054-002 Customer Sample Number: 3024404 Project: LCR
Location: 2nd draw 816 MADISON ST NW Type: Dist.

Collection Date: 5/31/2015 Collection Time: 22:42 Sampler: HOME OWNER Received Date and Time: 6/8/2015 12:47:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.218 mg/L	6/9/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.004 mg/L	6/9/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0042 mg/L	6/9/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/22/2015
Report Number: LC-W1506054-003

SAMPLE INFORMATION

Sample Number: 1506054-003 Customer Sample Number: 3022794 Project: LCR
Location: 1st draw 926 HAMILTON ST NW Type: Dist.

Collection Date: 5/28/2015 Collection Time: 5:50 Sampler: HOME OWNER Received Date and Time: 6/8/2015 12:47:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	0.074 mg/L	6/18/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.029 mg/L	6/9/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0011 mg/L	6/9/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/22/2015
Report Number: LC-W1506123-001

SAMPLE INFORMATION

Sample Number: 1506123-001 Customer Sample Number: 3021220 Project: LCR
Location: 1st Draw 314 VARNUM ST NW Type: Dist.

Collection Date: 6/10/2015 Collection Time: 20:00 Sampler: HOME OWNER Received Date and Time: 6/17/2015 9:29:57 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	6/18/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.029 mg/L	6/18/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0055 mg/L	6/18/2015	RHoffa

Comment:


ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/22/2015
Report Number: LC-W1506123-002


SAMPLE INFORMATION

Sample Number: 1506123-002 Customer Sample Number: 3021220 Project: LCR
Location: 2nd Draw 314 VARNUM ST NW Type: Dist.

Collection Date: 6/10/2015 Collection Time: 20:05 Sampler: HOME OWNER Received Date and Time: 6/17/2015 9:29:57 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	ug/L	0.01 mg/L	ND mg/L	6/18/2015	RHoffa
Copper	EPA 200.8	1.30 mg/L	ug/L	0.0002 mg/L	0.009 mg/L	6/18/2015	RHoffa
Lead	EPA 200.8	0.015 mg/L	ug/L	0.0002 mg/L	0.0079 mg/L	6/18/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Robert P. Hoffa, Laboratory Manager

6/22/2015
Date

Attachment 2

Other Addition Non-Regulated Monitoring Data

Customer Service Samples

DC Water operates a program where customers request a lead sampling kit on an annual basis. The kit comes with bottles and instructions on how to take first and second draw samples. Customers collect their own samples and contact DC Water to deliver the bottles to the Washington Aqueduct. Results are then reported back to the customer through DC Water's Customer Service Program.

This attached sample analysis data contains personal information of DC Water's customers, such as names and home addresses, the disclosure of which would constitute a violation of D.C. Code § 2-534(a)(2) and 5 U.S.C. § 552(b)(6). If EPA is requested to produce the sampling analysis data in whole or in part, in order to maintain confidentiality, the personal information must be redacted from the documents produced.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/15/2015
Report Number: LC-W1412089-001

SAMPLE INFORMATION

Sample Number: 1412089-001 Customer Sample Number: 3101467 Program: DS
Location: 1st draw 525 23RD PLACE NE Type: Dist.

Collection Date: 12/4/2014 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 12/10/2014 11:43:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.5 ug/L	12/17/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/15/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/15/2015
Report Number: LC-W1412089-002

SAMPLE INFORMATION

Sample Number: 1412089-002 Customer Sample Number: 3101467 Program: DS
Location: 2nd draw 525 23RD PLACE NE Type: Dist.

Collection Date: 12/4/2014 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 12/10/2014 11:43:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	12/17/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/15/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/15/2015
Report Number: LC-W1412089-003

SAMPLE INFORMATION

Sample Number: 1412089-003 Customer Sample Number: 3023739 Program: DS
Location: 1st draw 5325 5TH STREET NW Type: Dist.

Collection Date: 12/4/2014 Collection Time: 18:25 Sampler: HOME OWNER Received Date and Time: 12/10/2014 11:43:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	2.5 ug/L	12/17/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/15/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/15/2015
Report Number: LC-W1412089-004

SAMPLE INFORMATION

Sample Number: 1412089-004 Customer Sample Number: 3023739 Program: DS
Location: 2nd draw 5325 5TH STREET NW Type: Dist.

Collection Date: 12/4/2014 Collection Time: 18:25 Sampler: HOME OWNER Received Date and Time: 12/10/2014 11:43:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	12/17/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/15/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/15/2015
Report Number: LC-W1412089-005

SAMPLE INFORMATION

Sample Number: 1412089-005 Customer Sample Number: 3059573 Program: DS
Location: 1st draw 4817 RODMAN ST NW Type: Dist.
Collection Date: 12/7/2014 Collection Time: 6:56 Sampler: HOME OWNER Received Date and Time: 12/10/2014 11:43:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	12/17/2014	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/15/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/15/2015
Report Number: LC-W1412089-006

SAMPLE INFORMATION

Sample Number: 1412089-006 Customer Sample Number: 3059573 Program: DS
Location: 2nd draw 4817 RODMAN ST NW Type: Dist.

Collection Date: 12/7/2014 Collection Time: 6:59 Sampler: HOME OWNER Received Date and Time: 12/10/2014 11:43:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	12/17/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/15/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/15/2015
Report Number: LC-W1412089-011

SAMPLE INFORMATION

Sample Number: 1412089-011 Customer Sample Number: 3023080 Program: DS
Location: 1st draw 5101 7TH ST NW Type: Dist.

Collection Date: 12/8/2014 Collection Time: 13:55 Sampler: HOME OWNER Received Date and Time: 12/10/2014 11:43:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	12/17/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/15/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/15/2015
Report Number: LC-W1412089-012

SAMPLE INFORMATION

Sample Number: 1412089-012 Customer Sample Number: 3023080 Program: DS
Location: 2nd draw 5101 7TH ST NW Type: Dist.

Collection Date: 12/8/2014 Collection Time: 13:58 Sampler: HOME OWNER Received Date and Time: 12/10/2014 11:43:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	12/17/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/15/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/15/2015
Report Number: LC-W1412089-013

SAMPLE INFORMATION

Sample Number: 1412089-013 Customer Sample Number: 3021562 Program: DS
Location: 1st draw 637 ALLISON ST NW Type: Dist.

Collection Date: 12/8/2014 Collection Time: 14:50 Sampler: HOME OWNER Received Date and Time: 12/10/2014 11:43:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	12/17/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/15/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/15/2015
Report Number: LC-W1412089-014

SAMPLE INFORMATION

Sample Number: 1412089-014 Customer Sample Number: 3021562 Program: DS
Location: 2nd draw 637 ALLISON ST NW Type: Dist.

Collection Date: 12/8/2014 Collection Time: 14:52 Sampler: HOME OWNER Received Date and Time: 12/10/2014 11:43:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	12/17/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/15/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/15/2015
Report Number: LC-W1412113-001

SAMPLE INFORMATION

Sample Number: 1412113-001 Customer Sample Number: 3105970 Program: DS
Location: 1st draw 3812 18TH ST NE Type: Dist.

Collection Date: 12/7/2014 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 12/12/2014 2:31:24 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	12/17/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/15/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/15/2015
Report Number: LC-W1412113-002

SAMPLE INFORMATION

Sample Number: 1412113-002 Customer Sample Number: 3105970 Program: DS
Location: 2nd draw 3812 18TH ST NE Type: Dist.

Collection Date: 12/7/2014 Collection Time: 7:05 Sampler: HOME OWNER Received Date and Time: 12/12/2014 2:31:24 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	12/17/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/15/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/15/2015
Report Number: LC-W1412113-003

SAMPLE INFORMATION

Sample Number: 1412113-003 Customer Sample Number: 3073521 Program: DS
Location: 1st draw 735 10TH ST SE Type: Dist.

Collection Date: 12/9/2014 Collection Time: 8:30 Sampler: HOME OWNER Received Date and Time: 12/12/2014 2:31:24 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.4 ug/L	12/17/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/15/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/15/2015
Report Number: LC-W1412113-004

SAMPLE INFORMATION

Sample Number: 1412113-004 Customer Sample Number: 3073521 Program: DS
Location: 2nd draw 735 10TH ST SE Type: Dist.

Collection Date: 12/9/2014 Collection Time: 8:35 Sampler: HOME OWNER Received Date and Time: 12/12/2014 2:31:24 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.5 ug/L	12/17/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/15/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1412144-003

SAMPLE INFORMATION

Sample Number: 1412144-003 Customer Sample Number: 3022854 Program: DS
Location: 1st draw 5018 ILLINOIS AVE NW Type: Dist.

Collection Date: 12/8/2014 Collection Time: 18:35 Sampler: HOME OWNER Received Date and Time: 12/18/2014 8:45:05 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.4 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1412144-004

SAMPLE INFORMATION

Sample Number: 1412144-004 Customer Sample Number: 3022854 Program: DS
Location: 2nd draw 5018 ILLINOIS AVE NW Type: Dist.

Collection Date: 12/8/2014 Collection Time: 18:38 Sampler: HOME OWNER Received Date and Time: 12/18/2014 8:45:05 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	3.7 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1412144-005

SAMPLE INFORMATION

Sample Number: 1412144-005 Customer Sample Number: 3071629 Program: DS
Location: 1st draw 320 C ST SE Type: Dist.

Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 12/18/2014 8:45:05 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.5 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1412144-006

SAMPLE INFORMATION

Sample Number: 1412144-006 Customer Sample Number: 3071629 Program: DS
Location: 2nd draw 320 C ST SE Type: Dist.

Collection Date: 12/10/2014 Collection Time: 7:16 Sampler: HOME OWNER Received Date and Time: 12/18/2014 8:45:05 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.9 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1412144-009

SAMPLE INFORMATION

Sample Number: 1412144-009 Customer Sample Number: 3057195 Program: DS
Location: 1st draw 4127 4TH ST NW Type: Dist.

Collection Date: 12/11/2014 Collection Time: 6:50 Sampler: HOME OWNER Received Date and Time: 12/18/2014 8:45:05 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.6 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1412144-010

SAMPLE INFORMATION

Sample Number: 1412144-010 Customer Sample Number: 3057195 Program: DS
Location: 2nd draw 4127 4TH ST NW Type: Dist.

Collection Date: 12/11/2014 Collection Time: 6:52 Sampler: HOME OWNER Received Date and Time: 12/18/2014 8:45:05 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.6 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1412163-003

SAMPLE INFORMATION

Sample Number: 1412163-003 Customer Sample Number: 3080903 Program: DS
Location: 1st draw 2504 BRANCH AVE SE Type: Dist.

Collection Date: 12/15/2014 Collection Time: 5:32 Sampler: HOME OWNER Received Date and Time: 12/22/2014 12:03:45 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.1 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1412163-004

SAMPLE INFORMATION

Sample Number: 1412163-004 Customer Sample Number: 3080903 Program: DS
Location: 2nd draw 2504 BRANCH AVE SE Type: Dist.

Collection Date: 12/15/2014 Collection Time: 5:34 Sampler: HOME OWNER Received Date and Time: 12/22/2014 12:03:45 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1412163-005

SAMPLE INFORMATION

Sample Number: 1412163-005 Customer Sample Number: 3125490 Program: DS
Location: 1st draw 1936 SUMMIT PL NE Type: Dist.

Collection Date: 12/12/2014 Collection Time: 7:09 Sampler: HOME OWNER Received Date and Time: 12/22/2014 12:03:45 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	3.3 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1412163-006

SAMPLE INFORMATION

Sample Number: 1412163-006 Customer Sample Number: 3125490 Program: DS
Location: 2nd draw 1936 SUMMIT PL NE Type: Dist.

Collection Date: 12/12/2014 Collection Time: 7:11 Sampler: HOME OWNER Received Date and Time: 12/22/2014 12:03:45 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	20.6 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1412163-007

SAMPLE INFORMATION

Sample Number: 1412163-007 Customer Sample Number: 3074108 Program: DS
Location: 1st draw 326 12TH ST SE Type: Dist.

Collection Date: 12/17/2014 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 12/22/2014 12:03:45 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	4.1 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1412163-008

SAMPLE INFORMATION

Sample Number: 1412163-008 Customer Sample Number: 3074108 Program: DS
Location: 2nd draw 326 12TH ST SE Type: Dist.

Collection Date: 12/17/2014 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 12/22/2014 12:03:45 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	43.7 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1412163-009

SAMPLE INFORMATION

Sample Number: 1412163-009 Customer Sample Number: 3029271 Program: DS
Location: 1st draw 3915 13TH ST NW Type: Dist.

Collection Date: 12/15/2014 Collection Time: 5:15 Sampler: HOME OWNER Received Date and Time: 12/22/2014 12:03:45 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.0 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1412163-010

SAMPLE INFORMATION

Sample Number: 1412163-010 Customer Sample Number: 3029271 Program: DS
Location: 2nd draw 3915 13TH ST NW Type: Dist.

Collection Date: 12/15/2014 Collection Time: 5:16 Sampler: HOME OWNER Received Date and Time: 12/22/2014 12:03:45 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.6 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1412163-015

SAMPLE INFORMATION

Sample Number: 1412163-015 Customer Sample Number: 3053181 Program: DS
Location: 1st draw 4550 BROAD BRANCH RD NW Type: Dist.
Collection Date: 12/15/2014 Collection Time: 5:45 Sampler: HOME OWNER Received Date and Time: 12/22/2014 12:03:45 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	1/20/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1412163-016

SAMPLE INFORMATION

Sample Number: 1412163-016 Customer Sample Number: 3053181 Program: DS
Location: 2nd draw 4550 BROAD BRANCH RD NW Type: Dist.

Collection Date: 12/15/2014 Collection Time: 5:45 Sampler: HOME OWNER Received Date and Time: 12/22/2014 12:03:45 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1412186-001

SAMPLE INFORMATION

Sample Number: 1412186-001 Customer Sample Number: 3035286 Program: DS
Location: 1st draw 3015 WHITEHAVEN ST NW Type: Dist.

Collection Date: 12/16/2014 Collection Time: 5:58 Sampler: HOME OWNER Received Date and Time: 12/24/2014 3:31:15 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.4 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1412186-002

SAMPLE INFORMATION

Sample Number: 1412186-002 Customer Sample Number: 3035286 Program: DS
Location: 2nd draw 3015 WHITEHAVEN ST NW Type: Dist.

Collection Date: 12/16/2014 Collection Time: 6:02 Sampler: HOME OWNER Received Date and Time: 12/24/2014 3:31:15 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.1 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1412186-003

SAMPLE INFORMATION

Sample Number: 1412186-003 Customer Sample Number: 3019751 Program: DS
Location: 1st draw 614 LAMONT ST NW Type: Dist.

Collection Date: 12/18/2014 Collection Time: 18:00 Sampler: HOME OWNER Received Date and Time: 12/24/2014 3:31:15 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.9 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1412186-004

SAMPLE INFORMATION

Sample Number: 1412186-004 Customer Sample Number: 3019751 Program: DS
Location: 2nd draw 614 LAMONT ST NW Type: Dist.

Collection Date: 12/18/2014 Collection Time: 18:00 Sampler: HOME OWNER Received Date and Time: 12/24/2014 3:31:15 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.5 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1412186-005

SAMPLE INFORMATION

Sample Number: 1412186-005 Customer Sample Number: 3074463 Program: DS
Location: 1st draw 1304 C ST SE Type: Dist.

Collection Date: 12/22/2014 Collection Time: 0:00 Sampler: HOME OWNER Received Date and Time: 12/24/2014 3:31:15 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.9 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1412186-006

SAMPLE INFORMATION

Sample Number: 1412186-006 Customer Sample Number: 3074463 Program: DS
Location: 2nd draw 1304 C ST SE Type: Dist.

Collection Date: 12/22/2014 Collection Time: 0:01 Sampler: HOME OWNER Received Date and Time: 12/24/2014 3:31:15 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	2.8 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1412186-009

SAMPLE INFORMATION

Sample Number: 1412186-009 Customer Sample Number: 3121499 Program: DS
Location: 1st draw 220 TENNESSEE AVE NE Type: Dist.

Collection Date: 12/22/2014 Collection Time: 18:00 Sampler: HOME OWNER Received Date and Time: 12/24/2014 3:31:15 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.3 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1412186-010

SAMPLE INFORMATION

Sample Number: 1412186-010 Customer Sample Number: 3121499 Program: DS
Location: 2nd draw 220 TENNESSEE AVE NE Type: Dist.

Collection Date: 12/22/2014 Collection Time: 18:01 Sampler: HOME OWNER Received Date and Time: 12/24/2014 3:31:15 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.9 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1501005-003

SAMPLE INFORMATION

Sample Number: 1501005-003 Customer Sample Number: 3041265 Program: DS
Location: 1st Draw 4224 37TH ST., NW Type: Dist.

Collection Date: 12/28/2014 Collection Time: 8:15 Sampler: HOME OWNER Received Date and Time: 1/2/2015 11:49:42 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	5.2 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1501005-004

SAMPLE INFORMATION

Sample Number: 1501005-004 Customer Sample Number: 3041265 Program: DS
Location: 2nd Draw 4224 37TH ST., NW Type: Dist.

Collection Date: 12/28/2014 Collection Time: 8:16 Sampler: HOME OWNER Received Date and Time: 1/2/2015 11:49:42 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	2.7 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1501005-005

SAMPLE INFORMATION

Sample Number: 1501005-005 Customer Sample Number: 3128595 Program: DS
Location: 1st Draw 520 12TH ST. NE Type: Dist.

Collection Date: 12/29/2014 Collection Time: 11:00 Sampler: HOME OWNER Received Date and Time: 1/2/2015 11:49:42 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.2 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1501005-006

SAMPLE INFORMATION

Sample Number: 1501005-006 Customer Sample Number: 3128595 Program: DS
Location: 2nd Draw 520 12TH ST. NE Type: Dist.

Collection Date: 12/29/2014 Collection Time: 11:00 Sampler: HOME OWNER Received Date and Time: 1/2/2015 11:49:42 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1501026-001

SAMPLE INFORMATION

Sample Number: 1501026-001 Customer Sample Number: 3103560 Program: DS
Location: 1st Draw 1017 HAMLIN ST. NE Type: Dist.

Collection Date: 12/31/2014 Collection Time: 15:18 Sampler: HOME OWNER Received Date and Time: 1/6/2015 4:16:25 PM Received By: LNeal

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1501026-002

SAMPLE INFORMATION

Sample Number: 1501026-002 Customer Sample Number: 3103560 Program: DS
Location: 2nd Draw 1017 HAMLIN ST. NE Type: Dist.

Collection Date: 12/31/2014 Collection Time: 15:20 Sampler: HOME OWNER Received Date and Time: 1/6/2015 4:16:25 PM Received By: LNeal

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1501026-005

SAMPLE INFORMATION

Sample Number: 1501026-005 Customer Sample Number: 3024337 Program: DS
Location: 1st Draw 5706 4TH ST. NW Type: Dist.

Collection Date: 12/31/2014 Collection Time: 6:23 Sampler: HOME OWNER Received Date and Time: 1/6/2015 4:16:25 PM Received By: LNeal

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	5.6 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By: 
Michael Chicoine, Laboratory Manager

1/21/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1501026-006

SAMPLE INFORMATION

Sample Number: 1501026-006 Customer Sample Number: 3024337 Program: DS
Location: 2nd Draw 5706 4TH ST. NW Type: Dist.

Collection Date: 12/31/2014 Collection Time: 6:25 Sampler: HOME OWNER Received Date and Time: 1/6/2015 4:16:25 PM Received By: LNeal

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	3.1 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1501054-001

SAMPLE INFORMATION

Sample Number: 1501054-001 Customer Sample Number: 3009971 Program: DS
Location: 1s tdraw 2119 HUIDEKOPER PL NW Type: Dist.
Collection Date: 1/6/2015 Collection Time: 6:17 Sampler: HOME OWNER Received Date and Time: 1/9/2015 11:00:51 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.8 ug/L	1/20/2015	RHoffa

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1501054-002

SAMPLE INFORMATION

Sample Number: 1501054-002 Customer Sample Number: 3009971 Program: DS
Location: 2nd draw 2119 HUIDEKOPER PL NW Type: Dist.

Collection Date: 1/6/2015 Collection Time: 6:18 Sampler: HOME OWNER Received Date and Time: 1/9/2015 11:00:51 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.2 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1501054-005

SAMPLE INFORMATION

Sample Number: 1501054-005 Customer Sample Number: 3086759 Program: DS
Location: 1st draw 23 7TH STREET SE Type: Dist.

Collection Date: 1/3/2015 Collection Time: 8:44 Sampler: HOME OWNER Received Date and Time: 1/9/2015 11:00:51 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1501054-006

SAMPLE INFORMATION

Sample Number: 1501054-006 Customer Sample Number: 3086759 Program: DS
Location: 2nd draw 23 7TH STREET SE Type: Dist.

Collection Date: 1/3/2015 Collection Time: 8:47 Sampler: HOME OWNER Received Date and Time: 1/9/2015 11:00:51 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1501106-001

SAMPLE INFORMATION

Sample Number: 1501106-001 Customer Sample Number: 3073455 Program: DS
Location: 1st Draw 520 9TH ST SE Type: Dist.

Collection Date: 1/11/2015 Collection Time: 10:25 Sampler: HOME OWNER Received Date and Time: 1/16/2015 8:49:54 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1501106-002

SAMPLE INFORMATION

Sample Number: 1501106-002 Customer Sample Number: 3073455 Program: DS
Location: 2nd Draw 520 9TH ST SE Type: Dist.

Collection Date: 1/11/2015 Collection Time: 10:27 Sampler: HOME OWNER Received Date and Time: 1/16/2015 8:49:54 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1501106-003

SAMPLE INFORMATION

Sample Number: 1501106-003 Customer Sample Number: 3028674 Program: DS
Location: 1st Draw 1360 TAYLOR NW Type: Dist.

Collection Date: 1/12/2015 Collection Time: 6:15 Sampler: HOME OWNER Received Date and Time: 1/16/2015 8:49:54 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.4 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1501106-004

SAMPLE INFORMATION

Sample Number: 1501106-004 Customer Sample Number: 3028674 Program: DS
Location: 2nd Draw 1360 TAYLOR NW Type: Dist.

Collection Date: 1/12/2015 Collection Time: 6:16 Sampler: HOME OWNER Received Date and Time: 1/16/2015 8:49:54 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	2.8 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1501106-005

SAMPLE INFORMATION

Sample Number: 1501106-005 Customer Sample Number: 3061502 Program: DS
Location: 1st Draw 1812 24TH ST NW Type: Dist.

Collection Date: 1/14/2015 Collection Time: 6:21 Sampler: HOME OWNER Received Date and Time: 1/16/2015 8:49:54 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1501106-006

SAMPLE INFORMATION

Sample Number: 1501106-006 Customer Sample Number: 3061502 Program: DS
Location: 2nd Draw 1812 24TH ST NW Type: Dist.

Collection Date: 1/14/2015 Collection Time: 6:21 Sampler: HOME OWNER Received Date and Time: 1/16/2015 8:49:54 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: LC-W1501153-001


SAMPLE INFORMATION

Sample Number: 1501153-001 Customer Sample Number: 3147530 Program: DS
Location: 1st draw 4650 BROAD BRANCH RD. NW Type: Dist.
Collection Date: 1/15/2015 Collection Time: 15:17 Sampler: HOME OWNER Received Date and Time: 1/23/2015 11:17:47 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	9.7 ug/L	2/2/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa
Laboratory Manager

2/5/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: LC-W1501153-002

SAMPLE INFORMATION


Sample Number: 1501153-002 Customer Sample Number: 3147530 Program: DS
Location: 2nd draw 4650 BROAD BRANCH RD. NW Type: Dist.

Collection Date: 1/15/2015 Collection Time: 15:19 Sampler: HOME OWNER Received Date and Time: 1/23/2015 11:17:47 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	12.6 ug/L	2/2/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



2/5/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: LC-W1501153-003

SAMPLE INFORMATION


Sample Number: 1501153-003 Customer Sample Number: 3080628 Program: DS
Location: 1st draw 3645 BANGOR ST SE Type: Dist.

Collection Date: 1/16/2015 Collection Time: 6:32 Sampler: HOME OWNER Received Date and Time: 1/23/2015 11:17:47 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	2/2/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



2/5/2015

Ü[à^!oUEP[~-a!Bq * Sca[|a[i^ Á a[a^ ^!

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: LC-W1501153-004

SAMPLE INFORMATION


Sample Number: 1501153-004 Customer Sample Number: 3080628 Program: DS
Location: 2nd draw 3645 BANGOR ST SE Type: Dist.

Collection Date: 1/16/2015 Collection Time: 6:34 Sampler: HOME OWNER Received Date and Time: 1/23/2015 11:17:47 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	2/2/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



2/5/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: LC-W1501153-005

SAMPLE INFORMATION


Sample Number: 1501153-005 Customer Sample Number: 3043002 Program: DS
Location: 1st draw 4619 YUMA ST NW Type: Dist.

Collection Date: 1/19/2015 Collection Time: 6:10 Sampler: HOME OWNER Received Date and Time: 1/23/2015 11:17:47 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.9 ug/L	2/2/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



2/5/2015

Ü[à^!oUEP[~a^!Bç * Åca[|a[i^ Á a[a^!a

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: LC-W1501153-006

SAMPLE INFORMATION


Sample Number: 1501153-006 Customer Sample Number: 3043002 Program: DS
Location: 2nd draw 4619 YUMA ST NW Type: Dist.

Collection Date: 1/19/2015 Collection Time: 6:15 Sampler: HOME OWNER Received Date and Time: 1/23/2015 11:17:47 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.1 ug/L	2/2/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



2/5/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: LC-W1501153-007


SAMPLE INFORMATION

Sample Number: 1501153-007 Customer Sample Number: 3000546 Program: DS
Location: 1st draw 2143 NEWPORT PL NW APT C Type: Dist.
Collection Date: 1/20/2015 Collection Time: 7:36 Sampler: HOME OWNER Received Date and Time: 1/23/2015 11:17:47 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	2.1 ug/L	2/2/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



2/5/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: LC-W1501153-008

SAMPLE INFORMATION


Sample Number: 1501153-008 Customer Sample Number: 3000546 Program: DS
Location: 2nd draw 2143 NEWPORT PL NW APT C Type: Dist.

Collection Date: 1/20/2015 Collection Time: 7:38 Sampler: HOME OWNER Received Date and Time: 1/23/2015 11:17:47 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	2/2/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



2/5/2015

Ü[à^!oUEP[~a^Bç * Sca[|a[i^ Á a[a^ ^!

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: LC-W1501182-005

SAMPLE INFORMATION


Sample Number: 1501182-005 Customer Sample Number: 3046856 Program: DS
Location: 1st draw 7325 BLAIR RD NW Type: Dist.

Collection Date: 1/21/2015 Collection Time: 7:03 Sampler: HOME OWNER Received Date and Time: 1/27/2015 4:27:13 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.2 ug/L	2/2/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



2/5/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: LC-W1501182-006

SAMPLE INFORMATION


Sample Number: 1501182-006 Customer Sample Number: 3046856 Program: DS
Location: 2nd draw 7325 BLAIR RD NW Type: Dist.

Collection Date: 1/21/2015 Collection Time: 7:05 Sampler: HOME OWNER Received Date and Time: 1/27/2015 4:27:13 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	2/2/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



2/5/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: LC-W1501182-007


SAMPLE INFORMATION

Sample Number: 1501182-007 Customer Sample Number: 3047701 Program: DS
Location: 1st draw 1429 LOCUST RD NW Type: Dist.
Collection Date: 1/22/2015 Collection Time: 5:42 Sampler: HOME OWNER Received Date and Time: 1/27/2015 4:27:13 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.7 ug/L	2/2/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



2/5/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: LC-W1501182-008

SAMPLE INFORMATION


Sample Number: 1501182-008 Customer Sample Number: 3047701 Program: DS
Location: 2nd draw 1429 LOCUST RD NW Type: Dist.

Collection Date: 1/22/2015 Collection Time: 5:44 Sampler: HOME OWNER Received Date and Time: 1/27/2015 4:27:13 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	2/2/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



2/5/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: LC-W1501200-011


SAMPLE INFORMATION

Sample Number: 1501200-011 Customer Sample Number: 3021999 Program: DS
Location: 1st draw 4623 8TH ST., NW Type: Dist.
Collection Date: 1/26/2015 Collection Time: 17:30 Sampler: HOME OWNER Received Date and Time: 1/30/2015 8:30:25 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.5 ug/L	2/2/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



2/5/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: LC-W1501200-012

SAMPLE INFORMATION


Sample Number: 1501200-012 Customer Sample Number: 3021999 Program: DS
Location: 2nd draw 4623 8TH ST., NW Type: Dist.

Collection Date: 1/26/2015 Collection Time: 17:35 Sampler: HOME OWNER Received Date and Time: 1/30/2015 8:30:25 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.5 ug/L	2/2/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



2/5/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: LC-W1501200-015

SAMPLE INFORMATION


Sample Number: 1501200-015 Customer Sample Number: 3076020 Program: DS
Location: 1st draw 416 17TH ST., SE Type: Dist.

Collection Date: 1/23/2015 Collection Time: 16:40 Sampler: HOME OWNER Received Date and Time: 1/30/2015 8:30:25 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	2/2/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



2/5/2015

Ü[à^!oUEP[~-a!Bq * Sca[|a[i^ Á a[a^!

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: LC-W1501200-016

SAMPLE INFORMATION


Sample Number: 1501200-016 Customer Sample Number: 3076020 Program: DS
Location: 2nd draw 416 17TH ST., SE Type: Dist.

Collection Date: 1/23/2015 Collection Time: 16:40 Sampler: HOME OWNER Received Date and Time: 1/30/2015 8:30:25 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.5 ug/L	2/2/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



2/5/2015

Ü[à^!oUEP[~a^!Bç * Sca[|a[i^ Á a[a^!a

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: LC-W1501200-017

SAMPLE INFORMATION


Sample Number: 1501200-017 Customer Sample Number: 3086706 Program: DS
Location: 1st draw 413 1/2 6TH ST., SE Type: Dist.

Collection Date: 1/24/2015 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 1/30/2015 8:30:25 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	2/2/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



2/5/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: LC-W1501200-018

SAMPLE INFORMATION


Sample Number: 1501200-018 Customer Sample Number: 3086706 Program: DS
Location: 2nd draw 413 1/2 6TH ST., SE Type: Dist.

Collection Date: 1/24/2015 Collection Time: 8:02 Sampler: HOME OWNER Received Date and Time: 1/30/2015 8:30:25 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	2/2/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



2/5/2015

Ü[à^!oUEP[-a^!Bç * Åca[|a[i^ Á a[a[a^!

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1501200-021

SAMPLE INFORMATION


Sample Number: 1501200-021 Customer Sample Number: 3053678 Program: DS
Location: 1st draw 5215 WESTERN AVE., NW Type: Dist.

Collection Date: 1/24/2015 Collection Time: 18:30 Sampler: HOME OWNER Received Date and Time: 1/30/2015 8:30:25 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	2/4/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1501200-022

SAMPLE INFORMATION


Sample Number: 1501200-022 Customer Sample Number: 3053678 Program: DS
Location: 2nd draw 5215 WESTERN AVE., NW Type: Dist.

Collection Date: 1/24/2015 Collection Time: 18:35 Sampler: HOME OWNER Received Date and Time: 1/30/2015 8:30:25 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.5 ug/L	2/4/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502049-001

SAMPLE INFORMATION


Sample Number: 1502049-001 Customer Sample Number: 3054311 Program: DS
Location: 1st draw 1127 COLUMBIA RD NW Type: Dist.

Collection Date: 2/1/2015 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 2/6/2015 9:08:42 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	2/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502049-002

SAMPLE INFORMATION


Sample Number: 1502049-002 Customer Sample Number: 3054311 Program: DS
Location: 2nd draw 1127 COLUMBIA RD NW Type: Dist.

Collection Date: 2/1/2015 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 2/6/2015 9:08:42 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.2 ug/L	2/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502049-003

SAMPLE INFORMATION


Sample Number: 1502049-003 Customer Sample Number: 3071840 Program: DS
Location: 1st draw 504 INDEPENDENCE AVE SE Type: Dist.

Collection Date: 1/30/2015 Collection Time: 7:19 Sampler: HOME OWNER Received Date and Time: 2/6/2015 9:08:42 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	14.3 ug/L	2/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502049-004

SAMPLE INFORMATION


Sample Number: 1502049-004 Customer Sample Number: 3071840 Program: DS
Location: 2nd draw 504 INDEPENDENCE AVE SE Type: Dist.

Collection Date: 1/30/2015 Collection Time: 7:23 Sampler: HOME OWNER Received Date and Time: 2/6/2015 9:08:42 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	4.7 ug/L	2/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502049-005

SAMPLE INFORMATION


Sample Number: 1502049-005 Customer Sample Number: 3043842 Program: DS
Location: 1st draw 4709 ASBURY PL NW Type: Dist.

Collection Date: 2/1/2015 Collection Time: 6:34 Sampler: HOME OWNER Received Date and Time: 2/6/2015 9:08:42 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.3 ug/L	2/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502049-006

SAMPLE INFORMATION


Sample Number: 1502049-006 Customer Sample Number: 3043842 Program: DS
Location: 2nd draw 4709 ASBURY PL NW Type: Dist.

Collection Date: 2/1/2015 Collection Time: 6:36 Sampler: HOME OWNER Received Date and Time: 2/6/2015 9:08:42 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	2/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502049-009

SAMPLE INFORMATION


Sample Number: 1502049-009 Customer Sample Number: 3125492 Program: DS
Location: 1st draw 131 U ST NE Type: Dist.

Collection Date: 1/31/2015 Collection Time: 8:41 Sampler: HOME OWNER Received Date and Time: 2/6/2015 9:08:42 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	2/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502049-010

SAMPLE INFORMATION


Sample Number: 1502049-010 Customer Sample Number: 3125492 Program: DS
Location: 2nd draw 131 U ST NE Type: Dist.

Collection Date: 1/31/2015 Collection Time: 8:45 Sampler: HOME OWNER Received Date and Time: 2/6/2015 9:08:42 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	3.1 ug/L	2/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502049-011

SAMPLE INFORMATION


Sample Number: 1502049-011 Customer Sample Number: 3086882 Program: DS
Location: 1st draw 405 11TH ST SE Type: Dist.

Collection Date: 1/30/2015 Collection Time: 5:38 Sampler: HOME OWNER Received Date and Time: 2/6/2015 9:08:42 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.3 ug/L	2/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502049-012

SAMPLE INFORMATION


Sample Number: 1502049-012 Customer Sample Number: 3086882 Program: DS
Location: 2nd draw 405 11TH ST SE Type: Dist.

Collection Date: 1/30/2015 Collection Time: 5:39 Sampler: HOME OWNER Received Date and Time: 2/6/2015 9:08:42 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	2/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502049-013

SAMPLE INFORMATION


Sample Number: 1502049-013 Customer Sample Number: 3103967 Program: DS
Location: 1st draw 3805 12TH ST NE Type: Dist.

Collection Date: 1/30/2015 Collection Time: 6:20 Sampler: HOME OWNER Received Date and Time: 2/6/2015 9:08:42 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	2.5 ug/L	2/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502049-014

SAMPLE INFORMATION


Sample Number: 1502049-014 Customer Sample Number: 3103967 Program: DS
Location: 2nd draw 3805 12TH ST NE Type: Dist.

Collection Date: 1/30/2015 Collection Time: 6:20 Sampler: HOME OWNER Received Date and Time: 2/6/2015 9:08:42 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.5 ug/L	2/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502049-015

SAMPLE INFORMATION


Sample Number: 1502049-015 Customer Sample Number: 3076567 Program: DS
Location: 1st draw 5039 BENNING RD SE Type: Dist.

Collection Date: 2/2/2015 Collection Time: 4:00 Sampler: HOME OWNER Received Date and Time: 2/6/2015 9:08:42 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	2/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502049-016

SAMPLE INFORMATION


Sample Number: 1502049-016 Customer Sample Number: 3076567 Program: DS
Location: 2nd draw 5039 BENNING RD SE Type: Dist.

Collection Date: 2/2/2015 Collection Time: 4:00 Sampler: HOME OWNER Received Date and Time: 2/6/2015 9:08:42 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	2/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502049-019

SAMPLE INFORMATION


Sample Number: 1502049-019 Customer Sample Number: 3124234 Program: DS
Location: 1st draw 618 D ST NE Type: Dist.

Collection Date: 1/29/2015 Collection Time: 10:05 Sampler: HOME OWNER Received Date and Time: 2/6/2015 9:08:42 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	7.5 ug/L	2/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502049-020

SAMPLE INFORMATION


Sample Number: 1502049-020 Customer Sample Number: 3124234 Program: DS
Location: 2nd draw 618 D ST NE Type: Dist.

Collection Date: 1/29/2015 Collection Time: 10:10 Sampler: HOME OWNER Received Date and Time: 2/6/2015 9:08:42 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	3.0 ug/L	2/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502049-021

SAMPLE INFORMATION


Sample Number: 1502049-021 Customer Sample Number: 3024593 Program: DS
Location: 1st draw 500 NICHOLSON ST NW Type: Dist.

Collection Date: 2/2/2015 Collection Time: 17:25 Sampler: HOME OWNER Received Date and Time: 2/6/2015 9:08:42 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.0 ug/L	2/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502049-022

SAMPLE INFORMATION


Sample Number: 1502049-022 Customer Sample Number: 3024593 Program: DS
Location: 2nd draw 500 NICHOLSON ST NW Type: Dist.

Collection Date: 2/2/2015 Collection Time: 17:27 Sampler: HOME OWNER Received Date and Time: 2/6/2015 9:08:42 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	2/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502087-001

SAMPLE INFORMATION


Sample Number: 1502087-001 Customer Sample Number: 3049437 Program: DS
Location: 1st draw 1420 INGRAHAM ST NW Type: Dist.

Collection Date: 1/28/2015 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 2/11/2015 12:04:16 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.6 ug/L	2/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502087-002

SAMPLE INFORMATION


Sample Number: 1502087-002 Customer Sample Number: 3049437 Program: DS
Location: 2nd draw 1420 INGRAHAM ST NW Type: Dist.

Collection Date: 1/28/2015 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 2/11/2015 12:04:16 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.7 ug/L	2/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502087-003

SAMPLE INFORMATION


Sample Number: 1502087-003 Customer Sample Number: 3023764 Program: DS
Location: 1st draw 427 INGRAHAM ST NW Type: Dist.

Collection Date: 2/3/2015 Collection Time: 17:45 Sampler: HOME OWNER Received Date and Time: 2/11/2015 12:04:16 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.6 ug/L	2/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502087-004

SAMPLE INFORMATION


Sample Number: 1502087-004 Customer Sample Number: 3023764 Program: DS
Location: 2nd draw 427 INGRAHAM ST NW Type: Dist.

Collection Date: 2/3/2015 Collection Time: 17:48 Sampler: HOME OWNER Received Date and Time: 2/11/2015 12:04:16 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	2.2 ug/L	2/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502087-005


SAMPLE INFORMATION

Sample Number: 1502087-005 Customer Sample Number: 3029082 Program: DS
Location: 1st draw 4301 17TH ST NW Type: Dist.
Collection Date: 2/5/2015 Collection Time: 6:54 Sampler: HOME OWNER Received Date and Time: 2/11/2015 12:04:16 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.7 ug/L	2/12/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502087-006

SAMPLE INFORMATION


Sample Number: 1502087-006 Customer Sample Number: 3029082 Program: DS
Location: 2nd draw 4301 17TH ST NW Type: Dist.

Collection Date: 2/5/2015 Collection Time: 6:55 Sampler: HOME OWNER Received Date and Time: 2/11/2015 12:04:16 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	2/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502087-009

SAMPLE INFORMATION


Sample Number: 1502087-009 Customer Sample Number: 3010136 Program: DS
Location: 1st draw 2209 38TH ST NW Type: Dist.

Collection Date: 2/6/2015 Collection Time: 6:40 Sampler: HOME OWNER Received Date and Time: 2/11/2015 12:04:16 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.7 ug/L	2/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502087-010

SAMPLE INFORMATION


Sample Number: 1502087-010 Customer Sample Number: 3010136 Program: DS
Location: 2nd draw 2209 38TH ST NW Type: Dist.

Collection Date: 2/6/2015 Collection Time: 6:42 Sampler: HOME OWNER Received Date and Time: 2/11/2015 12:04:16 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.7 ug/L	2/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502087-011

SAMPLE INFORMATION


Sample Number: 1502087-011 Customer Sample Number: 3102711 Program: DS
Location: 1st draw 1132 PENN ST NE Type: Dist.

Collection Date: 2/7/2015 Collection Time: 10:40 Sampler: HOME OWNER Received Date and Time: 2/11/2015 12:04:16 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.5 ug/L	2/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502087-012

SAMPLE INFORMATION


Sample Number: 1502087-012 Customer Sample Number: 3102711 Program: DS
Location: 2nd draw 1132 PENN ST NE Type: Dist.

Collection Date: 2/7/2015 Collection Time: 10:45 Sampler: HOME OWNER Received Date and Time: 2/11/2015 12:04:16 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	2/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502087-013

SAMPLE INFORMATION


Sample Number: 1502087-013 Customer Sample Number: 3040026 Program: DS
Location: 1st draw 3939 LEGATION ST NW Type: Dist.

Collection Date: 2/7/2015 Collection Time: 8:52 Sampler: HOME OWNER Received Date and Time: 2/11/2015 12:04:16 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	2/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502087-014

SAMPLE INFORMATION


Sample Number: 1502087-014 Customer Sample Number: 3040026 Program: DS
Location: 2nd draw 3939 LEGATION ST NW Type: Dist.

Collection Date: 2/7/2015 Collection Time: 8:57 Sampler: HOME OWNER Received Date and Time: 2/11/2015 12:04:16 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	2/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1502137-005

SAMPLE INFORMATION


Sample Number: 1502137-005 Customer Sample Number: 3034907 Program: DS
Location: 1st draw 67 OBSERVATORY CIRCLE NW Type: Dist.

Collection Date: 2/10/2015 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 2/19/2015 11:02:46 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.8 ug/L	3/10/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1502137-006

SAMPLE INFORMATION


Sample Number: 1502137-006 Customer Sample Number: 3034907 Program: DS
Location: 2nd draw 67 OBSERVATORY CIRCLE NW Type: Dist.

Collection Date: 2/10/2015 Collection Time: 7:05 Sampler: HOME OWNER Received Date and Time: 2/19/2015 11:02:46 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	3/10/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1502137-007

SAMPLE INFORMATION


Sample Number: 1502137-007 Customer Sample Number: 3111851 Program: DS
Location: 1st draw 123 16TH ST NE Type: Dist.

Collection Date: 2/10/2015 Collection Time: 18:30 Sampler: HOME OWNER Received Date and Time: 2/19/2015 11:02:46 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.5 ug/L	3/10/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1502137-008

SAMPLE INFORMATION


Sample Number: 1502137-008 Customer Sample Number: 3111851 Program: DS
Location: 2nd draw 123 16TH ST NE Type: Dist.

Collection Date: 2/10/2015 Collection Time: 18:35 Sampler: HOME OWNER Received Date and Time: 2/19/2015 11:02:46 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	9.3 ug/L	3/10/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1502137-009

SAMPLE INFORMATION


Sample Number: 1502137-009 Customer Sample Number: 3048755 Program: DS
Location: 1st draw 6415 16TH ST NW Type: Dist.

Collection Date: 2/10/2015 Collection Time: 20:08 Sampler: HOME OWNER Received Date and Time: 2/19/2015 11:02:46 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.8 ug/L	3/10/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1502137-010


SAMPLE INFORMATION

Sample Number: 1502137-010 Customer Sample Number: 3048755 Program: DS
Location: 2nd draw 6415 16TH ST NW Type: Dist.
Collection Date: 2/10/2015 Collection Time: 20:11 Sampler: HOME OWNER Received Date and Time: 2/19/2015 11:02:46 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1502137-011

SAMPLE INFORMATION


Sample Number: 1502137-011 Customer Sample Number: 3122329 Program: DS
Location: 1st draw 222 15TH ST NE Type: Dist.

Collection Date: 2/10/2015 Collection Time: 20:06 Sampler: HOME OWNER Received Date and Time: 2/19/2015 11:02:46 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.7 ug/L	3/10/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1502137-012

SAMPLE INFORMATION


Sample Number: 1502137-012 Customer Sample Number: 3122329 Program: DS
Location: 2nd draw 222 15TH ST NE Type: Dist.

Collection Date: 2/10/2015 Collection Time: 20:14 Sampler: HOME OWNER Received Date and Time: 2/19/2015 11:02:46 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.2 ug/L	3/10/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1502137-013

SAMPLE INFORMATION


Sample Number: 1502137-013 Customer Sample Number: 3064199 Program: DS
Location: 1st draw 6411 16TH ST NW Type: Dist.

Collection Date: 2/11/2015 Collection Time: 10:00 Sampler: HOME OWNER Received Date and Time: 2/19/2015 11:02:46 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	3/10/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1502137-014

SAMPLE INFORMATION


Sample Number: 1502137-014 Customer Sample Number: 3064199 Program: DS
Location: 2nd draw 6411 16TH ST NW Type: Dist.

Collection Date: 2/11/2015 Collection Time: 10:09 Sampler: HOME OWNER Received Date and Time: 2/19/2015 11:02:46 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	3/10/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1502150-007

SAMPLE INFORMATION


Sample Number: 1502150-007 Customer Sample Number: 3100307 Program: DS
Location: 1st draw 1436 A ST NE Type: Dist.

Collection Date: 2/17/2015 Collection Time: 8:30 Sampler: HOME OWNER Received Date and Time: 2/20/2015 10:51:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.2 ug/L	3/10/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1502150-008

SAMPLE INFORMATION


Sample Number: 1502150-008 Customer Sample Number: 3100307 Program: DS
Location: 2nd draw 1436 A ST NE Type: Dist.

Collection Date: 2/17/2015 Collection Time: 8:35 Sampler: HOME OWNER Received Date and Time: 2/20/2015 10:51:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	3.1 ug/L	3/10/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 3/13/2015
Report Number: LC-W1502195-001

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502195-001 Customer Sample Number: 3034024 Program: DS
Location: 1st draw 1733 HARVARD ST NW Type: SP
Collection Date: 2/18/2015 Collection Time: 18:25 Sampler: HOME OWNER Received Date and Time: 2/27/2015 8:41:32 AM Received By: MMoore


Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 3/13/2015
Report Number: LC-W1502195-002

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


SAMPLE INFORMATION

Sample Number: 1502195-002 Customer Sample Number: 3034024 Program: DS
Location: 2nd draw 1733 HARVARD ST NW Type: SP
Collection Date: 2/18/2015 Collection Time: 18:27 Sampler: HOME OWNER Received Date and Time: 2/27/2015 8:41:32 AM Received By: MMoore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	3/10/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 3/13/2015
Report Number: LC-W1502195-005

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


SAMPLE INFORMATION

Sample Number: 1502195-005 Customer Sample Number: 3041706 Program: DS
Location: 1st draw 3722 35TH ST NW Type: SP
Collection Date: 2/25/2015 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 2/27/2015 8:41:32 AM Received By: MMoore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	2.1 ug/L	3/10/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 3/13/2015
Report Number: LC-W1502195-006

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION


Sample Number: 1502195-006 Customer Sample Number: 3041706 Program: DS
Location: 2nd draw 3722 35TH ST NW Type: SP

Collection Date: 2/25/2015 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 2/27/2015 8:41:32 AM Received By: MMoore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	6.0 ug/L	3/10/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503035-001


SAMPLE INFORMATION

Sample Number: 1503035-001 Customer Sample Number: 3049676 Program: DS
Location: 1st draw 1319 GALLATIN ST NW Type: Dist.
Collection Date: 3/3/2015 Collection Time: 6:45 Sampler: HOME OWNER Received Date and Time: 3/4/2015 3:42:55 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.0 ug/L	3/10/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1503035-002

SAMPLE INFORMATION


Sample Number: 1503035-002 Customer Sample Number: 3049676 Program: DS
Location: 2nd draw 1319 GALLATIN ST NW Type: Dist.

Collection Date: 3/3/2015 Collection Time: 6:48 Sampler: HOME OWNER Received Date and Time: 3/4/2015 3:42:55 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.9 ug/L	3/10/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503101-001

SAMPLE INFORMATION


Sample Number: 1503101-001 Customer Sample Number: 3021129 Program: DS
Location: 1st Draw 4117 3RD ST NW Type: Dist.

Collection Date: 2/28/2015 Collection Time: 6:05 Sampler: HOME OWNER Received Date and Time: 3/13/2015 3:55:15 PM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.0 ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503101-002

SAMPLE INFORMATION


Sample Number: 1503101-002 Customer Sample Number: 3021129 Program: DS
Location: 2nd Draw 4117 3RD ST NW Type: Dist.

Collection Date: 2/28/2015 Collection Time: 6:09 Sampler: HOME OWNER Received Date and Time: 3/13/2015 3:55:15 PM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503101-003

SAMPLE INFORMATION


Sample Number: 1503101-003 Customer Sample Number: 3075614 Program: DS
Location: 1st Draw 1013 15TH ST SE Type: Dist.

Collection Date: 3/3/2015 Collection Time: 6:45 Sampler: HOME OWNER Received Date and Time: 3/13/2015 3:55:15 PM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503101-004

SAMPLE INFORMATION


Sample Number: 1503101-004 Customer Sample Number: 3075614 Program: DS
Location: 2nd Draw 1013 15TH ST SE Type: Dist.

Collection Date: 3/3/2015 Collection Time: 6:45 Sampler: HOME OWNER Received Date and Time: 3/13/2015 3:55:15 PM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503131-003

SAMPLE INFORMATION


Sample Number: 1503131-003 Customer Sample Number: 3106504 Program: DS
Location: 1st draw 4110 22ND STREET NE Type: Dist.

Collection Date: 3/11/2015 Collection Time: 8:18 Sampler: HOME OWNER Received Date and Time: 3/18/2015 10:39:11 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503131-004

SAMPLE INFORMATION


Sample Number: 1503131-004 Customer Sample Number: 3106504 Program: DS
Location: 2nd draw 4110 22ND STREET NE Type: Dist.

Collection Date: 3/11/2015 Collection Time: 8:19 Sampler: HOME OWNER Received Date and Time: 3/18/2015 10:39:11 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503131-011

SAMPLE INFORMATION


Sample Number: 1503131-011 Customer Sample Number: 3028310 Program: DS
Location: 1st draw 4110 ARKANSAS AVE NW Type: Dist.

Collection Date: 3/12/2015 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 3/18/2015 10:39:11 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503131-012

SAMPLE INFORMATION


Sample Number: 1503131-012 Customer Sample Number: 3028310 Program: DS
Location: 2nd draw 4110 ARKANSAS AVE NW Type: Dist.

Collection Date: 3/12/2015 Collection Time: 8:01 Sampler: HOME OWNER Received Date and Time: 3/18/2015 10:39:11 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503155-003

SAMPLE INFORMATION


Sample Number: 1503155-003 Customer Sample Number: 3052131 Program: DS
Location: 1st draw 2220 N. CAPITOL ST NW #2 Type: Dist.

Collection Date: 3/17/2015 Collection Time: 5:30 Sampler: HOME OWNER Received Date and Time: 3/20/2015 9:48:28 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.6 ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503155-004

SAMPLE INFORMATION


Sample Number: 1503155-004 Customer Sample Number: 3052131 Program: DS
Location: 2nd draw 2220 N. CAPITOL ST NW #2 Type: Dist.

Collection Date: 3/17/2015 Collection Time: 5:35 Sampler: HOME OWNER Received Date and Time: 3/20/2015 9:48:28 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.0 ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503155-005

SAMPLE INFORMATION


Sample Number: 1503155-005 Customer Sample Number: 3099044 Program: DS
Location: 1st draw 1020 G STREET NE Type: Dist.

Collection Date: 3/17/2015 Collection Time: 7:08 Sampler: HOME OWNER Received Date and Time: 3/20/2015 9:48:28 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.3 ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503155-006

SAMPLE INFORMATION


Sample Number: 1503155-006 Customer Sample Number: 3099044 Program: DS
Location: 2nd draw 1020 G STREET NE Type: Dist.

Collection Date: 3/17/2015 Collection Time: 7:10 Sampler: HOME OWNER Received Date and Time: 3/20/2015 9:48:28 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.6 ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503155-011

SAMPLE INFORMATION


Sample Number: 1503155-011 Customer Sample Number: 3074104 Program: DS
Location: 1st draw 334 12TH ST SE Type: Dist.

Collection Date: 3/16/2015 Collection Time: 7:04 Sampler: HOME OWNER Received Date and Time: 3/20/2015 9:48:28 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	6.2 ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503155-012

SAMPLE INFORMATION


Sample Number: 1503155-012 Customer Sample Number: 3074104 Program: DS
Location: 2nd draw 334 12TH ST SE Type: Dist.

Collection Date: 3/16/2015 Collection Time: 7:05 Sampler: HOME OWNER Received Date and Time: 3/20/2015 9:48:28 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	5.9 ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503155-015

SAMPLE INFORMATION


Sample Number: 1503155-015 Customer Sample Number: 3115009 Program: DS
Location: 1st draw 4437 S DAKOTA AVE NE Type: Dist.

Collection Date: 3/16/2015 Collection Time: 11:00 Sampler: HOME OWNER Received Date and Time: 3/20/2015 9:48:28 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.5 ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503155-016

SAMPLE INFORMATION


Sample Number: 1503155-016 Customer Sample Number: 3115009 Program: DS
Location: 2nd draw 4437 S DAKOTA AVE NE Type: Dist.

Collection Date: 3/16/2015 Collection Time: 11:00 Sampler: HOME OWNER Received Date and Time: 3/20/2015 9:48:28 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503155-017

SAMPLE INFORMATION


Sample Number: 1503155-017 Customer Sample Number: 3123382 Program: DS
Location: 1st draw 3101 SOUTH DAKOTA AVE NE Type: Dist.

Collection Date: 3/15/2015 Collection Time: 16:40 Sampler: HOME OWNER Received Date and Time: 3/20/2015 9:48:28 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503178-001

SAMPLE INFORMATION


Sample Number: 1503178-001 Customer Sample Number: 3018508 Program: DS
Location: 1st Draw 120 BRYANT STREET NW Type: Dist.

Collection Date: 3/19/2015 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 3/24/2015 9:38:54 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503178-002

SAMPLE INFORMATION


Sample Number: 1503178-002 Customer Sample Number: 3018508 Program: DS
Location: 2nd Draw 120 BRYANT STREET NW Type: Dist.

Collection Date: 3/19/2015 Collection Time: 7:01 Sampler: HOME OWNER Received Date and Time: 3/24/2015 9:38:54 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503178-003

SAMPLE INFORMATION


Sample Number: 1503178-003 Customer Sample Number: 3040814 Program: DS
Location: 1st Draw 4906 41ST STREET NW Type: Dist.

Collection Date: 3/19/2015 Collection Time: 6:25 Sampler: HOME OWNER Received Date and Time: 3/24/2015 9:38:54 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	2.0 ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503178-004

SAMPLE INFORMATION


Sample Number: 1503178-004 Customer Sample Number: 3040814 Program: DS
Location: 2nd Draw 4906 41ST STREET NW Type: Dist.

Collection Date: 3/19/2015 Collection Time: 6:27 Sampler: HOME OWNER Received Date and Time: 3/24/2015 9:38:54 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.2 ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503155-001

SAMPLE INFORMATION


Sample Number: 1503155-001 Customer Sample Number: 3062187 Program: DS250
Location: 1st draw 133 WEBSTER ST NW APT 9 Type: Dist.

Collection Date: 3/17/2015 Collection Time: 5:00 Sampler: HOME OWNER Received Date and Time: 3/20/2015 9:48:28 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503155-002

SAMPLE INFORMATION


Sample Number: 1503155-002 Customer Sample Number: 3062187 Program: DS250
Location: 2nd draw 133 WEBSTER ST NW APT 9 Type: Dist.

Collection Date: 3/17/2015 Collection Time: 5:00 Sampler: HOME OWNER Received Date and Time: 3/20/2015 9:48:28 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503204-001

Report revised on 4/6/15 by MC.
Lab Sample Number 1503204-001, the Customer Sample Number was changed from 3050271
to 3058271 as reported on the chain of custody.

SAMPLE INFORMATION


Sample Number: 1503204-001 Customer Sample Number: 3058271 Program: DS
Location: 1st draw 4704 LINNEAN AVE NW Type: Dist.

Collection Date: 3/22/2015 Collection Time: 12:22 Sampler: HOMEOWNER Received Date and Time: 3/27/2015 9:13:34 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	11.0 ug/L	4/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503204-002

Report revised on 4/6/15 by MC.
Lab Sample Number 1503204-002, the Customer Sample Number was changed from 3050271
to 3058271 as reported on the chain of custody.

SAMPLE INFORMATION

Sample Number: 1503204-002

Customer Sample Number: 3058271

Program: DS

Location: 2nd draw 4704 LINNEAN AVE NW

Type: Dist.

Collection Date:
3/22/2015

Collection Time:
12:24

Sampler:
HOMEOWNER

Received Date and Time:
3/27/2015 9:13:34 AM

Received By:
TPasquale


Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.8 ug/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503204-003

SAMPLE INFORMATION


Sample Number: 1503204-003 Customer Sample Number: 3039405 Program: DS
Location: 1st draw 3355 MILITARY RD NW Type: Dist.

Collection Date: 3/22/2015 Collection Time: 6:00 Sampler: HOMEOWNER Received Date and Time: 3/27/2015 9:13:34 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.5 ug/L	4/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503204-004

SAMPLE INFORMATION


Sample Number: 1503204-004 Customer Sample Number: 3039405 Program: DS
Location: 2nd draw 3355 MILITARY RD NW Type: Dist.

Collection Date: 3/22/2015 Collection Time: 6:00 Sampler: HOMEOWNER Received Date and Time: 3/27/2015 9:13:34 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	4/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503204-005

SAMPLE INFORMATION


Sample Number: 1503204-005 Customer Sample Number: 3043481 Program: DS
Location: 1st draw 4466 TINDALL ST NW Type: Dist.

Collection Date: 3/18/2015 Collection Time: 7:30 Sampler: HOMEOWNER Received Date and Time: 3/27/2015 9:13:34 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	4/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503204-006

SAMPLE INFORMATION


Sample Number: 1503204-006 Customer Sample Number: 3043481 Program: DS
Location: 2nd draw 4466 TINDALL ST NW Type: Dist.

Collection Date: 3/18/2015 Collection Time: 7:30 Sampler: HOMEOWNER Received Date and Time: 3/27/2015 9:13:34 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	4/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503224-001

SAMPLE INFORMATION


Sample Number: 1503224-001 Customer Sample Number: 3036105 Program: DS
Location: 1st draw 3405 ASHLEY TERR NW Type: Dist.

Collection Date: 3/25/2015 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:54:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.3 ug/L	4/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503224-002

SAMPLE INFORMATION


Sample Number: 1503224-002 Customer Sample Number: 3036105 Program: DS
Location: 2nd draw 3405 ASHLEY TERR NW Type: Dist.

Collection Date: 3/25/2015 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:54:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.9 ug/L	4/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503224-003

SAMPLE INFORMATION


Sample Number: 1503224-003 Customer Sample Number: 3035965 Program: DS
Location: 1st draw 3511 WOODLEY RD NW Type: Dist.

Collection Date: 3/28/2015 Collection Time: 6:50 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:54:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.5 ug/L	4/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503224-004

SAMPLE INFORMATION


Sample Number: 1503224-004 Customer Sample Number: 3035965 Program: DS
Location: 2nd draw 3511 WOODLEY RD NW Type: Dist.

Collection Date: 3/28/2015 Collection Time: 6:53 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:54:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	4/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503224-007

SAMPLE INFORMATION


Sample Number: 1503224-007 Customer Sample Number: 3079351 Program: DS
Location: 1st draw 3739 O ST SE Type: Dist.

Collection Date: 3/24/2015 Collection Time: 10:40 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:54:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.2 ug/L	4/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503224-008

SAMPLE INFORMATION


Sample Number: 1503224-008 Customer Sample Number: 3079351 Program: DS
Location: 2nd draw 3739 O ST SE Type: Dist.

Collection Date: 3/24/2015 Collection Time: 10:42 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:54:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	4/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503224-009

SAMPLE INFORMATION


Sample Number: 1503224-009 Customer Sample Number: 3031042 Program: DS
Location: 1st draw 1873 INGLESIDE TER NW Type: Dist.

Collection Date: 3/23/2015 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:54:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	4/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503224-010

SAMPLE INFORMATION


Sample Number: 1503224-010 Customer Sample Number: 3031042 Program: DS
Location: 2nd draw 1873 INGLESIDE TER NW Type: Dist.

Collection Date: 3/23/2015 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:54:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	4/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1504001-001

SAMPLE INFORMATION


Sample Number: 1504001-001 Customer Sample Number: 3002600 Program: DS
Location: 1st Draw 1416 T STREET NW Type: Dist.

Collection Date: 3/24/2015 Collection Time: 20:30 Sampler: HOME OWNER Received Date and Time: 4/1/2015 9:47:31 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.2 ug/L	4/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1504001-002

SAMPLE INFORMATION


Sample Number: 1504001-002 Customer Sample Number: 3002600 Program: DS
Location: 2nd Draw 1416 T STREET NW Type: Dist.

Collection Date: 3/24/2015 Collection Time: 20:33 Sampler: HOME OWNER Received Date and Time: 4/1/2015 9:47:31 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.5 ug/L	4/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1504001-005

SAMPLE INFORMATION


Sample Number: 1504001-005 Customer Sample Number: 3019032 Program: DS
Location: 1st Draw 338 ELM ST NW Type: Dist.

Collection Date: 3/27/2015 Collection Time: 7:07 Sampler: HOME OWNER Received Date and Time: 4/1/2015 9:47:31 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	4/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1504001-006

SAMPLE INFORMATION


Sample Number: 1504001-006 Customer Sample Number: 3019032 Program: DS
Location: 2nd Draw 338 ELM ST NW Type: Dist.

Collection Date: 3/27/2015 Collection Time: 7:17 Sampler: HOME OWNER Received Date and Time: 4/1/2015 9:47:31 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	4/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1504001-007

SAMPLE INFORMATION


Sample Number: 1504001-007 Customer Sample Number: 3076280 Program: DS
Location: 1st Draw 1809 D ST. SE Type: Dist.

Collection Date: 3/31/2015 Collection Time: 6:03 Sampler: HOME OWNER Received Date and Time: 4/1/2015 9:47:31 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	4/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1504001-008

SAMPLE INFORMATION


Sample Number: 1504001-008 Customer Sample Number: 3076280 Program: DS
Location: 2nd Draw 1809 D ST. SE Type: Dist.

Collection Date: 3/31/2015 Collection Time: 6:04 Sampler: HOME OWNER Received Date and Time: 4/1/2015 9:47:31 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.6 ug/L	4/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1504001-009

SAMPLE INFORMATION


Sample Number: 1504001-009 Customer Sample Number: 3097181 Program: DS
Location: 1st Draw 1119 PENN ST NE APT 2 Type: Dist.

Collection Date: 3/31/2015 Collection Time: 6:37 Sampler: HOME OWNER Received Date and Time: 4/1/2015 9:47:31 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	4/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1504001-010

SAMPLE INFORMATION


Sample Number: 1504001-010 Customer Sample Number: 3097181 Program: DS
Location: 2nd Draw 1119 PENN ST NE APT 2 Type: Dist.

Collection Date: 3/31/2015 Collection Time: 6:43 Sampler: HOME OWNER Received Date and Time: 4/1/2015 9:47:31 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	4/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: LC-W1504026-003

SAMPLE INFORMATION

Sample Number: 1504026-003 Customer Sample Number: 3043350 Program: DS
Location: 1st Draw 4413 FESSENDEN ST, NW Type: Dist.

Collection Date: 4/1/2015 Collection Time: 18:53 Sampler: HOME OWNER Received Date and Time: 4/3/2015 10:49:02 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	4/6/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/24/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: LC-W1504026-004

SAMPLE INFORMATION

Sample Number: 1504026-004 Customer Sample Number: 3043350 Program: DS
Location: 2nd Draw 4413 FESSENDEN ST, NW Type: Dist.

Collection Date: 4/1/2015 Collection Time: 18:55 Sampler: HOME OWNER Received Date and Time: 4/3/2015 10:49:02 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	4/6/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/24/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: LC-W1504026-005

SAMPLE INFORMATION

Sample Number: 1504026-005 Customer Sample Number: 3042838 Program: DS
Location: 1st Draw 4620 43RD ST NW APT 2 Type: Dist.

Collection Date: 3/28/2015 Collection Time: 6:15 Sampler: HOME OWNER Received Date and Time: 4/3/2015 10:49:02 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.9 ug/L	4/6/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/24/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: LC-W1504026-006

SAMPLE INFORMATION

Sample Number: 1504026-006 Customer Sample Number: 3042838 Program: DS
Location: 2nd Draw 4620 43RD ST NW APT 2 Type: Dist.

Collection Date: 3/28/2015 Collection Time: 6:16 Sampler: HOME OWNER Received Date and Time: 4/3/2015 10:49:02 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.2 ug/L	4/6/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/24/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: LC-W1504026-007

SAMPLE INFORMATION

Sample Number: 1504026-007 Customer Sample Number: 3102060 Program: DS
Location: 1st Draw 1426 MORSE ST NE Type: Dist.
Collection Date: 4/2/2015 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 4/3/2015 10:49:02 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	4/6/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/24/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: LC-W1504026-008

SAMPLE INFORMATION

Sample Number: 1504026-008 Customer Sample Number: 3102060 Program: DS
Location: 2nd Draw 1426 MORSE ST NE Type: Dist.

Collection Date: 4/2/2015 Collection Time: 7:18 Sampler: HOME OWNER Received Date and Time: 4/3/2015 10:49:02 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	4/6/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

4/24/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 5/13/2015
Report Number: LC-W1504065-001

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION


Sample Number: 1504065-001 Customer Sample Number: 3098392 Program: DS
Location: 1st draw 1163 ABBEY PL NE Type: Dist.

Collection Date: 3/31/2015 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 4/8/2015 1:56:49 PM Received By: MMoore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.0 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 5/13/2015
Report Number: LC-W1504065-002

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION


Sample Number: 1504065-002 Customer Sample Number: 3098392 Program: DS
Location: 2nd draw 1163 ABBEY PL NE Type: Dist.

Collection Date: 3/31/2015 Collection Time: 7:20 Sampler: HOME OWNER Received Date and Time: 4/8/2015 1:56:49 PM Received By: MMoore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.5 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 5/13/2015
Report Number: LC-W1504065-003

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


SAMPLE INFORMATION

Sample Number: 1504065-003 Customer Sample Number: 3127340 Program: DS
Location: 1st draw 619 5TH ST NE Type: Dist.
Collection Date: 4/6/2015 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 4/8/2015 1:56:49 PM Received By: MMoore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.9 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 5/13/2015
Report Number: LC-W1504065-004

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION


Sample Number: 1504065-004 Customer Sample Number: 3127340 Program: DS
Location: 2nd draw 619 5TH ST NE Type: Dist.

Collection Date: 4/6/2015 Collection Time: 7:33 Sampler: HOME OWNER Received Date and Time: 4/8/2015 1:56:49 PM Received By: MMoore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.2 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 5/13/2015
Report Number: LC-W1504065-005

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


SAMPLE INFORMATION

Sample Number: 1504065-005 Customer Sample Number: 3033840 Program: DS
Location: 1st draw 1838 KENYON ST NW Type: Dist.
Collection Date: 4/5/2015 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 4/8/2015 1:56:49 PM Received By: MMoore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 5/13/2015
Report Number: LC-W1504065-006

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION


Sample Number: 1504065-006 Customer Sample Number: 3033840 Program: DS
Location: 2nd draw 1838 KENYON ST NW Type: Dist.

Collection Date: 4/5/2015 Collection Time: 8:05 Sampler: HOME OWNER Received Date and Time: 4/8/2015 1:56:49 PM Received By: MMoore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 5/13/2015
Report Number: LC-W1504065-007

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1504065-007 Customer Sample Number: 3103114 Program: DS
Location: 1st draw 209 RHODE ISLAND AVE NE Type: Dist.
Collection Date: 3/27/2015 Collection Time: 7:43 Sampler: HOME OWNER Received Date and Time: 4/8/2015 1:56:49 PM Received By: MMoore


Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	5/5/2015	RHoffa

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 5/13/2015
Report Number: LC-W1504065-008

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION


Sample Number: 1504065-008 Customer Sample Number: 3103114 Program: DS
Location: 2nd draw 209 RHODE ISLAND AVE NE Type: Dist.

Collection Date: 3/27/2015 Collection Time: 7:45 Sampler: HOME OWNER Received Date and Time: 4/8/2015 1:56:49 PM Received By: MMoore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	5.2 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 5/13/2015
Report Number: LC-W1504065-009

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION


Sample Number: 1504065-009 Customer Sample Number: 3122059 Program: DS
Location: 1st draw 303 ADAMS ST NE Type: Dist.

Collection Date: 4/2/2015 Collection Time: 18:07 Sampler: HOME OWNER Received Date and Time: 4/8/2015 1:56:49 PM Received By: MMoore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.2 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 5/13/2015
Report Number: LC-W1504065-010

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION


Sample Number: 1504065-010 Customer Sample Number: 3122059 Program: DS
Location: 2nd draw 303 ADAMS ST NE Type: Dist.

Collection Date: 4/2/2015 Collection Time: 18:08 Sampler: HOME OWNER Received Date and Time: 4/8/2015 1:56:49 PM Received By: MMoore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504103-001

SAMPLE INFORMATION


Sample Number: 1504103-001 Customer Sample Number: 3107904 Program: DS
Location: 1st draw 2618 EVARTS ST NE Type: Dist.

Collection Date: 4/8/2015 Collection Time: 20:15 Sampler: HOME OWNER Received Date and Time: 4/14/2015 12:18:07 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	11.2 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504103-002

SAMPLE INFORMATION


Sample Number: 1504103-002 Customer Sample Number: 3107904 Program: DS
Location: 2nd draw 2618 EVARTS ST NE Type: Dist.

Collection Date: 4/8/2015 Collection Time: 20:16 Sampler: HOME OWNER Received Date and Time: 4/14/2015 12:18:07 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	3.9 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504103-003

SAMPLE INFORMATION


Sample Number: 1504103-003 Customer Sample Number: 3006210 Program: DS
Location: 1st draw 1708 NJ AVE NW Type: Dist.

Collection Date: 4/1/2015 Collection Time: 16:40 Sampler: HOME OWNER Received Date and Time: 4/14/2015 12:18:07 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504103-004

SAMPLE INFORMATION


Sample Number: 1504103-004 Customer Sample Number: 3006210 Program: DS
Location: 2nd draw 1708 NJ AVE NW Type: Dist.

Collection Date: 4/1/2015 Collection Time: 16:44 Sampler: HOME OWNER Received Date and Time: 4/14/2015 12:18:07 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504103-005

SAMPLE INFORMATION


Sample Number: 1504103-005 Customer Sample Number: 3000974 Program: DS
Location: 1st draw 1630 A 19TH ST NW Type: Dist.

Collection Date: 4/4/2015 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 4/14/2015 12:18:07 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504103-006

SAMPLE INFORMATION


Sample Number: 1504103-006 Customer Sample Number: 3000974 Program: DS
Location: 2nd draw 1630 A 19TH ST NW Type: Dist.

Collection Date: 4/4/2015 Collection Time: 6:05 Sampler: HOME OWNER Received Date and Time: 4/14/2015 12:18:07 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504103-007

SAMPLE INFORMATION


Sample Number: 1504103-007 Customer Sample Number: 3059493 Program: DS
Location: 1st draw 5025 TILDEN ST NW Type: Dist.

Collection Date: 4/8/2015 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 4/14/2015 12:18:07 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504103-008

SAMPLE INFORMATION


Sample Number: 1504103-008 Customer Sample Number: 3059493 Program: DS
Location: 2nd draw 5025 TILDEN ST NW Type: Dist.

Collection Date: 4/8/2015 Collection Time: 7:16 Sampler: HOME OWNER Received Date and Time: 4/14/2015 12:18:07 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504111-001

SAMPLE INFORMATION


Sample Number: 1504111-001 Customer Sample Number: 3047413 Program: DS
Location: 1st draw 1316 LEEGATE RD NW Type: Dist.

Collection Date: 4/6/2015 Collection Time: 5:20 Sampler: HOME OWNER Received Date and Time: 4/15/2015 10:47:35 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504111-002

SAMPLE INFORMATION


Sample Number: 1504111-002 Customer Sample Number: 3047413 Program: DS
Location: 2nd draw 1316 LEEGATE RD NW Type: Dist.

Collection Date: 4/6/2015 Collection Time: 5:22 Sampler: HOME OWNER Received Date and Time: 4/15/2015 10:47:35 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504111-003

SAMPLE INFORMATION


Sample Number: 1504111-003 Customer Sample Number: 3078464 Program: DS
Location: 1st draw 2523 NAYLOR RD SE Type: Dist.

Collection Date: 4/7/2015 Collection Time: 5:52 Sampler: HOME OWNER Received Date and Time: 4/15/2015 10:47:35 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.6 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504111-004

SAMPLE INFORMATION


Sample Number: 1504111-004 Customer Sample Number: 3078464 Program: DS
Location: 2nd draw 2523 NAYLOR RD SE Type: Dist.

Collection Date: 4/7/2015 Collection Time: 5:53 Sampler: HOME OWNER Received Date and Time: 4/15/2015 10:47:35 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504111-005

SAMPLE INFORMATION


Sample Number: 1504111-005 Customer Sample Number: 3033465 Program: DS
Location: 1st draw 1445 CLIFTON ST NW Type: Dist.

Collection Date: 4/8/2015 Collection Time: 6:04 Sampler: HOME OWNER Received Date and Time: 4/15/2015 10:47:35 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504111-006

SAMPLE INFORMATION


Sample Number: 1504111-006 Customer Sample Number: 3033465 Program: DS
Location: 2nd draw 1445 CLIFTON ST NW Type: Dist.

Collection Date: 4/8/2015 Collection Time: 6:04 Sampler: HOME OWNER Received Date and Time: 4/15/2015 10:47:35 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.2 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504111-009

SAMPLE INFORMATION


Sample Number: 1504111-009 Customer Sample Number: 3010276 Program: DS
Location: 1st draw 3830 BEECHER ST NW Type: Dist.

Collection Date: 4/11/2015 Collection Time: 8:16 Sampler: HOME OWNER Received Date and Time: 4/15/2015 10:47:35 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.8 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504111-010

SAMPLE INFORMATION


Sample Number: 1504111-010 Customer Sample Number: 3010276 Program: DS
Location: 2nd draw 3830 BEECHER ST NW Type: Dist.

Collection Date: 4/11/2015 Collection Time: 8:17 Sampler: HOME OWNER Received Date and Time: 4/15/2015 10:47:35 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504111-011

SAMPLE INFORMATION


Sample Number: 1504111-011 Customer Sample Number: 3028613 Program: DS
Location: 1st draw 1344 SHEPHERD ST NW Type: Dist.

Collection Date: 4/12/2015 Collection Time: 5:05 Sampler: HOME OWNER Received Date and Time: 4/15/2015 10:47:35 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.5 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504111-012

SAMPLE INFORMATION


Sample Number: 1504111-012 Customer Sample Number: 3028613 Program: DS
Location: 2nd draw 1344 SHEPHERD ST NW Type: Dist.

Collection Date: 4/12/2015 Collection Time: 5:08 Sampler: HOME OWNER Received Date and Time: 4/15/2015 10:47:35 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	8.6 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504132-003

SAMPLE INFORMATION


Sample Number: 1504132-003 Customer Sample Number: 3103184 Program: DS
Location: 1st draw 2420 3RD ST NE Type: Dist.

Collection Date: 4/13/2015 Collection Time: 19:00 Sampler: HOME OWNER Received Date and Time: 4/17/2015 12:34:26 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.1 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504132-004

SAMPLE INFORMATION


Sample Number: 1504132-004 Customer Sample Number: 3103184 Program: DS
Location: 2nd draw 2420 3RD ST NE Type: Dist.

Collection Date: 4/13/2015 Collection Time: 19:04 Sampler: HOME OWNER Received Date and Time: 4/17/2015 12:34:26 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504132-005

SAMPLE INFORMATION


Sample Number: 1504132-005 Customer Sample Number: 3029592 Program: DS
Location: 1st draw 3610 13TH ST NW Type: Dist.

Collection Date: 4/14/2015 Collection Time: 6:45 Sampler: HOME OWNER Received Date and Time: 4/17/2015 12:34:26 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.7 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504132-006

SAMPLE INFORMATION


Sample Number: 1504132-006 Customer Sample Number: 3029592 Program: DS
Location: 2nd draw 3610 13TH ST NW Type: Dist.

Collection Date: 4/14/2015 Collection Time: 6:46 Sampler: HOME OWNER Received Date and Time: 4/17/2015 12:34:26 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	2.6 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504180-003

SAMPLE INFORMATION


Sample Number: 1504180-003 Customer Sample Number: 3044278 Program: DS
Location: 1st Draw 4440 GARFIELD ST Type: Dist.

Collection Date: 4/17/2015 Collection Time: 5:30 Sampler: HOME OWNER Received Date and Time: 4/24/2015 9:02:17 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.0 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504180-004

SAMPLE INFORMATION


Sample Number: 1504180-004 Customer Sample Number: 3044278 Program: DS
Location: 2nd Draw 4440 GARFIELD ST Type: Dist.

Collection Date: 4/17/2015 Collection Time: 5:40 Sampler: HOME OWNER Received Date and Time: 4/24/2015 9:02:17 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	2.2 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504180-005

SAMPLE INFORMATION


Sample Number: 1504180-005 Customer Sample Number: 3076301 Program: DS
Location: 1st Draw 1814 POTOMAC AVE. SE Type: Dist.

Collection Date: 4/22/2015 Collection Time: 5:30 Sampler: HOME OWNER Received Date and Time: 4/24/2015 9:02:17 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504180-006

SAMPLE INFORMATION


Sample Number: 1504180-006 Customer Sample Number: 3076301 Program: DS
Location: 2nd Draw 1814 POTOMAC AVE. SE Type: Dist.

Collection Date: 4/22/2015 Collection Time: 5:33 Sampler: HOME OWNER Received Date and Time: 4/24/2015 9:02:17 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504180-007

SAMPLE INFORMATION


Sample Number: 1504180-007 Customer Sample Number: 3040437 Program: DS
Location: 1st Draw 3809 JENIFER ST, NW Type: Dist.

Collection Date: 4/20/2015 Collection Time: 18:20 Sampler: HOME OWNER Received Date and Time: 4/24/2015 9:02:17 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.0 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504180-008

SAMPLE INFORMATION


Sample Number: 1504180-008 Customer Sample Number: 3040437 Program: DS
Location: 2nd Draw 3809 JENIFER ST, NW Type: Dist.

Collection Date: 4/20/2015 Collection Time: 18:20 Sampler: HOME OWNER Received Date and Time: 4/24/2015 9:02:17 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.6 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504180-009

SAMPLE INFORMATION


Sample Number: 1504180-009 Customer Sample Number: 3106578 Program: DS
Location: 1st Draw 1925 UPSHUR ST NE Type: Dist.

Collection Date: 4/20/2015 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 4/24/2015 9:02:17 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.2 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504180-010

SAMPLE INFORMATION


Sample Number: 1504180-010 Customer Sample Number: 3106578 Program: DS
Location: 2nd Draw 1925 UPSHUR ST NE Type: Dist.

Collection Date: 4/20/2015 Collection Time: 7:03 Sampler: HOME OWNER Received Date and Time: 4/24/2015 9:02:17 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504180-011

SAMPLE INFORMATION


Sample Number: 1504180-011 Customer Sample Number: 3004413 Program: DS
Location: 1st Draw 916 FRENCH ST NW Type: Dist.

Collection Date: 4/17/2015 Collection Time: 17:20 Sampler: HOME OWNER Received Date and Time: 4/24/2015 9:02:17 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504180-012

SAMPLE INFORMATION


Sample Number: 1504180-012 Customer Sample Number: 3004413 Program: DS
Location: 2nd Draw 916 FRENCH ST NW Type: Dist.

Collection Date: 4/17/2015 Collection Time: 17:22 Sampler: HOME OWNER Received Date and Time: 4/24/2015 9:02:17 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504180-013

SAMPLE INFORMATION


Sample Number: 1504180-013 Customer Sample Number: 3074956 Program: DS
Location: 1st Draw 1426 K ST SE Type: Dist.

Collection Date: 4/14/2015 Collection Time: 6:35 Sampler: HOME OWNER Received Date and Time: 4/24/2015 9:02:17 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	11.4 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504180-014

SAMPLE INFORMATION


Sample Number: 1504180-014 Customer Sample Number: 3074956 Program: DS
Location: 2nd Draw 1426 K ST SE Type: Dist.

Collection Date: 4/14/2015 Collection Time: 6:40 Sampler: HOME OWNER Received Date and Time: 4/24/2015 9:02:17 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.8 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1505005-005

SAMPLE INFORMATION


Sample Number: 1505005-005 Customer Sample Number: 3074107 Program: DS
Location: 1st draw 328 12TH ST SE Type: Dist.

Collection Date: 4/28/2015 Collection Time: 4:06 Sampler: HOME OWNER Received Date and Time: 5/1/2015 12:32:38 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	3.6 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1505005-006

SAMPLE INFORMATION


Sample Number: 1505005-006 Customer Sample Number: 3074107 Program: DS
Location: 2nd draw 328 12TH ST SE Type: Dist.

Collection Date: 4/28/2015 Collection Time: 4:07 Sampler: HOME OWNER Received Date and Time: 5/1/2015 12:32:38 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.6 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1505005-009

SAMPLE INFORMATION


Sample Number: 1505005-009 Customer Sample Number: 3128643 Program: DS
Location: 1st draw 1115 I ST NE Type: Dist.

Collection Date: 4/27/2015 Collection Time: 19:17 Sampler: HOME OWNER Received Date and Time: 5/1/2015 12:32:38 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1505005-010

SAMPLE INFORMATION


Sample Number: 1505005-010 Customer Sample Number: 3128643 Program: DS
Location: 2nd draw 1115 I ST NE Type: Dist.

Collection Date: 4/27/2015 Collection Time: 19:20 Sampler: HOME OWNER Received Date and Time: 5/1/2015 12:32:38 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1505005-013

SAMPLE INFORMATION


Sample Number: 1505005-013 Customer Sample Number: 3034050 Program: DS
Location: 1st draw 1642 ARGONNE PL NW Type: Dist.

Collection Date: 4/27/2015 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 5/1/2015 12:32:38 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.2 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1505005-014

SAMPLE INFORMATION


Sample Number: 1505005-014 Customer Sample Number: 3034050 Program: DS
Location: 2nd draw 1642 ARGONNE PL NW Type: Dist.

Collection Date: 4/27/2015 Collection Time: 7:03 Sampler: HOME OWNER Received Date and Time: 5/1/2015 12:32:38 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	2.4 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1505005-015

SAMPLE INFORMATION


Sample Number: 1505005-015 Customer Sample Number: 3105016 Program: DS
Location: 1st draw 3201 15TH ST NE Type: Dist.

Collection Date: 4/27/2015 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 5/1/2015 12:32:38 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.4 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1505005-016

SAMPLE INFORMATION


Sample Number: 1505005-016 Customer Sample Number: 3105016 Program: DS
Location: 2nd draw 3201 15TH ST NE Type: Dist.

Collection Date: 4/27/2015 Collection Time: 6:35 Sampler: HOME OWNER Received Date and Time: 5/1/2015 12:32:38 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	2.7 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 5/13/2015
Report Number: LC-W1504065-011

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


SAMPLE INFORMATION

Sample Number: 1504065-011 Customer Sample Number: 3014122 Program: DS250
Location: 1st draw 601 PENNSYLVANIA AVE NW APT 1102 Type: Dist.
Collection Date: 3/31/2015 Collection Time: 3:40 Sampler: HOME OWNER Received Date and Time: 4/8/2015 1:56:49 PM Received By: MMoore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer Authority

Report Date: 5/13/2015
Report Number: LC-W1504065-012

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


SAMPLE INFORMATION

Sample Number: 1504065-012 Customer Sample Number: 3014122 Program: DS250
Location: 2nd draw 601 PENNSYLVANIA AVE NW APT 1102 Type: Dist.
Collection Date: 3/31/2015 Collection Time: 3:40 Sampler: HOME OWNER Received Date and Time: 4/8/2015 1:56:49 PM Received By: MMoore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505056-001

SAMPLE INFORMATION


Sample Number: 1505056-001 Customer Sample Number: 3105584 Program: DS
Location: 1st Draw 4307 18TH ST NE Type: Dist.

Collection Date: 4/30/2015 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 5/8/2015 10:39:13 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.0 ug/L	5/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505056-002

SAMPLE INFORMATION


Sample Number: 1505056-002 Customer Sample Number: 3105584 Program: DS
Location: 2nd Draw 4307 18TH ST NE Type: Dist.

Collection Date: 4/30/2015 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 5/8/2015 10:39:13 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	5/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505056-003

SAMPLE INFORMATION


Sample Number: 1505056-003 Customer Sample Number: 3040364 Program: DS
Location: 1st Draw 3925 GARRISON ST NW Type: Dist.

Collection Date: 5/1/2015 Collection Time: 6:54 Sampler: HOME OWNER Received Date and Time: 5/8/2015 10:39:13 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	5/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505056-004

SAMPLE INFORMATION


Sample Number: 1505056-004 Customer Sample Number: 3040364 Program: DS
Location: 2nd Draw 3925 GARRISON ST NW Type: Dist.

Collection Date: 5/1/2015 Collection Time: 6:57 Sampler: HOME OWNER Received Date and Time: 5/8/2015 10:39:13 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	5/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505056-005

SAMPLE INFORMATION


Sample Number: 1505056-005 Customer Sample Number: 3125289 Program: DS
Location: 1st Draw 14 TODD PL NE Type: Dist.

Collection Date: 5/5/2015 Collection Time: 7:45 Sampler: HOME OWNER Received Date and Time: 5/8/2015 10:39:13 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	3.4 ug/L	5/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505056-006

SAMPLE INFORMATION


Sample Number: 1505056-006 Customer Sample Number: 3125289 Program: DS
Location: 2nd Draw 14 TODD PL NE Type: Dist.

Collection Date: 5/5/2015 Collection Time: 7:46 Sampler: HOME OWNER Received Date and Time: 5/8/2015 10:39:13 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	2.1 ug/L	5/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: LC-W1505109-001

SAMPLE INFORMATION


Sample Number: 1505109-001 Customer Sample Number: 3052030 Program: DS
Location: 1st draw 2005 1ST ST NW Type: Dist.

Collection Date: 5/13/2015 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 5/15/2015 11:34:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.6 ug/L	6/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: LC-W1505109-002

SAMPLE INFORMATION


Sample Number: 1505109-002 Customer Sample Number: 3052030 Program: DS
Location: 2nd draw 2005 1ST ST NW Type: Dist.

Collection Date: 5/13/2015 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 5/15/2015 11:34:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	6/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: LC-W1505109-003

SAMPLE INFORMATION


Sample Number: 1505109-003 Customer Sample Number: 3007747 Program: DS
Location: 1st draw 3040 DENT PLACE NW Type: Dist.

Collection Date: 5/11/2015 Collection Time: 19:50 Sampler: HOME OWNER Received Date and Time: 5/15/2015 11:34:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.2 ug/L	6/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: LC-W1505109-004

SAMPLE INFORMATION


Sample Number: 1505109-004 Customer Sample Number: 3007747 Program: DS
Location: 2nd draw 3040 DENT PLACE NW Type: Dist.

Collection Date: 5/11/2015 Collection Time: 19:55 Sampler: HOME OWNER Received Date and Time: 5/15/2015 11:34:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	6/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: LC-W1505109-005

SAMPLE INFORMATION


Sample Number: 1505109-005 Customer Sample Number: 3109643 Program: DS
Location: 1st draw 5358 AMES ST NE Type: Dist.

Collection Date: 5/12/2015 Collection Time: 6:45 Sampler: HOME OWNER Received Date and Time: 5/15/2015 11:34:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	6/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: LC-W1505109-006

SAMPLE INFORMATION


Sample Number: 1505109-006 Customer Sample Number: 3109643 Program: DS
Location: 2nd draw 5358 AMES ST NE Type: Dist.

Collection Date: 5/12/2015 Collection Time: 6:47 Sampler: HOME OWNER Received Date and Time: 5/15/2015 11:34:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	6/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: LC-W1505109-007

SAMPLE INFORMATION


Sample Number: 1505109-007 Customer Sample Number: 3028769 Program: DS
Location: 1st draw 1610 VARNUM ST NW Type: Dist.

Collection Date: 5/12/2015 Collection Time: 7:58 Sampler: HOME OWNER Received Date and Time: 5/15/2015 11:34:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.7 ug/L	6/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: LC-W1505109-008

SAMPLE INFORMATION


Sample Number: 1505109-008 Customer Sample Number: 3028769 Program: DS
Location: 2nd draw 1610 VARNUM ST NW Type: Dist.

Collection Date: 5/12/2015 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 5/15/2015 11:34:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.9 ug/L	6/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: LC-W1505109-009

SAMPLE INFORMATION


Sample Number: 1505109-009 Customer Sample Number: 3023924 Program: DS
Location: 1st draw 827 INGRAHAM ST NW Type: Dist.

Collection Date: 5/13/2015 Collection Time: 5:05 Sampler: HOME OWNER Received Date and Time: 5/15/2015 11:34:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.8 ug/L	6/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: LC-W1505109-010

SAMPLE INFORMATION


Sample Number: 1505109-010 Customer Sample Number: 3023924 Program: DS
Location: 2nd draw 827 INGRAHAM ST NW Type: Dist.

Collection Date: 5/13/2015 Collection Time: 5:05 Sampler: HOME OWNER Received Date and Time: 5/15/2015 11:34:18 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.6 ug/L	6/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: LC-W1505159-001

SAMPLE INFORMATION


Sample Number: 1505159-001 Customer Sample Number: 3045198 Program: DS
Location: 1st Draw 4933 MACARTHUR BLVD NW Type: Dist.

Collection Date: 5/14/2015 Collection Time: 6:25 Sampler: HOME OWNER Received Date and Time: 5/22/2015 11:54:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	6/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: LC-W1505159-002

SAMPLE INFORMATION


Sample Number: 1505159-002 Customer Sample Number: 3045198 Program: DS
Location: 2nd Draw 4933 MACARTHUR BLVD NW Type: Dist.

Collection Date: 5/14/2015 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 5/22/2015 11:54:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	6/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: LC-W1505159-005


SAMPLE INFORMATION

Sample Number: 1505159-005 Customer Sample Number: 3029291 Program: DS
Location: 1st Draw 1204 SHEPHERD ST NW Type: Dist.
Collection Date: 5/18/2015 Collection Time: 6:34 Sampler: HOME OWNER Received Date and Time: 5/22/2015 11:54:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	6/3/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: LC-W1505159-006


SAMPLE INFORMATION

Sample Number: 1505159-006 Customer Sample Number: 3029291 Program: DS
Location: 2nd Draw 1204 SHEPHERD ST NW Type: Dist.
Collection Date: 5/18/2015 Collection Time: 6:37 Sampler: HOME OWNER Received Date and Time: 5/22/2015 11:54:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	6/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: LC-W1505159-007

SAMPLE INFORMATION


Sample Number: 1505159-007 Customer Sample Number: 3039365 Program: DS
Location: 1st Draw 3613 MILITARY ROAD, NW Type: Dist.

Collection Date: 5/18/2015 Collection Time: 14:54 Sampler: HOME OWNER Received Date and Time: 5/22/2015 11:54:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.4 ug/L	6/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: LC-W1505159-008

SAMPLE INFORMATION


Sample Number: 1505159-008 Customer Sample Number: 3039365 Program: DS
Location: 2nd Draw 3613 MILITARY ROAD, NW Type: Dist.

Collection Date: 5/18/2015 Collection Time: 14:59 Sampler: HOME OWNER Received Date and Time: 5/22/2015 11:54:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.6 ug/L	6/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: LC-W1505159-009

SAMPLE INFORMATION


Sample Number: 1505159-009 Customer Sample Number: 3098478 Program: DS
Location: 1st Draw 1106 5TH ST. NE Type: Dist.

Collection Date: 5/19/2015 Collection Time: 19:02 Sampler: HOME OWNER Received Date and Time: 5/22/2015 11:54:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.7 ug/L	6/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: LC-W1505159-010

SAMPLE INFORMATION


Sample Number: 1505159-010 Customer Sample Number: 3098478 Program: DS
Location: 2nd Draw 1106 5TH ST. NE Type: Dist.

Collection Date: 5/19/2015 Collection Time: 19:08 Sampler: HOME OWNER Received Date and Time: 5/22/2015 11:54:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.9 ug/L	6/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: LC-W1506009-001

SAMPLE INFORMATION


Sample Number: 1506009-001 Customer Sample Number: 3052912 Program: DS
Location: 1st draw 5010 CATHEDRAL AVE NW Type: Dist.

Collection Date: 5/26/2015 Collection Time: 5:40 Sampler: HOME OWNER Received Date and Time: 6/1/2015 11:45:53 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	6/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: LC-W1506009-002

SAMPLE INFORMATION


Sample Number: 1506009-002 Customer Sample Number: 3052912 Program: DS
Location: 2nd draw 5010 CATHEDRAL AVE NW Type: Dist.

Collection Date: 5/26/2015 Collection Time: 5:44 Sampler: HOME OWNER Received Date and Time: 6/1/2015 11:45:53 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	6/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: LC-W1506009-003

SAMPLE INFORMATION


Sample Number: 1506009-003 Customer Sample Number: 3103058 Program: DS
Location: 1st draw 1840 3RD ST NE Type: Dist.

Collection Date: 5/28/2015 Collection Time: 6:20 Sampler: HOME OWNER Received Date and Time: 6/1/2015 11:45:53 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.7 ug/L	6/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: LC-W1506009-004

SAMPLE INFORMATION


Sample Number: 1506009-004 Customer Sample Number: 3103058 Program: DS
Location: 2nd draw 1840 3RD ST NE Type: Dist.

Collection Date: 5/28/2015 Collection Time: 6:23 Sampler: HOME OWNER Received Date and Time: 6/1/2015 11:45:53 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	3.3 ug/L	6/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: LC-W1506009-005

SAMPLE INFORMATION


Sample Number: 1506009-005 Customer Sample Number: 3122980 Program: DS
Location: 1st draw 614 15TH ST NE Type: Dist.

Collection Date: 5/24/2015 Collection Time: 8:10 Sampler: HOME OWNER Received Date and Time: 6/1/2015 11:45:53 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	6/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: LC-W1506009-006

SAMPLE INFORMATION


Sample Number: 1506009-006 Customer Sample Number: 3122980 Program: DS
Location: 2nd draw 614 15TH ST NE Type: Dist.

Collection Date: 5/24/2015 Collection Time: 8:11 Sampler: HOME OWNER Received Date and Time: 6/1/2015 11:45:53 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	6/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: LC-W1506009-009

SAMPLE INFORMATION


Sample Number: 1506009-009 Customer Sample Number: 3072558 Program: DS
Location: 1st draw 654 INDEPENDENCE AVE SE Type: Dist.

Collection Date: 5/21/2015 Collection Time: 21:30 Sampler: HOME OWNER Received Date and Time: 6/1/2015 11:45:53 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	6/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: LC-W1506009-010

SAMPLE INFORMATION


Sample Number: 1506009-010 Customer Sample Number: 3072558 Program: DS
Location: 2nd draw 654 INDEPENDENCE AVE SE Type: Dist.

Collection Date: 5/21/2015 Collection Time: 21:30 Sampler: HOME OWNER Received Date and Time: 6/1/2015 11:45:53 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	6/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/22/2015
Report Number: LC-W1506053-001

SAMPLE INFORMATION

Sample Number: 1506053-001 Customer Sample Number: 3009445 Program: DS
Location: 1st draw 3518 S ST NW Type: Dist.

Collection Date: 5/26/2015 Collection Time: 16:00 Sampler: HOME OWNER Received Date and Time: 6/8/2015 12:43:27 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.4 ug/L	6/9/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

6/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/22/2015
Report Number: LC-W1506053-002

SAMPLE INFORMATION


Sample Number: 1506053-002 Customer Sample Number: 3009445 Program: DS
Location: 2nd draw 3518 S ST NW Type: Dist.

Collection Date: 5/26/2015 Collection Time: 16:02 Sampler: HOME OWNER Received Date and Time: 6/8/2015 12:43:27 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	4.2 ug/L	6/9/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/22/2015
Report Number: LC-W1506053-003

SAMPLE INFORMATION


Sample Number: 1506053-003 Customer Sample Number: 3031021 Program: DS
Location: 1st draw 1829 INGLESIDE TER NW Type: Dist.

Collection Date: 5/28/2015 Collection Time: 4:00 Sampler: HOME OWNER Received Date and Time: 6/8/2015 12:43:27 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.5 ug/L	6/9/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/22/2015
Report Number: LC-W1506053-004

SAMPLE INFORMATION


Sample Number: 1506053-004 Customer Sample Number: 3031021 Program: DS
Location: 2nd draw 1829 INGLESIDE TER NW Type: Dist.

Collection Date: 5/28/2015 Collection Time: 4:00 Sampler: HOME OWNER Received Date and Time: 6/8/2015 12:43:27 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	6/9/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/22/2015
Report Number: LC-W1506053-007


SAMPLE INFORMATION

Sample Number: 1506053-007 Customer Sample Number: 3120642 Program: DS
Location: 1st draw 915 F ST NE Type: Dist.

Collection Date: 5/29/2015 Collection Time: 7:20 Sampler: HOME OWNER Received Date and Time: 6/8/2015 12:43:27 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.5 ug/L	6/9/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By: 
Robert P. Hoffa, Laboratory Manager

6/22/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/22/2015
Report Number: LC-W1506053-008

SAMPLE INFORMATION


Sample Number: 1506053-008 Customer Sample Number: 3120642 Program: DS
Location: 2nd draw 915 F ST NE Type: Dist.

Collection Date: 5/29/2015 Collection Time: 7:22 Sampler: HOME OWNER Received Date and Time: 6/8/2015 12:43:27 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	6/9/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/22/2015
Report Number: LC-W1506053-013

SAMPLE INFORMATION


Sample Number: 1506053-013 Customer Sample Number: 3119902 Program: DS
Location: 1st draw 5214 12TH ST NE Type: Dist.

Collection Date: 6/3/2015 Collection Time: 6:29 Sampler: HOME OWNER Received Date and Time: 6/8/2015 12:43:27 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	6/9/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/22/2015
Report Number: LC-W1506053-014

SAMPLE INFORMATION


Sample Number: 1506053-014 Customer Sample Number: 3119902 Program: DS
Location: 2nd draw 5214 12TH ST NE Type: Dist.

Collection Date: 6/3/2015 Collection Time: 6:31 Sampler: HOME OWNER Received Date and Time: 6/8/2015 12:43:27 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	6/9/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/22/2015
Report Number: LC-W1506093-001


SAMPLE INFORMATION

Sample Number: 1506093-001 Customer Sample Number: 3031013 Program: DS
Location: 1st draw 1813 INGLESIDE TER, NW Type: Dist.
Collection Date: 6/6/2015 Collection Time: 17:25 Sampler: HOME OWNER Received Date and Time: 6/12/2015 9:23:30 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	6/18/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/22/2015
Report Number: LC-W1506093-002

SAMPLE INFORMATION


Sample Number: 1506093-002 Customer Sample Number: 3031013 Program: DS
Location: 2nd draw 1813 INGLESIDE TER, NW Type: Dist.

Collection Date: 6/6/2015 Collection Time: 17:28 Sampler: HOME OWNER Received Date and Time: 6/12/2015 9:23:30 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	6/18/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/22/2015
Report Number: LC-W1506122-001

SAMPLE INFORMATION


Sample Number: 1506122-001 Customer Sample Number: 3057043 Program: DS
Location: 1st Draw 717 UPSHUR ST NW Type: Dist.

Collection Date: 6/9/2015 Collection Time: 21:32 Sampler: HOME OWNER Received Date and Time: 6/17/2015 9:16:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.5 ug/L	6/18/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/22/2015
Report Number: LC-W1506122-002

SAMPLE INFORMATION


Sample Number: 1506122-002 Customer Sample Number: 3057043 Program: DS
Location: 2nd Draw 717 UPSHUR ST NW Type: Dist.

Collection Date: 6/9/2015 Collection Time: 21:35 Sampler: HOME OWNER Received Date and Time: 6/17/2015 9:16:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.6 ug/L	6/18/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/22/2015
Report Number: LC-W1506122-005

SAMPLE INFORMATION


Sample Number: 1506122-005 Customer Sample Number: 3100386 Program: DS
Location: 1st Draw 4238 H ST., S.E. Type: Dist.

Collection Date: 6/11/2015 Collection Time: 15:10 Sampler: HOME OWNER Received Date and Time: 6/17/2015 9:16:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.7 ug/L	6/18/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/22/2015
Report Number: LC-W1506122-006

SAMPLE INFORMATION


Sample Number: 1506122-006 Customer Sample Number: 3100386 Program: DS
Location: 2nd Draw 4238 H ST., S.E. Type: Dist.

Collection Date: 6/11/2015 Collection Time: 15:15 Sampler: HOME OWNER Received Date and Time: 6/17/2015 9:16:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.0 ug/L	6/18/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/22/2015
Report Number: LC-W1506122-007

SAMPLE INFORMATION


Sample Number: 1506122-007 Customer Sample Number: 3008876 Program: DS
Location: 1st Draw 3242 Q ST NW Type: Dist.

Collection Date: 6/12/2015 Collection Time: 7:04 Sampler: HOME OWNER Received Date and Time: 6/17/2015 9:16:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	6/18/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/22/2015
Report Number: LC-W1506122-008

SAMPLE INFORMATION


Sample Number: 1506122-008 Customer Sample Number: 3008876 Program: DS
Location: 2nd Draw 3242 Q ST NW Type: Dist.

Collection Date: 6/12/2015 Collection Time: 7:05 Sampler: HOME OWNER Received Date and Time: 6/17/2015 9:16:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	6/18/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/22/2015

Date

Post Lead Service Line Replacement Samples

DC Water operates a program where lead sampling kits are dropped off to customers that have had a partial or full lead service line replacement. Samples are typically dropped off 4.5 months after the replacement to determine if it is necessary for customers to continue filtering their water. The kit comes with bottles and instructions on how to take first and second draw samples. Customers collect their own samples and contact DC Water to deliver the bottles to the Washington Aqueduct. Results are then reported back to the customer through DC Water's Customer Service Program.

This attached sample analysis data contains personal information of DC Water's customers, such as names and home addresses, the disclosure of which would constitute a violation of D.C. Code § 2-534(a)(2) and 5 U.S.C. § 552(b)(6). If EPA is requested to produce the sampling analysis data in whole or in part, in order to maintain confidentiality, the personal information must be redacted from the documents produced.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/15/2015
Report Number: LC-W1412089-007

SAMPLE INFORMATION

Sample Number: 1412089-007 Customer Sample Number: 3036072 Program: Post-LSR
Location: 1st draw 2934 NEWARK ST. NW Type: Dist.
Collection Date: 12/8/2014 Collection Time: 6:14 Sampler: HOME OWNER Received Date and Time: 12/10/2014 11:43:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.9 ug/L	12/17/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/15/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/15/2015
Report Number: LC-W1412089-008

SAMPLE INFORMATION

Sample Number: 1412089-008 Customer Sample Number: 3036072 Program: Post-LSR
Location: 2nd draw 2934 NEWARK ST. NW Type: Dist.

Collection Date: 12/8/2014 Collection Time: 6:16 Sampler: HOME OWNER Received Date and Time: 12/10/2014 11:43:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	12/17/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/15/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/15/2015
Report Number: LC-W1412089-009

SAMPLE INFORMATION

Sample Number: 1412089-009 Customer Sample Number: Program: Post-LSR
Location: 1st draw 4401 5TH ST. NW Type: Dist.
Collection Date: 12/8/2014 Collection Time: 7:38 Sampler: HOME OWNER Received Date and Time: 12/10/2014 11:43:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	11.1 ug/L	12/17/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/15/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/15/2015
Report Number: LC-W1412089-010

SAMPLE INFORMATION

Sample Number: 1412089-010 Customer Sample Number: Program: Post-LSR
Location: 2nd draw 4401 5TH ST. NW Type: Dist.

Collection Date: 12/8/2014 Collection Time: 7:39 Sampler: HOME OWNER Received Date and Time: 12/10/2014 11:43:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.7 ug/L	12/17/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/15/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1412144-001

SAMPLE INFORMATION

Sample Number: 1412144-001 Customer Sample Number: 3002837 Program: Post-LSR
Location: 1st draw 1341 WALLACH PLACE NW Type: Dist.

Collection Date: 12/8/2014 Collection Time: 8:46 Sampler: HOME OWNER Received Date and Time: 12/18/2014 8:45:05 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1412144-002

SAMPLE INFORMATION

Sample Number: 1412144-002 Customer Sample Number: 3002837 Program: Post-LSR
Location: 2nd draw 1341 WALLACH PLACE NW Type: Dist.

Collection Date: 12/8/2014 Collection Time: 8:51 Sampler: HOME OWNER Received Date and Time: 12/18/2014 8:45:05 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1412144-007

SAMPLE INFORMATION

Sample Number: 1412144-007 Customer Sample Number: 3002845 Program: Post-LSR
Location: 1st draw 1321 WALLACH PLACE NW Type: Dist.
Collection Date: 12/11/2014 Collection Time: 4:00 Sampler: HOME OWNER Received Date and Time: 12/18/2014 8:45:05 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1412144-008

SAMPLE INFORMATION

Sample Number: 1412144-008 Customer Sample Number: 3002845 Program: Post-LSR
Location: 2nd draw 1321 WALLACH PLACE NW Type: Dist.

Collection Date: 12/11/2014 Collection Time: 4:00 Sampler: HOME OWNER Received Date and Time: 12/18/2014 8:45:05 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1412163-001

SAMPLE INFORMATION

Sample Number: 1412163-001 Customer Sample Number: 3097827 Program: Post-LSR
Location: 1st draw 236 F ST NE Type: Dist.

Collection Date: 12/16/2014 Collection Time: 15:50 Sampler: HOME OWNER Received Date and Time: 12/22/2014 12:03:45 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.2 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1412163-002

SAMPLE INFORMATION

Sample Number: 1412163-002 Customer Sample Number: 3097827 Program: Post-LSR
Location: 2nd draw 236 F ST NE Type: Dist.

Collection Date: 12/16/2014 Collection Time: 15:51 Sampler: HOME OWNER Received Date and Time: 12/22/2014 12:03:45 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1412163-011

SAMPLE INFORMATION

Sample Number: 1412163-011 Customer Sample Number: 3002846 Program: Post-LSR
Location: 1st draw 1319 WALLACH PL NW Type: Dist.
Collection Date: 12/16/2014 Collection Time: 6:20 Sampler: HOME OWNER Received Date and Time: 12/22/2014 12:03:45 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.0 ug/L	1/20/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1412163-012

SAMPLE INFORMATION

Sample Number: 1412163-012 Customer Sample Number: 3002846 Program: Post-LSR
Location: 2nd draw 1319 WALLACH PL NW Type: Dist.

Collection Date: 12/16/2014 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 12/22/2014 12:03:45 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1412163-013

SAMPLE INFORMATION

Sample Number: 1412163-013 Customer Sample Number: 3036074 Program: Post-LSR
Location: 1st draw 2926 NEWARK ST NW Type: Dist.

Collection Date: 12/11/2014 Collection Time: 17:31 Sampler: HOME OWNER Received Date and Time: 12/22/2014 12:03:45 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	2.0 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1412163-014

SAMPLE INFORMATION

Sample Number: 1412163-014 Customer Sample Number: 3036074 Program: Post-LSR
Location: 2nd draw 2926 NEWARK ST NW Type: Dist.
Collection Date: 12/11/2014 Collection Time: 17:34 Sampler: HOME OWNER Received Date and Time: 12/22/2014 12:03:45 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	1/20/2015	RHoffa

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1412186-007

SAMPLE INFORMATION

Sample Number: 1412186-007 Customer Sample Number: 3002844 Program: Post-LSR
Location: 1st draw 1323 WALLACH PL NW Type: Dist.
Collection Date: 12/22/2014 Collection Time: 6:55 Sampler: HOME OWNER Received Date and Time: 12/24/2014 3:31:15 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.6 ug/L	1/20/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1412186-008

SAMPLE INFORMATION

Sample Number: 1412186-008 Customer Sample Number: 3002844 Program: Post-LSR
Location: 2nd draw 1323 WALLACH PL NW Type: Dist.

Collection Date: 12/22/2014 Collection Time: 6:59 Sampler: HOME OWNER Received Date and Time: 12/24/2014 3:31:15 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1501005-001

SAMPLE INFORMATION

Sample Number: 1501005-001 Customer Sample Number: 3017238 Program: Post-LSR
Location: 1st Draw 1329 WALLACH PL NW Type: Dist.

Collection Date: 12/27/2014 Collection Time: 10:20 Sampler: HOME OWNER Received Date and Time: 1/2/2015 11:49:42 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1501005-002

SAMPLE INFORMATION

Sample Number: 1501005-002 Customer Sample Number: 3017238 Program: Post-LSR
Location: 2nd Draw 1329 WALLACH PL NW Type: Dist.

Collection Date: 12/27/2014 Collection Time: 10:25 Sampler: HOME OWNER Received Date and Time: 1/2/2015 11:49:42 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1501026-003

SAMPLE INFORMATION

Sample Number: 1501026-003 Customer Sample Number: 3017906 Program: Post-LSR
Location: 1st Draw 78 S ST. NW Type: Dist.

Collection Date: 12/30/2014 Collection Time: 7:45 Sampler: HOME OWNER Received Date and Time: 1/6/2015 4:16:25 PM Received By: LNeal

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1501026-004

SAMPLE INFORMATION

Sample Number: 1501026-004 Customer Sample Number: 3017906 Program: Post-LSR
Location: 2nd Draw 78 S ST NW Type: Dist.

Collection Date: 12/30/2014 Collection Time: 7:45 Sampler: HOME OWNER Received Date and Time: 1/6/2015 4:16:25 PM Received By: LNeal

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1501026-007

SAMPLE INFORMATION

Sample Number: 1501026-007 Customer Sample Number: 3002838 Program: Post-LSR
Location: 1st Draw 1339 WALLACH PL NW Type: Dist.

Collection Date: 1/2/2015 Collection Time: 9:08 Sampler: HOME OWNER Received Date and Time: 1/6/2015 4:16:25 PM Received By: LNeal

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1501026-008

SAMPLE INFORMATION

Sample Number: 1501026-008 Customer Sample Number: 3002838 Program: Post-LSR
Location: 2nd Draw 1338 WALLACH PLACE NW Type: Dist.

Collection Date: 1/2/2015 Collection Time: 9:12 Sampler: HOME OWNER Received Date and Time: 1/6/2015 4:16:25 PM Received By: LNeal

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1501054-003

SAMPLE INFORMATION

Sample Number: 1501054-003 Customer Sample Number: 3002840 Program: Post-LSR
Location: 1st draw 1335B WALLACH PL NW Type: Dist.
Collection Date: 1/6/2015 Collection Time: 6:34 Sampler: HOME OWNER Received Date and Time: 1/9/2015 11:00:51 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/21/2015
Report Number: LC-W1501054-004

SAMPLE INFORMATION

Sample Number: 1501054-004 Customer Sample Number: 3002840 Program: Post-LSR
Location: 2nd draw 1335B WALLACH PL NW Type: Dist.

Collection Date: 1/6/2015 Collection Time: 6:34 Sampler: HOME OWNER Received Date and Time: 1/9/2015 11:00:51 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	1/20/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

1/21/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: LC-W1501182-001


SAMPLE INFORMATION

Sample Number: 1501182-001 Customer Sample Number: 3002826 Program: Post-LSR
Location: 1st draw 1338 WALLACH PLACE NW Type: Dist.
Collection Date: 1/17/2015 Collection Time: 7:52 Sampler: HOME OWNER Received Date and Time: 1/27/2015 4:27:13 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	2/2/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



2/5/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: LC-W1501182-002

SAMPLE INFORMATION


Sample Number: 1501182-002 Customer Sample Number: 3002826 Program: Post-LSR
Location: 2nd draw 1338 WALLACH PLACE NW Type: Dist.

Collection Date: 1/17/2015 Collection Time: 7:55 Sampler: HOME OWNER Received Date and Time: 1/27/2015 4:27:13 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	2/2/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



2/5/2015

Ü[à^!oUEP[-afABg * Sca[|af |^ Á a^ ^!

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: LC-W1501182-003

SAMPLE INFORMATION


Sample Number: 1501182-003 Customer Sample Number: 3111807 Program: Post-LSR
Location: 1st draw 1634 A ST NE Type: Dist.

Collection Date: 1/20/2015 Collection Time: 16:20 Sampler: HOME OWNER Received Date and Time: 1/27/2015 4:27:13 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.6 ug/L	2/2/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



2/5/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: LC-W1501182-004

SAMPLE INFORMATION


Sample Number: 1501182-004 Customer Sample Number: 3111807 Program: Post-LSR
Location: 2nd draw 1634 A ST NE Type: Dist.

Collection Date: 1/20/2015 Collection Time: 16:22 Sampler: HOME OWNER Received Date and Time: 1/27/2015 4:27:13 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	2/2/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



2/5/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: LC-W1501182-009


SAMPLE INFORMATION

Sample Number: 1501182-009 Customer Sample Number: 3104455 Program: Post-LSR
Location: 1st draw 1312 RANDOLPH ST NE Type: Dist.
Collection Date: 1/22/2015 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 1/27/2015 4:27:13 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.2 ug/L	2/2/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



2/5/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: LC-W1501182-010

SAMPLE INFORMATION


Sample Number: 1501182-010 Customer Sample Number: 3104455 Program: Post-LSR
Location: 2nd draw 1312 RANDOLPH ST NE Type: Dist.

Collection Date: 1/22/2015 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 1/27/2015 4:27:13 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	2/2/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



2/5/2015

Ü[à^!oUEP[-a^!Bç * Åca[|a[i^ Á a[a^!a

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: LC-W1501182-011


SAMPLE INFORMATION

Sample Number: 1501182-011 Customer Sample Number: 3010969 Program: Post-LSR
Location: 1st draw 1326 WALLACH PLACE NW Type: Dist.
Collection Date: 1/22/2015 Collection Time: 7:26 Sampler: HOME OWNER Received Date and Time: 1/27/2015 4:27:13 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	2/2/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



2/5/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: LC-W1501182-012

SAMPLE INFORMATION


Sample Number: 1501182-012 Customer Sample Number: 3010969 Program: Post-LSR
Location: 2nd draw 1326 WALLACH PLACE NW Type: Dist.

Collection Date: 1/22/2015 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 1/27/2015 4:27:13 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	2/2/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



2/5/2015

Ü[à^!oUEP[-afABg * Sca[|af |^ Á a^ a^!

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: LC-W1501200-013


SAMPLE INFORMATION

Sample Number: 1501200-013 Customer Sample Number: 3002823 Program: Post-LSR
Location: 1st draw 1332 WALLACH PL., NW Type: Dist.
Collection Date: 1/26/2015 Collection Time: 9:30 Sampler: HOME OWNER Received Date and Time: 1/30/2015 8:30:25 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.6 ug/L	2/2/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



2/5/2015

Ü[à^!oUEP[-afABg * Sca[|af |^ Á a^ a^!

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: LC-W1501200-014

SAMPLE INFORMATION


Sample Number: 1501200-014 Customer Sample Number: 3002823 Program: Post-LSR
Location: 2nd draw 1332 WALLACH PL., NW Type: Dist.

Collection Date: 1/26/2015 Collection Time: 9:31 Sampler: HOME OWNER Received Date and Time: 1/30/2015 8:30:25 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	2/2/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



2/5/2015

Ü[à^!oUEP[~-afCBg * Sca[|af |^ Á a^ a^!

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: LC-W1501200-019


SAMPLE INFORMATION

Sample Number: 1501200-019 Customer Sample Number: Program: Post-LSR
Location: 1st draw 2949 NEWARK ST., NW Type: Dist.
Collection Date: 1/27/2015 Collection Time: 2:00 Sampler: HOME OWNER Received Date and Time: 1/30/2015 8:30:25 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.8 ug/L	2/2/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



2/5/2015

Ü[à^!oUEP[-a^!Bç * Åca[|a[i^ Å a[a^!

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: LC-W1501200-020

SAMPLE INFORMATION


Sample Number: 1501200-020 Customer Sample Number: Program: Post-LSR
Location: 2nd draw 2949 NEWARK ST., NW Type: Dist.

Collection Date: 1/27/2015 Collection Time: 2:02 Sampler: HOME OWNER Received Date and Time: 1/30/2015 8:30:25 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	2/2/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



2/5/2015

Ü[à^!oUEP[~a^Bq * Sca[|a[i^ Á a[a^ ^!

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502049-007

SAMPLE INFORMATION


Sample Number: 1502049-007 Customer Sample Number: 3036070 Program: Post-LSR
Location: 1st draw 2940 NEWARK ST NW Type: Dist.

Collection Date: 1/31/2015 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 2/6/2015 9:08:42 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	2/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502049-008

SAMPLE INFORMATION


Sample Number: 1502049-008 Customer Sample Number: 3036070 Program: Post-LSR
Location: 2nd draw 2940 NEWARK ST NW Type: Dist.

Collection Date: 1/31/2015 Collection Time: 7:03 Sampler: HOME OWNER Received Date and Time: 2/6/2015 9:08:42 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	2/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502049-017

SAMPLE INFORMATION


Sample Number: 1502049-017 Customer Sample Number: 3002821 Program: Post-LSR
Location: 1st draw 1328 WALLACH PL NW Type: Dist.

Collection Date: 1/27/2015 Collection Time: 5:30 Sampler: HOME OWNER Received Date and Time: 2/6/2015 9:08:42 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	2/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502049-018

SAMPLE INFORMATION


Sample Number: 1502049-018 Customer Sample Number: 3002821 Program: Post-LSR
Location: 2nd draw 1328 WALLACH PL NW Type: Dist.

Collection Date: 1/27/2015 Collection Time: 5:33 Sampler: HOME OWNER Received Date and Time: 2/6/2015 9:08:42 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.2 ug/L	2/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502087-007

SAMPLE INFORMATION


Sample Number: 1502087-007 Customer Sample Number: 3036044 Program: Post-LSR
Location: 1st draw 3314 NEWARK ST NW Type: Dist.

Collection Date: 2/6/2015 Collection Time: 6:38 Sampler: HOME OWNER Received Date and Time: 2/11/2015 12:04:16 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.4 ug/L	2/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502087-008

SAMPLE INFORMATION


Sample Number: 1502087-008 Customer Sample Number: 3036044 Program: Post-LSR
Location: 2nd draw 3314 NEWARK ST NW Type: Dist.

Collection Date: 2/6/2015 Collection Time: 6:40 Sampler: HOME OWNER Received Date and Time: 2/11/2015 12:04:16 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.7 ug/L	2/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502087-015

SAMPLE INFORMATION


Sample Number: 1502087-015 Customer Sample Number: 3020381 Program: Post-LSR
Location: 1st draw 1433 TAYLOR ST NW Type: Dist.

Collection Date: 2/8/2015 Collection Time: 7:23 Sampler: HOME OWNER Received Date and Time: 2/11/2015 12:04:16 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	2/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502087-016

SAMPLE INFORMATION


Sample Number: 1502087-016 Customer Sample Number: 3020381 Program: Post-LSR
Location: 2nd draw 1433 TAYLOR ST NW Type: Dist.

Collection Date: 2/8/2015 Collection Time: 7:29 Sampler: HOME OWNER Received Date and Time: 2/11/2015 12:04:16 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	2/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502087-017


SAMPLE INFORMATION

Sample Number: 1502087-017 Customer Sample Number: 3002817 Program: Post-LSR
Location: 1st draw 1318 WALLACH PL NW Type: Dist.
Collection Date: 2/9/2015 Collection Time: 7:40 Sampler: HOME OWNER Received Date and Time: 2/11/2015 12:04:16 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	2/12/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: LC-W1502087-018


SAMPLE INFORMATION

Sample Number: 1502087-018 Customer Sample Number: 3002817 Program: Post-LSR
Location: 2nd draw 1318 WALLACH PL NW Type: Dist.
Collection Date: 2/9/2015 Collection Time: 7:44 Sampler: HOME OWNER Received Date and Time: 2/11/2015 12:04:16 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	2/12/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

2/23/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1502137-001

SAMPLE INFORMATION


Sample Number: 1502137-001 Customer Sample Number: 3002822 Program: Post-LSR
Location: 1st draw 1119 EAST CAPITOL ST SE Type: Dist.

Collection Date: 2/6/2015 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 2/19/2015 11:02:46 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	3/10/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1502137-002


SAMPLE INFORMATION

Sample Number: 1502137-002 Customer Sample Number: 3002822 Program: Post-LSR
Location: 2nd draw 1119 EAST CAPITOL ST SE Type: Dist.
Collection Date: 2/6/2015 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 2/19/2015 11:02:46 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1502137-003


SAMPLE INFORMATION

Sample Number: 1502137-003 Customer Sample Number: 3036094 Program: Post-LSR
Location: 1st draw 3209 HIGHLAND PL NW Type: Dist.
Collection Date: 2/9/2015 Collection Time: 7:09 Sampler: HOME OWNER Received Date and Time: 2/19/2015 11:02:46 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	3.3 ug/L	3/10/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1502137-004

SAMPLE INFORMATION


Sample Number: 1502137-004 Customer Sample Number: 3036094 Program: Post-LSR
Location: 2nd draw 3209 HIGHLAND PL NW Type: Dist.

Collection Date: 2/9/2015 Collection Time: 7:12 Sampler: HOME OWNER Received Date and Time: 2/19/2015 11:02:46 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	2.5 ug/L	3/10/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1502137-015

SAMPLE INFORMATION

Sample Number: 1502137-015 Customer Sample Number: 3057085 Program: Post-LSR
Location: 1st draw 605 TAYLOR ST NW Type: Dist.

Collection Date: 2/11/2015 Collection Time: 17:45 Sampler: HOME OWNER Received Date and Time: 2/19/2015 11:02:46 AM Received By: JCross


Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.3 ug/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1502137-016

SAMPLE INFORMATION


Sample Number: 1502137-016 Customer Sample Number: 3057085 Program: Post-LSR
Location: 2nd draw 605 TAYLOR ST NW Type: Dist.

Collection Date: 2/11/2015 Collection Time: 17:47 Sampler: HOME OWNER Received Date and Time: 2/19/2015 11:02:46 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	3/10/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1502150-001

SAMPLE INFORMATION

Sample Number: 1502150-001 Customer Sample Number: 3036037 Program: Post-LSR
Location: 1st draw 3322 NEWARK ST NW Type: Dist.

Collection Date: 2/14/2015 Collection Time: 5:55 Sampler: HOME OWNER Received Date and Time: 2/20/2015 10:51:44 AM Received By: JCross


Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.7 ug/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1502150-002

SAMPLE INFORMATION

Sample Number: 1502150-002 Customer Sample Number: 3036037 Program: Post-LSR
Location: 2nd draw 3322 NEWARK ST NW Type: Dist.

Collection Date: 2/14/2015 Collection Time: 5:58 Sampler: HOME OWNER Received Date and Time: 2/20/2015 10:51:44 AM Received By: JCross


Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.7 ug/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1502150-003


SAMPLE INFORMATION

Sample Number: 1502150-003 Customer Sample Number: 3036073 Program: Post-LSR
Location: 1st draw 2930 NEWARK ST NW Type: Dist.
Collection Date: 2/16/2015 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 2/20/2015 10:51:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.8 ug/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1502150-004


SAMPLE INFORMATION

Sample Number: 1502150-004 Customer Sample Number: 3036073 Program: Post-LSR
Location: 2nd draw 2930 NEWARK ST NW Type: Dist.

Collection Date: 2/16/2015 Collection Time: 8:05 Sampler: HOME OWNER Received Date and Time: 2/20/2015 10:51:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	3/10/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By: 
Robert P. Hoffa, Acting Laboratory Manager

3/13/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1502150-005

SAMPLE INFORMATION


Sample Number: 1502150-005 Customer Sample Number: 3036063 Program: Post-LSR
Location: 1st draw 2960 NEWARK ST NW Type: Dist.

Collection Date: 2/17/2015 Collection Time: 3:35 Sampler: HOME OWNER Received Date and Time: 2/20/2015 10:51:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.6 ug/L	3/10/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 3/13/2015
Report Number: LC-W1502150-006

SAMPLE INFORMATION


Sample Number: 1502150-006 Customer Sample Number: 3036063 Program: Post-LSR
Location: 2nd draw 2960 NEWARK ST NW Type: Dist.

Collection Date: 2/17/2015 Collection Time: 3:45 Sampler: HOME OWNER Received Date and Time: 2/20/2015 10:51:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	3/10/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 3/13/2015
Report Number: LC-W1502195-003

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502195-003 Customer Sample Number: 3075735 Program: Post-LSR
Location: 1st draw 1614 D ST NE Type: SP
Collection Date: 2/26/2015 Collection Time: 8:30 Sampler: HOME OWNER Received Date and Time: 2/27/2015 8:41:32 AM Received By: MMoore


Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 3/13/2015
Report Number: LC-W1502195-004

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


SAMPLE INFORMATION

Sample Number: 1502195-004 Customer Sample Number: 3075735 Program: Post-LSR
Location: 2nd draw 1614 D ST NE Type: SP
Collection Date: 2/26/2015 Collection Time: 8:40 Sampler: HOME OWNER Received Date and Time: 2/27/2015 8:41:32 AM Received By: MMoore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	3/10/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 3/13/2015
Report Number: LC-W1502195-007

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


SAMPLE INFORMATION

Sample Number: 1502195-007 Customer Sample Number: 3041737 Program: Post-LSR
Location: 1st draw 3451 NEWARK ST NW Type: SP
Collection Date: 2/22/2015 Collection Time: 7:20 Sampler: HOME OWNER Received Date and Time: 2/27/2015 8:41:32 AM Received By: MMoore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.5 ug/L	3/10/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 3/13/2015
Report Number: LC-W1502195-008

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


SAMPLE INFORMATION

Sample Number: 1502195-008 Customer Sample Number: 3041737 Program: Post-LSR
Location: 2nd draw 3541 NEWARK ST NW Type: SP
Collection Date: 2/22/2015 Collection Time: 7:20 Sampler: HOME OWNER Received Date and Time: 2/27/2015 8:41:32 AM Received By: MMoore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	3/10/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 3/13/2015
Report Number: LC-W1502195-009

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502195-009 Customer Sample Number: 3121814 Program: Post-LSR
Location: 1st draw 118 4TH ST NE Type: SP
Collection Date: 2/24/2015 Collection Time: 5:35 Sampler: HOME OWNER Received Date and Time: 2/27/2015 8:41:32 AM Received By: MMoore


Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 3/13/2015
Report Number: LC-W1502195-010

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502195-010 Customer Sample Number: 3121814 Program: Post-LSR
Location: 2nd draw 118 4TH ST NE Type: SP
Collection Date: 2/24/2015 Collection Time: 5:38 Sampler: HOME OWNER Received Date and Time: 2/27/2015 8:41:32 AM Received By: MMoore


Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	3/10/2015	RHoffa

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 3/13/2015
Report Number: LC-W1502195-011

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


SAMPLE INFORMATION

Sample Number: 1502195-011 Customer Sample Number: 3036048 Program: Post-LSR
Location: 1st draw 3216 NEWARK ST NW Type: SP
Collection Date: 2/23/2015 Collection Time: 18:08 Sampler: HOME OWNER Received Date and Time: 2/27/2015 8:41:32 AM Received By: MMoore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	4.2 ug/L	3/10/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 3/13/2015
Report Number: LC-W1502195-012

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION


Sample Number: 1502195-012 Customer Sample Number: 3036048 Program: Post-LSR
Location: 2nd draw 3216 NEWARK ST NW Type: SP

Collection Date: 2/23/2015 Collection Time: 18:10 Sampler: HOME OWNER Received Date and Time: 2/27/2015 8:41:32 AM Received By: MMoore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.5 ug/L	3/10/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 3/13/2015
Report Number: LC-W1502195-013

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


SAMPLE INFORMATION

Sample Number: 1502195-013 Customer Sample Number: 3029803 Program: Post-LSR
Location: 1st draw 3542 13TH ST NW, UNIT 2 Type: SP
Collection Date: 2/23/2015 Collection Time: 6:43 Sampler: HOME OWNER Received Date and Time: 2/27/2015 8:41:32 AM Received By: MMoore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	3/10/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 3/13/2015
Report Number: LC-W1502195-014

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


SAMPLE INFORMATION

Sample Number: 1502195-014 Customer Sample Number: 3029803 Program: Post-LSR
Location: 2nd draw 3542 13TH ST NW, UNIT 2 Type: SP
Collection Date: 2/23/2015 Collection Time: 6:45 Sampler: HOME OWNER Received Date and Time: 2/27/2015 8:41:32 AM Received By: MMoore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	3/10/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

3/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503131-001

SAMPLE INFORMATION


Sample Number: 1503131-001 Customer Sample Number: 3021923 Program: Post-LSR
Location: 1st draw 4615 16TH ST NW Type: Dist.

Collection Date: 3/10/2015 Collection Time: 20:20 Sampler: HOME OWNER Received Date and Time: 3/18/2015 10:39:11 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.2 ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503131-002

SAMPLE INFORMATION


Sample Number: 1503131-002 Customer Sample Number: 3021923 Program: Post-LSR
Location: 2nd draw 4615 16TH ST NW Type: Dist.

Collection Date: 3/10/2015 Collection Time: 20:20 Sampler: HOME OWNER Received Date and Time: 3/18/2015 10:39:11 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	3/27/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503131-005

SAMPLE INFORMATION


Sample Number: 1503131-005 Customer Sample Number: 3101368 Program: Post-LSR
Location: 1st draw 1801 E ST NE Type: Dist.

Collection Date: 3/11/2015 Collection Time: 5:35 Sampler: HOME OWNER Received Date and Time: 3/18/2015 10:39:11 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503131-006

SAMPLE INFORMATION


Sample Number: 1503131-006 Customer Sample Number: 3101368 Program: Post-LSR
Location: 2nd draw 1801 E ST NE Type: Dist.

Collection Date: 3/11/2015 Collection Time: 5:37 Sampler: HOME OWNER Received Date and Time: 3/18/2015 10:39:11 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503131-007

SAMPLE INFORMATION


Sample Number: 1503131-007 Customer Sample Number: 3036057 Program: Post-LSR
Location: 1st draw 3042 NEWARK ST NW Type: Dist.

Collection Date: 3/11/2015 Collection Time: 7:25 Sampler: HOME OWNER Received Date and Time: 3/18/2015 10:39:11 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503131-008

SAMPLE INFORMATION

Sample Number: 1503131-008 Customer Sample Number: 3036057 Program: Post-LSR
Location: 2nd draw 3042 NEWARK ST NW Type: Dist.

Collection Date: 3/11/2015 Collection Time: 7:35 Sampler: HOME OWNER Received Date and Time: 3/18/2015 10:39:11 AM Received By: JCross


Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	3/27/2015	RHoffa

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503131-009

SAMPLE INFORMATION


Sample Number: 1503131-009 Customer Sample Number: 3036126 Program: Post-LSR
Location: 1st draw 3319 NEWARK ST NW Type: Dist.

Collection Date: 3/12/2015 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 3/18/2015 10:39:11 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	3/27/2014	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503131-010

SAMPLE INFORMATION


Sample Number: 1503131-010 Customer Sample Number: 3036126 Program: Post-LSR
Location: 2nd draw 3319 NEWARK ST NW Type: Dist.

Collection Date: 3/12/2015 Collection Time: 7:33 Sampler: HOME OWNER Received Date and Time: 3/18/2015 10:39:11 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503131-013

SAMPLE INFORMATION


Sample Number: 1503131-013 Customer Sample Number: 3128073 Program: Post-LSR
Location: 1st draw 728 4TH ST. NE Type: Dist.

Collection Date: 3/12/2015 Collection Time: 10:30 Sampler: HOME OWNER Received Date and Time: 3/18/2015 10:39:11 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503131-014

SAMPLE INFORMATION

Sample Number: 1503131-014 Customer Sample Number: 3128073 Program: Post-LSR
Location: 2nd draw 728 4TH ST. NE Type: Dist.

Collection Date: 3/12/2015 Collection Time: 10:35 Sampler: HOME OWNER Received Date and Time: 3/18/2015 10:39:11 AM Received By: JCross


Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	3/27/2015	RHoffa

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503131-015

SAMPLE INFORMATION


Sample Number: 1503131-015 Customer Sample Number: 3036116 Program: Post-LSR
Location: 1st draw 3125 NEWARK ST NW Type: Dist.

Collection Date: 3/15/2015 Collection Time: 6:50 Sampler: HOME OWNER Received Date and Time: 3/18/2015 10:39:11 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503131-016

SAMPLE INFORMATION


Sample Number: 1503131-016 Customer Sample Number: 3036116 Program: Post-LSR
Location: 2nd draw 3125 NEWARK ST NW Type: Dist.

Collection Date: 3/15/2015 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 3/18/2015 10:39:11 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503155-007

SAMPLE INFORMATION


Sample Number: 1503155-007 Customer Sample Number: 3036088 Program: Post-LSR
Location: 1st draw 3035 NEWARK ST NW Type: Dist.

Collection Date: 3/10/2015 Collection Time: 6:15 Sampler: HOME OWNER Received Date and Time: 3/20/2015 9:48:28 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.0 ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503155-008

SAMPLE INFORMATION


Sample Number: 1503155-008 Customer Sample Number: 3036088 Program: Post-LSR
Location: 2nd draw 3035 NEWARK ST NW Type: Dist.

Collection Date: 3/10/2015 Collection Time: 6:20 Sampler: HOME OWNER Received Date and Time: 3/20/2015 9:48:28 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503155-009

SAMPLE INFORMATION


Sample Number: 1503155-009 Customer Sample Number: 3000575 Program: Post-LSR
Location: 1st draw 2150 NEWPORT PL NW Type: Dist.

Collection Date: 3/14/2015 Collection Time: 7:05 Sampler: HOME OWNER Received Date and Time: 3/20/2015 9:48:28 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	2.2 ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503155-010

SAMPLE INFORMATION


Sample Number: 1503155-010 Customer Sample Number: 3000575 Program: Post-LSR
Location: 2nd draw 2150 NEWPORT PL NW Type: Dist.

Collection Date: 3/14/2015 Collection Time: 7:10 Sampler: HOME OWNER Received Date and Time: 3/20/2015 9:48:28 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.2 ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503155-013

SAMPLE INFORMATION


Sample Number: 1503155-013 Customer Sample Number: 3000544 Program: Post-LSR
Location: 1st draw 2147 NEWPORT PL NW Type: Dist.

Collection Date: 3/16/2015 Collection Time: 8:35 Sampler: HOME OWNER Received Date and Time: 3/20/2015 9:48:28 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	3.9 ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503155-014

SAMPLE INFORMATION


Sample Number: 1503155-014 Customer Sample Number: 3000544 Program: Post-LSR
Location: 2nd draw 2147 NEWPORT PL NW Type: Dist.

Collection Date: 3/16/2015 Collection Time: 8:37 Sampler: HOME OWNER Received Date and Time: 3/20/2015 9:48:28 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	7.4 ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503178-005

SAMPLE INFORMATION


Sample Number: 1503178-005 Customer Sample Number: 3000543 Program: Post-LSR
Location: 1st Draw 2149 NEWPORT PL NW Type: Dist.

Collection Date: 3/18/2015 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 3/24/2015 9:38:54 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	5.6 ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/2/2015
Report Number: LC-W1503178-006

SAMPLE INFORMATION


Sample Number: 1503178-006 Customer Sample Number: 3000543 Program: Post-LSR
Location: 2nd Draw 2149 NEWPORT PL NW Type: Dist.

Collection Date: 3/18/2015 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 3/24/2015 9:38:54 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	10.0 ug/L	3/27/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/2/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503204-007

SAMPLE INFORMATION


Sample Number: 1503204-007 Customer Sample Number: 3111680 Program: Post-LSR
Location: 1st draw 323 7TH ST NE Type: Dist.

Collection Date: 3/24/2015 Collection Time: 6:34 Sampler: HOMEOWNER Received Date and Time: 3/27/2015 9:13:34 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.3 ug/L	4/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503204-008

SAMPLE INFORMATION


Sample Number: 1503204-008 Customer Sample Number: 3111680 Program: Post-LSR
Location: 2nd draw 323 7TH ST NE Type: Dist.

Collection Date: 3/24/2015 Collection Time: 6:40 Sampler: HOMEOWNER Received Date and Time: 3/27/2015 9:13:34 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	4/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503204-009

SAMPLE INFORMATION


Sample Number: 1503204-009 Customer Sample Number: 3036117 Program: Post-LSR
Location: 1st draw 3127 NEWARK ST NW Type: Dist.

Collection Date: 3/23/2015 Collection Time: 7:00 Sampler: HOMEOWNER Received Date and Time: 3/27/2015 9:13:34 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	4/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503204-010

SAMPLE INFORMATION


Sample Number: 1503204-010 Customer Sample Number: 3036117 Program: Post-LSR
Location: 2nd draw 3127 NEWARK ST NW Type: Dist.

Collection Date: 3/23/2015 Collection Time: 7:00 Sampler: HOMEOWNER Received Date and Time: 3/27/2015 9:13:34 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	4/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503204-011

SAMPLE INFORMATION


Sample Number: 1503204-011 Customer Sample Number: 3000542 Program: Post-LSR
Location: 1st draw 2151 NEWPORT PL NW Type: Dist.

Collection Date: 3/23/2015 Collection Time: 6:40 Sampler: HOMEOWNER Received Date and Time: 3/27/2015 9:13:34 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	2.0 ug/L	4/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503204-012

SAMPLE INFORMATION


Sample Number: 1503204-012 Customer Sample Number: 3000542 Program: Post-LSR
Location: 2nd draw 2151 NEWPORT PL NW Type: Dist.

Collection Date: 3/23/2015 Collection Time: 6:45 Sampler: HOMEOWNER Received Date and Time: 3/27/2015 9:13:34 AM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.0 ug/L	4/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503224-005

SAMPLE INFORMATION


Sample Number: 1503224-005 Customer Sample Number: 3122849 Program: Post-LSR
Location: 1st draw 917 K ST NE Type: Dist.

Collection Date: 3/25/2015 Collection Time: 16:32 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:54:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	4/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1503224-006

SAMPLE INFORMATION


Sample Number: 1503224-006 Customer Sample Number: 3122849 Program: Post-LSR
Location: 2nd draw 917 K ST NE Type: Dist.

Collection Date: 3/25/2015 Collection Time: 16:35 Sampler: HOME OWNER Received Date and Time: 3/31/2015 10:54:03 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.7 ug/L	4/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1504001-003

SAMPLE INFORMATION


Sample Number: 1504001-003 Customer Sample Number: 3075735 Program: Post-LSR
Location: 1st Draw 1614 D ST. SE Type: Dist.

Collection Date: 3/27/2015 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 4/1/2015 9:47:31 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	3.6 ug/L	4/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/6/2015
Report Number: LC-W1504001-004

SAMPLE INFORMATION

Sample Number: 1504001-004 Customer Sample Number: 3075735 Program: Post-LSR
Location: 2nd Draw 1614 D ST. SE Type: Dist.

Collection Date: 3/27/2015 Collection Time: 6:32 Sampler: HOME OWNER Received Date and Time: 4/1/2015 9:47:31 AM Received By: LGallimore


Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	4/3/2015	RHoffa

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/6/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: LC-W1504026-001

SAMPLE INFORMATION


Sample Number: 1504026-001 Customer Sample Number: 3041004 Program: Post-LSR
Location: 1st Draw 3738 ABERMARLE ST. NW Type: Dist.

Collection Date: 3/31/2015 Collection Time: 6:32 Sampler: HOME OWNER Received Date and Time: 4/3/2015 10:49:02 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.8 ug/L	4/6/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa * Laboratory Manager

4/24/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: LC-W1504026-002


SAMPLE INFORMATION

Sample Number: 1504026-002 Customer Sample Number: 3041004 Program: Post-LSR
Location: 2nd Draw 3738 ABERMARLE ST. NW Type: Dist.

Collection Date: 3/31/2015 Collection Time: 6:37 Sampler: HOME OWNER Received Date and Time: 4/3/2015 10:49:02 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	4/6/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:  4/24/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 5/13/2015
Report Number: LC-W1504065-013

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1504065-013 Customer Sample Number: 3047976 Program: Post-LSR
Location: 1st draw 1338 GERANIUM ST NW Type: Dist.
Collection Date: 4/1/2015 Collection Time: 19:15 Sampler: HOME OWNER Received Date and Time: 4/8/2015 1:56:49 PM Received By: MMoore


Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	5/5/2015	RHoffa

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 5/13/2015
Report Number: LC-W1504065-014

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1504065-014 Customer Sample Number: 3047976 Program: Post-LSR
Location: 2nd draw 1338 GERANIUM ST NW Type: Dist.
Collection Date: 4/1/2015 Collection Time: 19:17 Sampler: HOME OWNER Received Date and Time: 4/8/2015 1:56:49 PM Received By: MMoore


Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	5/5/2015	RHoffa

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 5/13/2015
Report Number: LC-W1504065-015

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1504065-015 Customer Sample Number: 3008195 Program: Post-LSR
Location: 1st draw 1534 28TH ST NW Type: Dist.
Collection Date: 4/3/2015 Collection Time: 9:15 Sampler: HOME OWNER Received Date and Time: 4/8/2015 1:56:49 PM Received By: MMoore


Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	5/5/2015	RHoffa

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 5/13/2015
Report Number: LC-W1504065-016

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


SAMPLE INFORMATION

Sample Number: 1504065-016 Customer Sample Number: 3008195 Program: Post-LSR
Location: 2nd draw 1534 28TH ST NW Type: Dist.
Collection Date: 4/3/2015 Collection Time: 9:16 Sampler: HOME OWNER Received Date and Time: 4/8/2015 1:56:49 PM Received By: MMoore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504111-007


SAMPLE INFORMATION

Sample Number: 1504111-007 Customer Sample Number: 3073521 Program: Post-LSR
Location: 1st draw 735 10TH ST SE Type: Dist.
Collection Date: 4/8/2015 Collection Time: 7:45 Sampler: HOME OWNER Received Date and Time: 4/15/2015 10:47:35 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.7 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504111-008

SAMPLE INFORMATION


Sample Number: 1504111-008 Customer Sample Number: 3073521 Program: Post-LSR
Location: 2nd draw 735 10TH ST SE Type: Dist.

Collection Date: 4/8/2015 Collection Time: 7:45 Sampler: HOME OWNER Received Date and Time: 4/15/2015 10:47:35 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.5 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504132-001


SAMPLE INFORMATION

Sample Number: 1504132-001 Customer Sample Number: 3000535 Program: Post-LSR
Location: 1st draw 2134 O ST NW, BSMT Type: Dist.
Collection Date: 4/13/2015 Collection Time: 17:32 Sampler: HOME OWNER Received Date and Time: 4/17/2015 12:34:26 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.1 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504132-002

SAMPLE INFORMATION


Sample Number: 1504132-002 Customer Sample Number: 3000535 Program: Post-LSR
Location: 2nd draw 2134 O ST NW, BSMT Type: Dist.

Collection Date: 4/13/2015 Collection Time: 17:36 Sampler: HOME OWNER Received Date and Time: 4/17/2015 12:34:26 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	4.6 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504132-007


SAMPLE INFORMATION

Sample Number: 1504132-007 Customer Sample Number: 3041681 Program: Post-LSR
Location: 1st draw 3704 RENO RD NW Type: Dist.
Collection Date: 4/15/2015 Collection Time: 8:16 Sampler: HOME OWNER Received Date and Time: 4/17/2015 12:34:26 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1504132-008

SAMPLE INFORMATION


Sample Number: 1504132-008 Customer Sample Number: 3041681 Program: Post-LSR
Location: 2nd draw 3704 RENO RD NW Type: Dist.

Collection Date: 4/15/2015 Collection Time: 8:17 Sampler: HOME OWNER Received Date and Time: 4/17/2015 12:34:26 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.7 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1505005-001

SAMPLE INFORMATION


Sample Number: 1505005-001 Customer Sample Number: 3036052 Program: Post-LSR
Location: 1st draw 3208 NEWARK ST NW Type: Dist.

Collection Date: 4/28/2015 Collection Time: 20:00 Sampler: HOME OWNER Received Date and Time: 5/1/2015 12:32:38 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.7 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1505005-002

SAMPLE INFORMATION

Sample Number: 1505005-002 Customer Sample Number: 3036052 Program: Post-LSR
Location: 2nd draw 3208 NEWARK ST NW Type: Dist.

Collection Date: 4/28/2015 Collection Time: 20:00 Sampler: HOME OWNER Received Date and Time: 5/1/2015 12:32:38 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.7 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:

Robert P. Hoffa
Robert P. Hoffa, Laboratory Manager

5/13/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1505005-003

SAMPLE INFORMATION


Sample Number: 1505005-003 Customer Sample Number: 3098377 Program: Post-LSR
Location: 1st draw 1133 ABBEY PL NE Type: Dist.

Collection Date: 4/27/2015 Collection Time: 19:30 Sampler: HOME OWNER Received Date and Time: 5/1/2015 12:32:38 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.2 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1505005-004

SAMPLE INFORMATION


Sample Number: 1505005-004 Customer Sample Number: 3098377 Program: Post-LSR
Location: 2nd draw 1133 ABBEY PL NE Type: Dist.

Collection Date: 4/27/2015 Collection Time: 19:34 Sampler: HOME OWNER Received Date and Time: 5/1/2015 12:32:38 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.7 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1505005-007

SAMPLE INFORMATION


Sample Number: 1505005-007 Customer Sample Number: 3032025 Program: Post-LSR
Location: 1st draw 743 NEWTON PL NW Type: Dist.

Collection Date: 4/26/2015 Collection Time: 15:07 Sampler: HOME OWNER Received Date and Time: 5/1/2015 12:32:38 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.4 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1505005-008

SAMPLE INFORMATION


Sample Number: 1505005-008 Customer Sample Number: 3032025 Program: Post-LSR
Location: 2nd draw 743 NEWTON PL NW Type: Dist.

Collection Date: 4/26/2015 Collection Time: 15:08 Sampler: HOME OWNER Received Date and Time: 5/1/2015 12:32:38 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	3.8 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1505005-011

SAMPLE INFORMATION


Sample Number: 1505005-011 Customer Sample Number: 3103981 Program: Post-LSR
Location: 1st draw 1244 GIRARD ST., NE Type: Dist.

Collection Date: 4/26/2015 Collection Time: 12:00 Sampler: HOME OWNER Received Date and Time: 5/1/2015 12:32:38 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	19.7 ug/L	5/5/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: LC-W1505005-012

SAMPLE INFORMATION

Sample Number: 1505005-012 Customer Sample Number: 3103981 Program: Post-LSR
Location: 2nd draw 1244 GIRARD ST., NE Type: Dist.

Collection Date: 4/26/2015 Collection Time: 12:05 Sampler: HOME OWNER Received Date and Time: 5/1/2015 12:32:38 PM Received By: JCross


Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	1.8 ug/L	5/5/2015	RHoffa

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/13/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505056-007

Reported revised on 6/25/15 by MC.
For Lab Sample Numbers 1505056-007 & 1505056-008, the sample address was changed
from 4919 13th St NE to 4419 13th St NE as indicated on the chain-of-custody form.

SAMPLE INFORMATION


Sample Number: 1505056-007 Customer Sample Number: 3104676 Program: Post-LSR
Location: 1st Draw 4419 13TH ST NE Type: Dist.

Collection Date: 5/5/2015 Collection Time: 18:48 Sampler: HOME OWNER Received Date and Time: 5/8/2015 10:39:13 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	5/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/22/2015
Report Number: LC-W1505056-008

Reported revised on 6/25/15 by MC.
For Lab Sample Numbers 1505056-007 & 1505056-008, the sample address was changed
from 4919 13th St NE to 4419 13th St NE as indicated on the chain-of-custody form.

SAMPLE INFORMATION


Sample Number: 1505056-008 Customer Sample Number: 3104676 Program: Post-LSR
Location: 2nd Draw 4419 13TH ST NE Type: Dist.

Collection Date: 5/5/2015 Collection Time: 18:51 Sampler: HOME OWNER Received Date and Time: 5/8/2015 10:39:13 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	5/12/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

5/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: LC-W1505159-003

SAMPLE INFORMATION


Sample Number: 1505159-003 Customer Sample Number: 3000557 Program: Post-LSR
Location: 1st Draw 2119 NEWPORT PL NW Type: Dist.

Collection Date: 5/17/2015 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 5/22/2015 11:54:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.5 ug/L	6/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: LC-W1505159-004

SAMPLE INFORMATION


Sample Number: 1505159-004 Customer Sample Number: 3000557 Program: Post-LSR
Location: 2nd Draw 2119 NEWPORT PL NW Type: Dist.

Collection Date: 5/17/2015 Collection Time: 6:03 Sampler: HOME OWNER Received Date and Time: 5/22/2015 11:54:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.4 ug/L	6/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: LC-W1506009-007

SAMPLE INFORMATION


Sample Number: 1506009-007 Customer Sample Number: 3021727 Program: Post-LSR
Location: 1st draw 4440 KANSAS AVE NW Type: Dist.

Collection Date: 5/19/2015 Collection Time: 23:00 Sampler: HOME OWNER Received Date and Time: 6/1/2015 11:45:53 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	6/3/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: LC-W1506009-008

SAMPLE INFORMATION

Sample Number: 1506009-008 Customer Sample Number: 3021727 Program: Post-LSR
Location: 2nd draw 4440 KANSAS AVE NW Type: Dist.

Collection Date: 5/19/2015 Collection Time: 23:15 Sampler: HOME OWNER Received Date and Time: 6/1/2015 11:45:53 AM Received By: JCross


Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	6/3/2015	RHoffa

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/22/2015
Report Number: LC-W1506053-005

SAMPLE INFORMATION


Sample Number: 1506053-005 Customer Sample Number: 3125529 Program: Post-LSR
Location: 1st draw 170 T ST NE Type: Dist.

Collection Date: 5/29/2015 Collection Time: 21:00 Sampler: HOME OWNER Received Date and Time: 6/8/2015 12:43:27 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	2.2 ug/L	6/9/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/22/2015
Report Number: LC-W1506053-006

SAMPLE INFORMATION


Sample Number: 1506053-006 Customer Sample Number: 3125529 Program: Post-LSR
Location: 2nd draw 170 T ST NE Type: Dist.

Collection Date: 5/29/2015 Collection Time: 21:00 Sampler: HOME OWNER Received Date and Time: 6/8/2015 12:43:27 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	4.3 ug/L	6/9/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/22/2015
Report Number: LC-W1506053-009

SAMPLE INFORMATION


Sample Number: 1506053-009 Customer Sample Number: 3021437 Program: Post-LSR
Location: 1st draw 4333 3RD ST NW Type: Dist.

Collection Date: 6/1/2015 Collection Time: 6:10 Sampler: HOME OWNER Received Date and Time: 6/8/2015 12:43:27 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.8 ug/L	6/9/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/22/2015
Report Number: LC-W1506053-010

SAMPLE INFORMATION


Sample Number: 1506053-010 Customer Sample Number: 3021437 Program: Post-LSR
Location: 2nd draw 4333 3RD ST NW Type: Dist.

Collection Date: 6/1/2015 Collection Time: 6:15 Sampler: HOME OWNER Received Date and Time: 6/8/2015 12:43:27 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	6/9/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/22/2015
Report Number: LC-W1506053-011

SAMPLE INFORMATION

Sample Number: 1506053-011 Customer Sample Number: 3000574 Program: Post-LSR
Location: 1st draw 2148 NEWPORT PL NW Type: Dist.
Collection Date: 6/1/2015 Collection Time: 16:30 Sampler: HOME OWNER Received Date and Time: 6/8/2015 12:43:27 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	2.1 ug/L	6/9/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By: 
Robert P. Hoffa, Laboratory Manager

6/22/2015
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/22/2015
Report Number: LC-W1506053-012

SAMPLE INFORMATION


Sample Number: 1506053-012 Customer Sample Number: 3000574 Program: Post-LSR
Location: 2nd draw 2148 NEWPORT PL NW Type: Dist.

Collection Date: 6/1/2015 Collection Time: 16:35 Sampler: HOME OWNER Received Date and Time: 6/8/2015 12:43:27 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.3 ug/L	6/9/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/22/2015
Report Number: LC-W1506053-015

SAMPLE INFORMATION


Sample Number: 1506053-015 Customer Sample Number: 3021723 Program: Post-LSR
Location: 1st draw 822 ALLISON ST NW Type: Dist.

Collection Date: 6/4/2015 Collection Time: 6:53 Sampler: HOME OWNER Received Date and Time: 6/8/2015 12:43:27 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.2 ug/L	6/9/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/22/2015
Report Number: LC-W1506053-016

SAMPLE INFORMATION


Sample Number: 1506053-016 Customer Sample Number: 3021723 Program: Post-LSR
Location: 2nd draw 822 ALLISON ST NW Type: Dist.

Collection Date: 6/4/2015 Collection Time: 6:54 Sampler: HOME OWNER Received Date and Time: 6/8/2015 12:43:27 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	6/9/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/22/2015
Report Number: LC-W1506093-003

SAMPLE INFORMATION

Sample Number: 1506093-003 Customer Sample Number: 3086654 Program: Post-LSR
Location: 1st draw 308 S. CAROLINA AVE SE Type: Dist.
Collection Date: 6/10/2015 Collection Time: 6:39 Sampler: HOME OWNER Received Date and Time: 6/12/2015 9:23:30 AM Received By: JCross


Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	24.1 ug/L	6/18/2015	RHoffa

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/22/2015
Report Number: LC-W1506093-004

SAMPLE INFORMATION


Sample Number: 1506093-004 Customer Sample Number: 3086654 Program: Post-LSR
Location: 2nd draw 308 S. CAROLINA AVE SE Type: Dist.

Collection Date: 6/10/2015 Collection Time: 6:42 Sampler: HOME OWNER Received Date and Time: 6/12/2015 9:23:30 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	3.6 ug/L	6/18/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/22/2015
Report Number: LC-W1506122-003


SAMPLE INFORMATION

Sample Number: 1506122-003 Customer Sample Number: 3000564 Program: Post-LSR
Location: 1st Draw 2128 NEWPORT PL NW Type: Dist.
Collection Date: 6/11/2015 Collection Time: 9:30 Sampler: HOME OWNER Received Date and Time: 6/17/2015 9:16:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	4.3 ug/L	6/18/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/22/2015
Report Number: LC-W1506122-004


SAMPLE INFORMATION

Sample Number: 1506122-004 Customer Sample Number: 3000564 Program: Post-LSR
Location: 2nd Draw 2128 NEWPORT PL NW Type: Dist.
Collection Date: 6/11/2015 Collection Time: 9:35 Sampler: HOME OWNER Received Date and Time: 6/17/2015 9:16:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	4.7 ug/L	6/18/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/22/2015
Report Number: LC-W1506122-009


SAMPLE INFORMATION

Sample Number: 1506122-009 Customer Sample Number: 3001185 Program: Post-LSR
Location: 1st Draw 2102 17TH ST NW Type: Dist.
Collection Date: 6/12/2015 Collection Time: 8:57 Sampler: HOME OWNER Received Date and Time: 6/17/2015 9:16:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	0.7 ug/L	6/18/2015	RHoffa

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/22/2015
Report Number: LC-W1506122-010

SAMPLE INFORMATION


Sample Number: 1506122-010 Customer Sample Number: 3001185 Program: Post-LSR
Location: 2nd Draw 2102 17TH ST NW Type: Dist.

Collection Date: 6/12/2015 Collection Time: 8:59 Sampler: HOME OWNER Received Date and Time: 6/17/2015 9:16:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	6/18/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/22/2015
Report Number: LC-W1506122-011

SAMPLE INFORMATION


Sample Number: 1506122-011 Customer Sample Number: 3032830 Program: Post-LSR
Location: 1st Draw 2819 13TH ST. NW Type: Dist.

Collection Date: 6/15/2015 Collection Time: 6:40 Sampler: HOME OWNER Received Date and Time: 6/17/2015 9:16:28 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	6/18/2015	RHoffa

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/22/2015

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/22/2015
Report Number: LC-W1506122-012

SAMPLE INFORMATION

Sample Number: 1506122-012 Customer Sample Number: 3032830 Program: Post-LSR
Location: 2nd Draw 2819 13TH ST. NW Type: Dist.

Collection Date: 6/15/2015 Collection Time: 6:45 Sampler: HOME OWNER Received Date and Time: 6/17/2015 9:16:28 AM Received By: LGallimore


Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	ug/L	0.2 ug/L	ND ug/L	6/18/2015	RHoffa

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/22/2015

Date

Lead Profile Information

DC Water surveys the plumbing of customers' homes and collects consecutive samples to identify the sources of lead. The homes are those that had elevated lead from previous samples collected for compliance monitoring or from other programs.

This attached sample analysis data contains personal information of DC Water's customers, such as names and home addresses, the disclosure of which would constitute a violation of D.C. Code § 2-534(a)(2) and 5 U.S.C. § 552(b)(6). If EPA is requested to produce the sampling analysis data in whole or in part, in order to maintain confidentiality, the personal information must be redacted from the documents produced.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-001

SAMPLE INFORMATION

Sample Number: 1412088-001 Customer Sample Number:
Location: 01 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/10/2014 7:15 CW/DVC 12/10/2014 11:23:05 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-002

SAMPLE INFORMATION

Sample Number: 1412088-002 Customer Sample Number:
Location: 01F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-003

SAMPLE INFORMATION

Sample Number: 1412088-003 Customer Sample Number:
Location: 02 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/10/2014 7:15 CW/DVC 12/10/2014 11:23:05 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/16/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-004

SAMPLE INFORMATION

Sample Number: 1412088-004 Customer Sample Number:
Location: 02F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	14.2 ug/L	12/17/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	12/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	12/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	22.9 ug/L	12/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	14.8 ug/L	12/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	12/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-004

SAMPLE INFORMATION

Sample Number: 1412088-004 Customer Sample Number:
Location: 02F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/16/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-005

SAMPLE INFORMATION

Sample Number: 1412088-005 Customer Sample Number:
Location: 03 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	17.3 ug/L	12/17/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.0 ug/L	12/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	12/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	19.2 ug/L	12/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.29 ug/L	12/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	12/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-005

SAMPLE INFORMATION

Sample Number: 1412088-005 Customer Sample Number:
Location: 03 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/10/2014 7:15 CW/DVC 12/10/2014 11:23:05 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-006

SAMPLE INFORMATION

Sample Number: 1412088-006 Customer Sample Number:
Location: 03F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	12.7 ug/L	12/17/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	12/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	12/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	17.3 ug/L	12/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	8.23 ug/L	12/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	12/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-006

SAMPLE INFORMATION

Sample Number: 1412088-006 Customer Sample Number:
Location: 03F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-007

SAMPLE INFORMATION

Sample Number: 1412088-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	17.9 ug/L	12/17/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.0 ug/L	12/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	12/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	19.5 ug/L	12/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.66 ug/L	12/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	12/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-007

SAMPLE INFORMATION

Sample Number: 1412088-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/10/2014 7:15 CW/DVC 12/10/2014 11:23:05 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-008

SAMPLE INFORMATION

Sample Number: 1412088-008 Customer Sample Number:
Location: 04F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/10/2014 7:15 CW/DVC 12/10/2014 11:23:05 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/16/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-009

SAMPLE INFORMATION

Sample Number: 1412088-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	19.6 ug/L	12/17/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	12/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	12/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	29.5 ug/L	12/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	8.14 ug/L	12/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	12/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-009

SAMPLE INFORMATION

Sample Number: 1412088-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/10/2014 7:15 CW/DVC 12/10/2014 11:23:05 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-010

SAMPLE INFORMATION

Sample Number: 1412088-010 Customer Sample Number:
Location: 05F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-011

SAMPLE INFORMATION

Sample Number: 1412088-011 Customer Sample Number:
Location: 06 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	20.1 ug/L	12/17/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.0 ug/L	12/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	12/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	25.2 ug/L	12/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.14 ug/L	12/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	12/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-011

SAMPLE INFORMATION

Sample Number: 1412088-011 Customer Sample Number:
Location: 06 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-012

SAMPLE INFORMATION

Sample Number: 1412088-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/16/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-013

SAMPLE INFORMATION

Sample Number: 1412088-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	19.7 ug/L	12/17/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.14 ug/L	12/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	22.9 ug/L	12/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	21.4 ug/L	12/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.81 ug/L	12/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.43 ug/L	12/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-013

SAMPLE INFORMATION

Sample Number: 1412088-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/10/2014 7:15 CW/DVC 12/10/2014 11:23:05 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-014

SAMPLE INFORMATION

Sample Number: 1412088-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	16.0 ug/L	12/17/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.12 ug/L	12/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	12/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	18.9 ug/L	12/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.12 ug/L	12/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	12/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-014

SAMPLE INFORMATION

Sample Number: 1412088-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-015

SAMPLE INFORMATION

Sample Number: 1412088-015 Customer Sample Number:
Location: 08 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	19.4 ug/L	12/17/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	12/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	10.2 ug/L	12/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	19.7 ug/L	12/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.02 ug/L	12/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.02 ug/L	12/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-015

SAMPLE INFORMATION

Sample Number: 1412088-015 Customer Sample Number:
Location: 08 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/10/2014 7:15 CW/DVC 12/10/2014 11:23:05 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-016

SAMPLE INFORMATION

Sample Number: 1412088-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	14.3 ug/L	12/17/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	12/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	12/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	18.4 ug/L	12/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.26 ug/L	12/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	12/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-016

SAMPLE INFORMATION

Sample Number: 1412088-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/16/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-017

SAMPLE INFORMATION

Sample Number: 1412088-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	17.8 ug/L	12/17/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	12/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	12/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	19.5 ug/L	12/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.66 ug/L	12/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.05 ug/L	12/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-017

SAMPLE INFORMATION

Sample Number: 1412088-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/10/2014 7:15 CW/DVC 12/10/2014 11:23:05 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/16/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-018

SAMPLE INFORMATION

Sample Number: 1412088-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	14.0 ug/L	12/17/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	12/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	12/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	17.6 ug/L	12/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.18 ug/L	12/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.02 ug/L	12/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-018

SAMPLE INFORMATION

Sample Number: 1412088-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-019

SAMPLE INFORMATION

Sample Number: 1412088-019 Customer Sample Number:
Location: 10 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	17.3 ug/L	12/17/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	12/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	12/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	19.1 ug/L	12/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.32 ug/L	12/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.99 ug/L	12/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-019

SAMPLE INFORMATION

Sample Number: 1412088-019 Customer Sample Number:
Location: 10 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/10/2014 7:15 CW/DVC 12/10/2014 11:23:05 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-020

SAMPLE INFORMATION

Sample Number: 1412088-020 Customer Sample Number:
Location: 10F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-021

SAMPLE INFORMATION

Sample Number: 1412088-021 Customer Sample Number:
Location: 11 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	20.1 ug/L	12/17/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	12/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	27.5 ug/L	12/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	20.1 ug/L	12/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.54 ug/L	12/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.01 ug/L	12/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-021

SAMPLE INFORMATION

Sample Number: 1412088-021 Customer Sample Number:
Location: 11 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/10/2014 7:15 CW/DVC 12/10/2014 11:23:05 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/16/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-022

SAMPLE INFORMATION

Sample Number: 1412088-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	12.7 ug/L	12/17/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	12/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	12/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	18.2 ug/L	12/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.40 ug/L	12/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.09 ug/L	12/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-022

SAMPLE INFORMATION

Sample Number: 1412088-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-023

SAMPLE INFORMATION

Sample Number: 1412088-023 Customer Sample Number:
Location: 12 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-024

SAMPLE INFORMATION

Sample Number: 1412088-024 Customer Sample Number:
Location: 12F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-025

SAMPLE INFORMATION

Sample Number: 1412088-025 Customer Sample Number:
Location: 13 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/10/2014 7:15 CW/DVC 12/10/2014 11:23:05 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-026

SAMPLE INFORMATION

Sample Number: 1412088-026 Customer Sample Number:
Location: 13F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	13.2 ug/L	12/17/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	12/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	12/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	21.0 ug/L	12/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.35 ug/L	12/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	12/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-026

SAMPLE INFORMATION

Sample Number: 1412088-026 Customer Sample Number:
Location: 13F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-027

SAMPLE INFORMATION

Sample Number: 1412088-027 Customer Sample Number:
Location: 14 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	17.8 ug/L	12/17/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	12/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	12/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	21.8 ug/L	12/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.02 ug/L	12/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.91 ug/L	12/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-027

SAMPLE INFORMATION

Sample Number: 1412088-027 Customer Sample Number:
Location: 14 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/10/2014 7:15 CW/DVC 12/10/2014 11:23:05 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-028

SAMPLE INFORMATION

Sample Number: 1412088-028
Location: 14F
LPR 3211 NEWARK ST NW FILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 12/10/2014
Collection Time: 7:15
Sampler: CW/DVC
Received Date and Time: 12/10/2014 11:23:05 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/16/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-029

SAMPLE INFORMATION

Sample Number: 1412088-029 Customer Sample Number:
Location: 15 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	16.5 ug/L	12/17/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	12/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	12/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	23.2 ug/L	12/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.68 ug/L	12/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.52 ug/L	12/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-029

SAMPLE INFORMATION

Sample Number: 1412088-029 Customer Sample Number:
Location: 15 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/10/2014 7:15 CW/DVC 12/10/2014 11:23:05 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-030

SAMPLE INFORMATION

Sample Number: 1412088-030 Customer Sample Number:
Location: 15F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-031

SAMPLE INFORMATION

Sample Number: 1412088-031
Location: 16
LPR 3211 NEWARK ST NW UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 12/10/2014
Collection Time: 7:15
Sampler: CW/DVC
Received Date and Time: 12/10/2014 11:23:05 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	16.4 ug/L	12/17/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	12/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	12/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	54.4 ug/L	12/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.88 ug/L	12/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.74 ug/L	12/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-031

SAMPLE INFORMATION

Sample Number: 1412088-031 Customer Sample Number:
Location: 16 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/10/2014 7:15 CW/DVC 12/10/2014 11:23:05 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-032

SAMPLE INFORMATION

Sample Number: 1412088-032 Customer Sample Number:
Location: 16F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/16/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-033

SAMPLE INFORMATION

Sample Number: 1412088-033 Customer Sample Number:
Location: 17 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/10/2014 7:15 CW/DVC 12/10/2014 11:23:05 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/16/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-034

SAMPLE INFORMATION

Sample Number: 1412088-034
Location: 17F
LPR 3211 NEWARK ST NW FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	10.5 ug/L	12/17/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	12/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	12/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	99.4 ug/L	12/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.90 ug/L	12/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.36 ug/L	12/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-034

SAMPLE INFORMATION

Sample Number: 1412088-034 Customer Sample Number:
Location: 17F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-035

SAMPLE INFORMATION

Sample Number: 1412088-035 Customer Sample Number:
Location: 18 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	14.4 ug/L	12/17/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	12/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	12/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	152 ug/L	12/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.25 ug/L	12/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.96 ug/L	12/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-035

SAMPLE INFORMATION

Sample Number: 1412088-035 Customer Sample Number:
Location: 18 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/10/2014 7:15 CW/DVC 12/10/2014 11:23:05 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-036

SAMPLE INFORMATION

Sample Number: 1412088-036
Location: 18F
LPR 3211 NEWARK ST NW FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/16/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-037

SAMPLE INFORMATION

Sample Number: 1412088-037 Customer Sample Number:
Location: 19 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	14.3 ug/L	12/17/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	12/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	12/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	154 ug/L	12/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.18 ug/L	12/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.65 ug/L	12/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-037

SAMPLE INFORMATION

Sample Number: 1412088-037 Customer Sample Number:
Location: 19 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/10/2014 7:15 CW/DVC 12/10/2014 11:23:05 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-038

SAMPLE INFORMATION

Sample Number: 1412088-038 Customer Sample Number:
Location: 19F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-039

SAMPLE INFORMATION

Sample Number: 1412088-039 Customer Sample Number:
Location: 20 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	13.9 ug/L	12/17/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	12/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	12/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	144 ug/L	12/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.22 ug/L	12/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.0 ug/L	12/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-039

SAMPLE INFORMATION

Sample Number: 1412088-039 Customer Sample Number:
Location: 20 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/10/2014 7:15 CW/DVC 12/10/2014 11:23:05 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-040

SAMPLE INFORMATION

Sample Number: 1412088-040 Customer Sample Number:
Location: 20F Type: Dist.
LPR 3211 NEWARK ST NW FILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/16/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-041

SAMPLE INFORMATION

Sample Number: 1412088-041 Customer Sample Number:
Location: H1 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	16.0 ug/L	12/17/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.0 ug/L	12/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	12/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	130 ug/L	12/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	6.27 ug/L	12/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	12/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-041

SAMPLE INFORMATION

Sample Number: 1412088-041 Customer Sample Number:
Location: H1 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/10/2014 7:15 CW/DVC 12/10/2014 11:23:05 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-042

SAMPLE INFORMATION

Sample Number: 1412088-042 Customer Sample Number:
Location: H2 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-043

SAMPLE INFORMATION

Sample Number: 1412088-043 Customer Sample Number:
Location: H3 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	16.6 ug/L	12/17/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.19 ug/L	12/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	19.8 ug/L	12/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	81.3 ug/L	12/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.20 ug/L	12/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	12/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-043

SAMPLE INFORMATION

Sample Number: 1412088-043 Customer Sample Number:
Location: H3 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/10/2014 7:15 CW/DVC 12/10/2014 11:23:05 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-044

SAMPLE INFORMATION

Sample Number: 1412088-044 Customer Sample Number:
Location: H4 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	17.5 ug/L	12/17/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.32 ug/L	12/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	26.9 ug/L	12/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	57.2 ug/L	12/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.10 ug/L	12/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	12/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-044

SAMPLE INFORMATION

Sample Number: 1412088-044 Customer Sample Number:
Location: H4 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/10/2014 7:15 CW/DVC 12/10/2014 11:23:05 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-045

SAMPLE INFORMATION

Sample Number: 1412088-045 Customer Sample Number:
Location: H5 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	24.4 ug/L	12/17/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.33 ug/L	12/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	28.8 ug/L	12/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	37.7 ug/L	12/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.06 ug/L	12/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	12/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-045

SAMPLE INFORMATION

Sample Number: 1412088-045 Customer Sample Number:
Location: H5 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/10/2014 7:15 CW/DVC 12/10/2014 11:23:05 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-046

SAMPLE INFORMATION

Sample Number: 1412088-046 Customer Sample Number:
Location: H6 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	18.9 ug/L	12/17/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.34 ug/L	12/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	29.6 ug/L	12/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	32.9 ug/L	12/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.39 ug/L	12/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	12/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-046

SAMPLE INFORMATION

Sample Number: 1412088-046 Customer Sample Number:
Location: H6 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/10/2014 7:15 CW/DVC 12/10/2014 11:23:05 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-047

SAMPLE INFORMATION

Sample Number: 1412088-047 Customer Sample Number:
Location: H7 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/10/2014 7:15 CW/DVC 12/10/2014 11:23:05 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/16/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-048

SAMPLE INFORMATION

Sample Number: 1412088-048 Customer Sample Number:
Location: H8 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-049

SAMPLE INFORMATION

Sample Number: 1412088-049 Customer Sample Number:
Location: H9 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	19.2 ug/L	12/17/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.45 ug/L	12/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	34.9 ug/L	12/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	21.3 ug/L	12/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.88 ug/L	12/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	12/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-049

SAMPLE INFORMATION

Sample Number: 1412088-049 Customer Sample Number:
Location: H9 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-050

SAMPLE INFORMATION

Sample Number: 1412088-050
Customer Sample Number:
Location: H10
Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 12/10/2014
Collection Time: 7:15
Sampler: CW/DVC
Received Date and Time: 12/10/2014 11:23:05 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	18.8 ug/L	12/17/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.38 ug/L	12/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	33.9 ug/L	12/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	17.0 ug/L	12/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.36 ug/L	12/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	12/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-050

SAMPLE INFORMATION

Sample Number: 1412088-050 Customer Sample Number:
Location: H10 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/10/2014 7:15 CW/DVC 12/10/2014 11:23:05 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-051

SAMPLE INFORMATION

Sample Number: 1412088-051 Customer Sample Number:
Location: H11 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	18.8 ug/L	12/17/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.43 ug/L	12/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	33.7 ug/L	12/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	17.1 ug/L	12/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.86 ug/L	12/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	12/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-051

SAMPLE INFORMATION

Sample Number: 1412088-051 Customer Sample Number:
Location: H11 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-052

SAMPLE INFORMATION

Sample Number: 1412088-052 Customer Sample Number:
Location: H12 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/10/2014 7:15 CW/DVC 12/10/2014 11:23:05 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-053

SAMPLE INFORMATION

Sample Number: 1412088-053 Customer Sample Number:
Location: H13 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED

Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	18.5 ug/L	12/17/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.42 ug/L	12/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	33.5 ug/L	12/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	15.9 ug/L	12/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.78 ug/L	12/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	12/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-053

SAMPLE INFORMATION

Sample Number: 1412088-053 Customer Sample Number:
Location: H13 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/10/2014 7:15 CW/DVC 12/10/2014 11:23:05 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-054

SAMPLE INFORMATION

Sample Number: 1412088-054 Customer Sample Number:
Location: H14 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/10/2014 7:15 CW/DVC 12/10/2014 11:23:05 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-055

SAMPLE INFORMATION

Sample Number: 1412088-055 Customer Sample Number:
Location: H15 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-056

SAMPLE INFORMATION

Sample Number: 1412088-056 Customer Sample Number:
Location: H16 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/10/2014 7:15 CW/DVC 12/10/2014 11:23:05 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-057

SAMPLE INFORMATION

Sample Number: 1412088-057 Customer Sample Number:
Location: H17 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	17.3 ug/L	12/17/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.39 ug/L	12/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	31.4 ug/L	12/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	14.8 ug/L	12/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.07 ug/L	12/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	12/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-057

SAMPLE INFORMATION

Sample Number: 1412088-057 Customer Sample Number:
Location: H17 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-058

SAMPLE INFORMATION

Sample Number: 1412088-058
Location: H18
LPR 3211 NEWARK ST NW UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 12/10/2014
Collection Time: 7:15
Sampler: CW/DVC
Received Date and Time: 12/10/2014 11:23:05 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	17.6 ug/L	12/17/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.40 ug/L	12/17/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	32.5 ug/L	12/17/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	19.7 ug/L	12/17/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.04 ug/L	12/17/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	12/17/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-058

SAMPLE INFORMATION

Sample Number: 1412088-058 Customer Sample Number:
Location: H18 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/10/2014 7:15 CW/DVC 12/10/2014 11:23:05 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-059

SAMPLE INFORMATION

Sample Number: 1412088-059 Customer Sample Number:
Location: H19 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/10/2014 7:15 CW/DVC 12/10/2014 11:23:05 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/16/2015
Report Number: M- W1412088-060

SAMPLE INFORMATION

Sample Number: 1412088-060 Customer Sample Number:
Location: H20 Type: Dist.
LPR 3211 NEWARK ST NW UNFILTERED
Collection Date: 12/10/2014 Collection Time: 7:15 Sampler: CW/DVC Received Date and Time: 12/10/2014 11:23:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/16/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-001

SAMPLE INFORMATION

Sample Number: 1412185-001 Customer Sample Number:
Location: 1 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 12/24/2014 Collection Time: 8:00 Sampler: IC/CW/DC Received Date and Time: 12/24/2014 3:23:57 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	49.4 ug/L	1/20/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.72 ug/L	1/20/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	25.3 ug/L	1/20/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.76 ug/L	1/20/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	41.8 ug/L	1/20/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.03 ug/L	1/20/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-001

SAMPLE INFORMATION

Sample Number: 1412185-001 Customer Sample Number:
Location: 1 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-002

SAMPLE INFORMATION

Sample Number: 1412185-002 Customer Sample Number:
Location: 1F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: 12/24/2014 Collection Time: 8:00 Sampler: IC/CW/DC Received Date and Time: 12/24/2014 3:23:57 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	13.8 ug/L	1/20/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.36 ug/L	1/20/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	1/20/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.41 ug/L	1/20/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	35.7 ug/L	1/20/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	1/20/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-002

SAMPLE INFORMATION

Sample Number: 1412185-002 Customer Sample Number:
Location: 1F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-003

SAMPLE INFORMATION

Sample Number: 1412185-003
Location: 02
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 12/24/2014 Collection Time: 8:00 Sampler: IC/CW/DC Received Date and Time: 12/24/2014 3:23:57 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	18.3 ug/L	1/20/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.62 ug/L	1/20/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	22.1 ug/L	1/20/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.82 ug/L	1/20/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.20 ug/L	1/20/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.15 ug/L	1/20/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-003

SAMPLE INFORMATION

Sample Number: 1412185-003 Customer Sample Number:
Location: 02 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-004

SAMPLE INFORMATION

Sample Number: 1412185-004 Customer Sample Number:
Location: 02F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-005

SAMPLE INFORMATION

Sample Number: 1412185-005 Customer Sample Number:
Location: 03 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-006

SAMPLE INFORMATION

Sample Number: 1412185-006 Customer Sample Number:
Location: 03F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: 12/24/2014 Collection Time: 8:00 Sampler: IC/CW/DC Received Date and Time: 12/24/2014 3:23:57 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-007

SAMPLE INFORMATION

Sample Number: 1412185-007
Location: 04
LPR 3815 5TH ST NW UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 12/24/2014
Collection Time: 8:00
Sampler: IC/CW/DC
Received Date and Time: 12/24/2014 3:23:57 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	31.7 ug/L	1/20/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.52 ug/L	1/20/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	23.8 ug/L	1/20/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.77 ug/L	1/20/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	28.0 ug/L	1/20/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.51 ug/L	1/20/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-007

SAMPLE INFORMATION

Sample Number: 1412185-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-008

SAMPLE INFORMATION

Sample Number: 1412185-008 Customer Sample Number:
Location: 04F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-009

SAMPLE INFORMATION

Sample Number: 1412185-009
Location: 05
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 12/24/2014 Collection Time: 8:00 Sampler: IC/CW/DC Received Date and Time: 12/24/2014 3:23:57 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	38.9 ug/L	1/20/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.79 ug/L	1/20/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	21.4 ug/L	1/20/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.85 ug/L	1/20/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	45.4 ug/L	1/20/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.60 ug/L	1/20/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-009

SAMPLE INFORMATION

Sample Number: 1412185-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-010

SAMPLE INFORMATION

Sample Number: 1412185-010 Customer Sample Number:
Location: 05F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-011

SAMPLE INFORMATION

Sample Number: 1412185-011
Location: 06
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 12/24/2014 Collection Time: 8:00 Sampler: IC/CW/DC Received Date and Time: 12/24/2014 3:23:57 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	20.4 ug/L	1/20/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.65 ug/L	1/20/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	21.1 ug/L	1/20/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.13 ug/L	1/20/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	8.87 ug/L	1/20/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.54 ug/L	1/20/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-011

SAMPLE INFORMATION

Sample Number: 1412185-011 Customer Sample Number:
Location: 06 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-012

SAMPLE INFORMATION

Sample Number: 1412185-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-013

SAMPLE INFORMATION

Sample Number: 1412185-013
Location: 07
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 12/24/2014 Collection Time: 8:00 Sampler: IC/CW/DC Received Date and Time: 12/24/2014 3:23:57 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	18.1 ug/L	1/20/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.93 ug/L	1/20/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	19.6 ug/L	1/20/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.38 ug/L	1/20/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	19.7 ug/L	1/20/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.35 ug/L	1/20/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-013

SAMPLE INFORMATION

Sample Number: 1412185-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-014

SAMPLE INFORMATION

Sample Number: 1412185-014
Location: 07F
LPR 3815 5TH ST NW FILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 12/24/2014
Collection Time: 8:00
Sampler: IC/CW/DC
Received Date and Time: 12/24/2014 3:23:57 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	10.2 ug/L	1/20/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.65 ug/L	1/20/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	1/20/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	6.58 ug/L	1/20/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	18.4 ug/L	1/20/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.30 ug/L	1/20/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-014

SAMPLE INFORMATION

Sample Number: 1412185-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-015

SAMPLE INFORMATION

Sample Number: 1412185-015
Location: 08
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 12/24/2014 Collection Time: 8:00 Sampler: IC/CW/DC Received Date and Time: 12/24/2014 3:23:57 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	16.6 ug/L	1/20/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.68 ug/L	1/20/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	17.2 ug/L	1/20/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.77 ug/L	1/20/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	15.7 ug/L	1/20/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.73 ug/L	1/20/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-015

SAMPLE INFORMATION

Sample Number: 1412185-015 Customer Sample Number:
Location: 08 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-016

SAMPLE INFORMATION

Sample Number: 1412185-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: 12/24/2014 Collection Time: 8:00 Sampler: IC/CW/DC Received Date and Time: 12/24/2014 3:23:57 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-017

SAMPLE INFORMATION

Sample Number: 1412185-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-018

SAMPLE INFORMATION

Sample Number: 1412185-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-019

SAMPLE INFORMATION

Sample Number: 1412185-019
Location: 10
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 12/24/2014 Collection Time: 8:00 Sampler: IC/CW/DC Received Date and Time: 12/24/2014 3:23:57 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	15.6 ug/L	1/20/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	1/20/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	15.9 ug/L	1/20/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.79 ug/L	1/20/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.30 ug/L	1/20/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.71 ug/L	1/20/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-019

SAMPLE INFORMATION

Sample Number: 1412185-019 Customer Sample Number:
Location: 10 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-020

SAMPLE INFORMATION

Sample Number: 1412185-020 Customer Sample Number:
Location: 10F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-021

SAMPLE INFORMATION

Sample Number: 1412185-021 Customer Sample Number:
Location: 11 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 12/24/2014 Collection Time: 8:00 Sampler: IC/CW/DC Received Date and Time: 12/24/2014 3:23:57 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	15.9 ug/L	1/20/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	1/20/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	16.1 ug/L	1/20/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.03 ug/L	1/20/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.11 ug/L	1/20/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.71 ug/L	1/20/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-021

SAMPLE INFORMATION

Sample Number: 1412185-021
Location: 11
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 12/24/2014 Collection Time: 8:00 Sampler: IC/CW/DC Received Date and Time: 12/24/2014 3:23:57 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-022

SAMPLE INFORMATION

Sample Number: 1412185-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: 12/24/2014 Collection Time: 8:00 Sampler: IC/CW/DC Received Date and Time: 12/24/2014 3:23:57 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-023

SAMPLE INFORMATION

Sample Number: 1412185-023 Customer Sample Number:
Location: 12 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-024

SAMPLE INFORMATION

Sample Number: 1412185-024 Customer Sample Number:
Location: 12F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-025

SAMPLE INFORMATION

Sample Number: 1412185-025
Location: 13
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 12/24/2014 Collection Time: 8:00 Sampler: IC/CW/DC Received Date and Time: 12/24/2014 3:23:57 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	14.8 ug/L	1/20/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.66 ug/L	1/20/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	20.3 ug/L	1/20/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.80 ug/L	1/20/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.90 ug/L	1/20/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.26 ug/L	1/20/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-025

SAMPLE INFORMATION

Sample Number: 1412185-025 Customer Sample Number:
Location: 13 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-026

SAMPLE INFORMATION

Sample Number: 1412185-026 Customer Sample Number:
Location: 13F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: 12/24/2014 Collection Time: 8:00 Sampler: IC/CW/DC Received Date and Time: 12/24/2014 3:23:57 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	1/20/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.54 ug/L	1/20/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	1/20/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.67 ug/L	1/20/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.27 ug/L	1/20/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.57 ug/L	1/20/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-026

SAMPLE INFORMATION

Sample Number: 1412185-026 Customer Sample Number:
Location: 13F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-027

SAMPLE INFORMATION

Sample Number: 1412185-027
Location: 14
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 12/24/2014 Collection Time: 8:00 Sampler: IC/CW/DC Received Date and Time: 12/24/2014 3:23:57 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	16.2 ug/L	1/20/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.72 ug/L	1/20/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	25.6 ug/L	1/20/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.77 ug/L	1/20/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.19 ug/L	1/20/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.13 ug/L	1/20/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-027

SAMPLE INFORMATION

Sample Number: 1412185-027 Customer Sample Number:
Location: 14 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-028

SAMPLE INFORMATION

Sample Number: 1412185-028 Customer Sample Number:
Location: 14F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: 12/24/2014 Collection Time: 8:00 Sampler: IC/CW/DC Received Date and Time: 12/24/2014 3:23:57 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	1/20/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.64 ug/L	1/20/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	1/20/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.72 ug/L	1/20/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.80 ug/L	1/20/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	1/20/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-028

SAMPLE INFORMATION

Sample Number: 1412185-028 Customer Sample Number:
Location: 14F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-029

SAMPLE INFORMATION

Sample Number: 1412185-029 Customer Sample Number:
Location: 15 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-030

SAMPLE INFORMATION

Sample Number: 1412185-030 Customer Sample Number:
Location: 15F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-031

SAMPLE INFORMATION

Sample Number: 1412185-031 Customer Sample Number:
Location: H1 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-032

SAMPLE INFORMATION

Sample Number: 1412185-032 Customer Sample Number:
Location: H2 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-033

SAMPLE INFORMATION

Sample Number: 1412185-033 Customer Sample Number:
Location: H3 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 12/24/2014 Collection Time: 8:00 Sampler: IC/CW/DC Received Date and Time: 12/24/2014 3:23:57 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	30.1 ug/L	1/20/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.17 ug/L	1/20/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	33.2 ug/L	1/20/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.79 ug/L	1/20/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.14 ug/L	1/20/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	15.6 ug/L	1/20/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-033

SAMPLE INFORMATION

Sample Number: 1412185-033 Customer Sample Number:
Location: H3 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-034

SAMPLE INFORMATION

Sample Number: 1412185-034 Customer Sample Number:
Location: H4 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 12/24/2014 Collection Time: 8:00 Sampler: IC/CW/DC Received Date and Time: 12/24/2014 3:23:57 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	25.8 ug/L	1/20/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.12 ug/L	1/20/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	33.3 ug/L	1/20/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.60 ug/L	1/20/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.63 ug/L	1/20/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	14.6 ug/L	1/20/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-034

SAMPLE INFORMATION

Sample Number: 1412185-034 Customer Sample Number:
Location: H4 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-035

SAMPLE INFORMATION

Sample Number: 1412185-035 Customer Sample Number:
Location: H5 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 12/24/2014 Collection Time: 8:00 Sampler: IC/CW/DC Received Date and Time: 12/24/2014 3:23:57 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	30.4 ug/L	1/20/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.04 ug/L	1/20/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	31.7 ug/L	1/20/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.74 ug/L	1/20/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	19.9 ug/L	1/20/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	10.1 ug/L	1/20/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-035

SAMPLE INFORMATION

Sample Number: 1412185-035 Customer Sample Number:
Location: H5 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-036

SAMPLE INFORMATION

Sample Number: 1412185-036 Customer Sample Number:
Location: H6 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 12/24/2014 Collection Time: 8:00 Sampler: IC/CW/DC Received Date and Time: 12/24/2014 3:23:57 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	22.1 ug/L	1/20/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.88 ug/L	1/20/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	30.2 ug/L	1/20/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.36 ug/L	1/20/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.20 ug/L	1/20/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.81 ug/L	1/20/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-036

SAMPLE INFORMATION

Sample Number: 1412185-036 Customer Sample Number:
Location: H6 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-037

SAMPLE INFORMATION

Sample Number: 1412185-037 Customer Sample Number:
Location: H7 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 12/24/2014 Collection Time: 8:00 Sampler: IC/CW/DC Received Date and Time: 12/24/2014 3:23:57 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	22.3 ug/L	1/20/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.97 ug/L	1/20/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	35.4 ug/L	1/20/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.74 ug/L	1/20/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.70 ug/L	1/20/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	6.35 ug/L	1/20/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-037

SAMPLE INFORMATION

Sample Number: 1412185-037 Customer Sample Number:
Location: H7 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-038

SAMPLE INFORMATION

Sample Number: 1412185-038
Location: H8
LPR 3815 5TH ST NW UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 12/24/2014
Collection Time: 8:00
Sampler: IC/CW/DC
Received Date and Time: 12/24/2014 3:23:57 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	20.3 ug/L	1/20/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.74 ug/L	1/20/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	30.1 ug/L	1/20/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.74 ug/L	1/20/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.36 ug/L	1/20/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.20 ug/L	1/20/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-038

SAMPLE INFORMATION

Sample Number: 1412185-038 Customer Sample Number:
Location: H8 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-039

SAMPLE INFORMATION

Sample Number: 1412185-039 Customer Sample Number:
Location: H9 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 12/24/2014 Collection Time: 8:00 Sampler: IC/CW/DC Received Date and Time: 12/24/2014 3:23:57 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	20.7 ug/L	1/20/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.88 ug/L	1/20/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	34.5 ug/L	1/20/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.54 ug/L	1/20/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.69 ug/L	1/20/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.30 ug/L	1/20/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-039

SAMPLE INFORMATION

Sample Number: 1412185-039 Customer Sample Number:
Location: H9 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-040

SAMPLE INFORMATION

Sample Number: 1412185-040
Location: H10
LPR 3815 5TH ST NW UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 12/24/2014
Collection Time: 8:00
Sampler: IC/CW/DC
Received Date and Time: 12/24/2014 3:23:57 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	20.9 ug/L	1/20/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.72 ug/L	1/20/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	30.9 ug/L	1/20/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.22 ug/L	1/20/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.18 ug/L	1/20/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.81 ug/L	1/20/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-040

SAMPLE INFORMATION

Sample Number: 1412185-040 Customer Sample Number:
Location: H10 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-041

SAMPLE INFORMATION

Sample Number: 1412185-041 Customer Sample Number:
Location: H11 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 12/24/2014 Collection Time: 8:00 Sampler: IC/CW/DC Received Date and Time: 12/24/2014 3:23:57 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	20.9 ug/L	1/20/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.75 ug/L	1/20/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	33.3 ug/L	1/20/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.22 ug/L	1/20/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.91 ug/L	1/20/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.12 ug/L	1/20/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-041

SAMPLE INFORMATION

Sample Number: 1412185-041 Customer Sample Number:
Location: H11 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-042

SAMPLE INFORMATION

Sample Number: 1412185-042 Customer Sample Number:
Location: H12 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 12/24/2014 Collection Time: 8:00 Sampler: IC/CW/DC Received Date and Time: 12/24/2014 3:23:57 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	20.3 ug/L	1/20/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.70 ug/L	1/20/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	32.4 ug/L	1/20/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.64 ug/L	1/20/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.87 ug/L	1/20/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.00 ug/L	1/20/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-042

SAMPLE INFORMATION

Sample Number: 1412185-042 Customer Sample Number:
Location: H12 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

1/22/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-043

SAMPLE INFORMATION

Sample Number: 1412185-043 Customer Sample Number:
Location: H13 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 12/24/2014 Collection Time: 8:00 Sampler: IC/CW/DC Received Date and Time: 12/24/2014 3:23:57 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	20.9 ug/L	1/20/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.73 ug/L	1/20/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	36.1 ug/L	1/20/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.83 ug/L	1/20/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.03 ug/L	1/20/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.56 ug/L	1/20/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-043

SAMPLE INFORMATION

Sample Number: 1412185-043 Customer Sample Number:
Location: H13 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-044

SAMPLE INFORMATION

Sample Number: 1412185-044 Customer Sample Number:
Location: H14 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-045

SAMPLE INFORMATION

Sample Number: 1412185-045 Customer Sample Number:
Location: H15 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 12/24/2014 Collection Time: 8:00 Sampler: IC/CW/DC Received Date and Time: 12/24/2014 3:23:57 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	19.9 ug/L	1/20/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.69 ug/L	1/20/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	29.5 ug/L	1/20/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.13 ug/L	1/20/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.92 ug/L	1/20/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.68 ug/L	1/20/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/22/2015
Report Number: M- W1412185-045

SAMPLE INFORMATION

Sample Number: 1412185-045 Customer Sample Number:
Location: H15 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
12/24/2014 8:00 IC/CW/DC 12/24/2014 3:23:57 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  1/22/2015
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-001


SAMPLE INFORMATION

Sample Number: 1501205-001
Location: 1
LPR 326 12TH ST SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/27/2015 Collection Time: 14:00 Sampler: CW Received Date and Time: 1/30/2015 12:29:24 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/5/2015
Robert P. Hoffa * Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-002

SAMPLE INFORMATION

Sample Number: 1501205-002
Location: 1F
LPR 326 12TH ST SE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/27/2015 Collection Time: 14:00 Sampler: CW Received Date and Time: 1/30/2015 12:29:24 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/5/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

**US Army Corps of Engineers
Washington Aqueduct Laboratory**

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-003

SAMPLE INFORMATION

Sample Number: 1501205-003 Customer Sample Number:
Location: 02 Type: Dist.
LPR 326 12TH ST SE (UNFILTERED)
Collection Date: 1/27/2015 Collection Time: 14:00 Sampler: CW Received Date and Time: 1/30/2015 12:29:24 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/5/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-004

SAMPLE INFORMATION

Sample Number: 1501205-004 Customer Sample Number:
Location: 02F Type: Dist.
LPR 326 12TH ST SE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/27/2015 14:00 CW 1/30/2015 12:29:24 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/5/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-005

SAMPLE INFORMATION

Sample Number: 1501205-005
Location: 03
LPR 326 12TH ST SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/27/2015 Collection Time: 14:00 Sampler: CW Received Date and Time: 1/30/2015 12:29:24 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/5/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-006

SAMPLE INFORMATION

Sample Number: 1501205-006
Location: 03F
LPR 326 12TH ST SE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/27/2015 Collection Time: 14:00 Sampler: CW Received Date and Time: 1/30/2015 12:29:24 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/5/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-007

SAMPLE INFORMATION

Sample Number: 1501205-007
Location: 04
LPR 326 12TH ST SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/27/2015 Collection Time: 14:00 Sampler: CW Received Date and Time: 1/30/2015 12:29:24 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/5/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-008

SAMPLE INFORMATION

Sample Number: 1501205-008 Customer Sample Number:
Location: 04F Type: Dist.
LPR 326 12TH ST SE (FILTERED)
Collection Date: 1/27/2015 Collection Time: 14:00 Sampler: CW Received Date and Time: 1/30/2015 12:29:24 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.0 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.75 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	11.3 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.2 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-008

SAMPLE INFORMATION

Sample Number: 1501205-008 Customer Sample Number:
Location: 04F Type: Dist.
LPR 326 12TH ST SE (FILTERED)
Collection Date: 1/27/2015 Collection Time: 14:00 Sampler: CW Received Date and Time: 1/30/2015 12:29:24 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/5/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-009

SAMPLE INFORMATION

Sample Number: 1501205-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 326 12TH ST SE (UNFILTERED)
Collection Date: 1/27/2015 Collection Time: 14:00 Sampler: CW Received Date and Time: 1/30/2015 12:29:24 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	11.5 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.15 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	34.2 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.38 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.77 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-009

SAMPLE INFORMATION

Sample Number: 1501205-009
Location: 05
LPR 326 12TH ST SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/27/2015 Collection Time: 14:00 Sampler: CW Received Date and Time: 1/30/2015 12:29:24 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/5/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-010

SAMPLE INFORMATION

Sample Number: 1501205-010
Location: 05F
LPR 326 12TH ST SE (FILTERED)
Customer Sample Number:
Type: Dist.
Collection Date: 1/27/2015
Collection Time: 14:00
Sampler: CW
Received Date and Time: 1/30/2015 12:29:24 PM
Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.15 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.78 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	10.5 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.2 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-010

SAMPLE INFORMATION

Sample Number: 1501205-010
Location: 05F
LPR 326 12TH ST SE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/27/2015 Collection Time: 14:00 Sampler: CW Received Date and Time: 1/30/2015 12:29:24 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/5/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-011

SAMPLE INFORMATION

Sample Number: 1501205-011
Location: 06
LPR 326 12TH ST SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/27/2015 Collection Time: 14:00 Sampler: CW Received Date and Time: 1/30/2015 12:29:24 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/5/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-012

SAMPLE INFORMATION

Sample Number: 1501205-012
Location: 06F
LPR 326 12TH ST SE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/27/2015 Collection Time: 14:00 Sampler: CW Received Date and Time: 1/30/2015 12:29:24 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/5/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-013

SAMPLE INFORMATION

Sample Number: 1501205-013
Location: 07
LPR 326 12TH ST SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/27/2015 Collection Time: 14:00 Sampler: CW Received Date and Time: 1/30/2015 12:29:24 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	11.0 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.22 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	39.8 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	6.62 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.27 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.79 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-013

SAMPLE INFORMATION

Sample Number: 1501205-013
Location: 07
LPR 326 12TH ST SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/27/2015 Collection Time: 14:00 Sampler: CW Received Date and Time: 1/30/2015 12:29:24 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/5/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-014

SAMPLE INFORMATION

Sample Number: 1501205-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 326 12TH ST SE (FILTERED)
Collection Date: 1/27/2015 Collection Time: 14:00 Sampler: CW Received Date and Time: 1/30/2015 12:29:24 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.18 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.96 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.36 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.21 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-014

SAMPLE INFORMATION

Sample Number: 1501205-014
Location: 07F
LPR 326 12TH ST SE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/27/2015 Collection Time: 14:00 Sampler: CW Received Date and Time: 1/30/2015 12:29:24 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/5/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-015

SAMPLE INFORMATION

Sample Number: 1501205-015
Location: 08
LPR 326 12TH ST SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/27/2015 Collection Time: 14:00 Sampler: CW Received Date and Time: 1/30/2015 12:29:24 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	10.7 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.54 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	37.3 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.78 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.97 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.50 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-015

SAMPLE INFORMATION

Sample Number: 1501205-015
Location: 08
LPR 326 12TH ST SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/27/2015 Collection Time: 14:00 Sampler: CW Received Date and Time: 1/30/2015 12:29:24 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/5/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-016

SAMPLE INFORMATION

Sample Number: 1501205-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 326 12TH ST SE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/27/2015 14:00 CW 1/30/2015 12:29:24 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/5/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-017

SAMPLE INFORMATION

Sample Number: 1501205-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 326 12TH ST SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/27/2015 14:00 CW 1/30/2015 12:29:24 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/5/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-018

SAMPLE INFORMATION

Sample Number: 1501205-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 326 12TH ST SE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/27/2015 14:00 CW 1/30/2015 12:29:24 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/5/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-019

SAMPLE INFORMATION

Sample Number: 1501205-019 Customer Sample Number:
Location: 10 Type: Dist.
LPR 326 12TH ST SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/27/2015 14:00 CW 1/30/2015 12:29:24 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/5/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-020

SAMPLE INFORMATION

Sample Number: 1501205-020 Customer Sample Number:
Location: 10F Type: Dist.
LPR 326 12TH ST SE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/27/2015 14:00 CW 1/30/2015 12:29:24 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/5/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-021

SAMPLE INFORMATION

Sample Number: 1501205-021 Customer Sample Number:
Location: 11 Type: Dist.
LPR 326 12TH ST SE (UNFILTERED)
Collection Date: 1/27/2015 Collection Time: 14:00 Sampler: CW Received Date and Time: 1/30/2015 12:29:24 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	10.7 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.68 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	34.2 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.88 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.13 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.96 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-021

SAMPLE INFORMATION

Sample Number: 1501205-021 Customer Sample Number:
Location: 11 Type: Dist.
LPR 326 12TH ST SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/27/2015 14:00 CW 1/30/2015 12:29:24 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/5/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-022

SAMPLE INFORMATION

Sample Number: 1501205-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 326 12TH ST SE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/27/2015 14:00 CW 1/30/2015 12:29:24 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/5/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-023

SAMPLE INFORMATION

Sample Number: 1501205-023
Location: 12
LPR 326 12TH ST SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/27/2015 Collection Time: 14:00 Sampler: CW Received Date and Time: 1/30/2015 12:29:24 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	11.2 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.60 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	31.4 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.49 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.81 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.23 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-023

SAMPLE INFORMATION

Sample Number: 1501205-023 Customer Sample Number:
Location: 12 Type: Dist.
LPR 326 12TH ST SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/27/2015 14:00 CW 1/30/2015 12:29:24 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/5/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-024

SAMPLE INFORMATION

Sample Number: 1501205-024 Customer Sample Number:
Location: 12F Type: Dist.
LPR 326 12TH ST SE (FILTERED)
Collection Date: 1/27/2015 Collection Time: 14:00 Sampler: CW Received Date and Time: 1/30/2015 12:29:24 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.56 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	13.7 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.28 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.72 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-024

SAMPLE INFORMATION

Sample Number: 1501205-024 Customer Sample Number:
Location: 12F Type: Dist.
LPR 326 12TH ST SE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/27/2015 14:00 CW 1/30/2015 12:29:24 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/5/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-025

SAMPLE INFORMATION

Sample Number: 1501205-025 Customer Sample Number:
Location: H1 Type: Dist.
LPR 326 12TH ST SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/27/2015 14:00 CW 1/30/2015 12:29:24 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/5/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-026

SAMPLE INFORMATION

Sample Number: 1501205-026 Customer Sample Number:
Location: H2 Type: Dist.
LPR 326 12TH ST SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/27/2015 14:00 CW 1/30/2015 12:29:24 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/5/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-027

SAMPLE INFORMATION

Sample Number: 1501205-027 Customer Sample Number:
Location: H3 Type: Dist.
LPR 326 12TH ST SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/27/2015 14:00 CW 1/30/2015 12:29:24 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/5/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-028

SAMPLE INFORMATION

Sample Number: 1501205-028 Customer Sample Number:
Location: H4 Type: Dist.
LPR 326 12TH ST SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/27/2015 14:00 CW 1/30/2015 12:29:24 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/5/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-029

SAMPLE INFORMATION

Sample Number: 1501205-029 Customer Sample Number:
Location: H5 Type: Dist.
LPR 326 12TH ST SE (UNFILTERED)
Collection Date: 1/27/2015 Collection Time: 14:00 Sampler: CW Received Date and Time: 1/30/2015 12:29:24 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	26.8 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.24 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	139 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	21.5 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	14.0 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	10.2 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-029

SAMPLE INFORMATION

Sample Number: 1501205-029 Customer Sample Number:
Location: H5 Type: Dist.
LPR 326 12TH ST SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/27/2015 14:00 CW 1/30/2015 12:29:24 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/5/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-030

SAMPLE INFORMATION

Sample Number: 1501205-030 Customer Sample Number:
Location: H6 Type: Dist.
LPR 326 12TH ST SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/27/2015 14:00 CW 1/30/2015 12:29:24 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/5/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-031

SAMPLE INFORMATION

Sample Number: 1501205-031 Customer Sample Number:
Location: H7 Type: Dist.
LPR 326 12TH ST SE (UNFILTERED)
Collection Date: 1/27/2015 Collection Time: 14:00 Sampler: CW Received Date and Time: 1/30/2015 12:29:24 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	22.0 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.00 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	107 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	14.6 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	8.45 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.50 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-031

SAMPLE INFORMATION

Sample Number: 1501205-031 Customer Sample Number:
Location: H7 Type: Dist.
LPR 326 12TH ST SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/27/2015 14:00 CW 1/30/2015 12:29:24 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/5/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-032

SAMPLE INFORMATION

Sample Number: 1501205-032 Customer Sample Number:
Location: H8 Type: Dist.
LPR 326 12TH ST SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/27/2015 14:00 CW 1/30/2015 12:29:24 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/5/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-033

SAMPLE INFORMATION

Sample Number: 1501205-033 Customer Sample Number:
Location: H9 Type: Dist.
LPR 326 12TH ST SE (UNFILTERED)
Collection Date: 1/27/2015 Collection Time: 14:00 Sampler: CW Received Date and Time: 1/30/2015 12:29:24 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	24.6 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.16 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	116 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	17.5 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	10.9 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.45 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-033

SAMPLE INFORMATION

Sample Number: 1501205-033 Customer Sample Number:
Location: H9 Type: Dist.
LPR 326 12TH ST SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/27/2015 14:00 CW 1/30/2015 12:29:24 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/5/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-034

SAMPLE INFORMATION

Sample Number: 1501205-034 Customer Sample Number:
Location: H10 Type: Dist.
LPR 326 12TH ST SE (UNFILTERED)
Collection Date: 1/27/2015 Collection Time: 14:00 Sampler: CW Received Date and Time: 1/30/2015 12:29:24 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	21.9 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.05 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	104 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	14.6 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	8.82 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.56 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-034

SAMPLE INFORMATION

Sample Number: 1501205-034 Customer Sample Number:
Location: H10 Type: Dist.
LPR 326 12TH ST SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/27/2015 14:00 CW 1/30/2015 12:29:24 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/5/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-035

SAMPLE INFORMATION

Sample Number: 1501205-035 Customer Sample Number:
Location: H11 Type: Dist.
LPR 326 12TH ST SE (UNFILTERED)
Collection Date: 1/27/2015 Collection Time: 14:00 Sampler: CW Received Date and Time: 1/30/2015 12:29:24 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	21.5 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.06 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	100 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	13.3 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.60 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.00 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-035

SAMPLE INFORMATION

Sample Number: 1501205-035 Customer Sample Number:
Location: H11 Type: Dist.
LPR 326 12TH ST SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/27/2015 14:00 CW 1/30/2015 12:29:24 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/5/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-036

SAMPLE INFORMATION

Sample Number: 1501205-036 Customer Sample Number:
Location: H12 Type: Dist.
LPR 326 12TH ST SE (UNFILTERED)
Collection Date: 1/27/2015 Collection Time: 14:00 Sampler: CW Received Date and Time: 1/30/2015 12:29:24 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	21.7 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.06 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	101 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	13.4 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.55 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.11 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/5/2015
Report Number: M- W1501205-036

SAMPLE INFORMATION

Sample Number: 1501205-036 Customer Sample Number:
Location: H12 Type: Dist.
LPR 326 12TH ST SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/27/2015 14:00 CW 1/30/2015 12:29:24 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/5/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-001

SAMPLE INFORMATION

Sample Number: 1501206-001
Location: 1
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/10/2015
AEP - aCBA * Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment: sample run at 2x dilution factor.

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-002

SAMPLE INFORMATION

Sample Number: 1501206-002 Customer Sample Number:
Location: 1F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-003

SAMPLE INFORMATION

Sample Number: 1501206-003
Location: 02
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-004

SAMPLE INFORMATION

Sample Number: 1501206-004 Customer Sample Number:
Location: 02F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-005

SAMPLE INFORMATION

Sample Number: 1501206-005
Location: 03
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-006

SAMPLE INFORMATION

Sample Number: 1501206-006
Location: 03F
LPR 3815 5TH ST NW FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-007

SAMPLE INFORMATION

Sample Number: 1501206-007
Location: 04
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
1/30/2015	8:00	IC/CW	1/30/2015 12:39:40 PM	LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	112 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.81 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	36.4 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.81 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	33.1 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.07 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-007

SAMPLE INFORMATION

Sample Number: 1501206-007
Location: 04
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-008

SAMPLE INFORMATION

Sample Number: 1501206-008 Customer Sample Number:
Location: 04F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-009

SAMPLE INFORMATION

Sample Number: 1501206-009
Location: 05
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	255 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.86 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	37.7 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.78 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	65.5 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.74 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-009

SAMPLE INFORMATION

Sample Number: 1501206-009
Location: 05
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-010

SAMPLE INFORMATION

Sample Number: 1501206-010 Customer Sample Number:
Location: 05F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-011

SAMPLE INFORMATION

Sample Number: 1501206-011
Location: 06
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-012

SAMPLE INFORMATION

Sample Number: 1501206-012
Location: 06F
LPR 3815 5TH ST NW FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-013

SAMPLE INFORMATION

Sample Number: 1501206-013
Location: 07
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	101 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.93 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	35.9 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.68 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	25.1 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.73 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-013

SAMPLE INFORMATION

Sample Number: 1501206-013
Location: 07
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-014

SAMPLE INFORMATION

Sample Number: 1501206-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	25.3 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.75 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.89 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	19.9 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-014

SAMPLE INFORMATION

Sample Number: 1501206-014
Location: 07F
LPR 3815 5TH ST NW FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-015

SAMPLE INFORMATION

Sample Number: 1501206-015
Location: 08
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-016

SAMPLE INFORMATION

Sample Number: 1501206-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-017

SAMPLE INFORMATION

Sample Number: 1501206-017
Location: 09
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-018

SAMPLE INFORMATION

Sample Number: 1501206-018
Location: 09F
LPR 3815 5TH ST NW FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-019

SAMPLE INFORMATION

Sample Number: 1501206-019
Location: 10
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
1/30/2015	8:00	IC/CW	1/30/2015 12:39:40 PM	LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	16.9 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.42 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	31.7 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.16 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	6.00 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.34 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-019

SAMPLE INFORMATION

Sample Number: 1501206-019
Location: 10
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-020

SAMPLE INFORMATION

Sample Number: 1501206-020 Customer Sample Number:
Location: 10F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-021

SAMPLE INFORMATION

Sample Number: 1501206-021
Location: 11
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-022

SAMPLE INFORMATION

Sample Number: 1501206-022
Location: 11F
LPR 3815 5TH ST NW FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-023

SAMPLE INFORMATION

Sample Number: 1501206-023
Location: 12
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	16.9 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.22 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	31.7 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.29 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.62 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.32 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-023

SAMPLE INFORMATION

Sample Number: 1501206-023
Location: 12
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-024

SAMPLE INFORMATION

Sample Number: 1501206-024
Location: 12F
LPR 3815 5TH ST NW FILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 1/30/2015
Collection Time: 8:00
Sampler: IC/CW
Received Date and Time: 1/30/2015 12:39:40 PM
Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.12 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.95 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.38 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.05 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-024

SAMPLE INFORMATION

Sample Number: 1501206-024
Location: 12F
LPR 3815 5TH ST NW FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-025

SAMPLE INFORMATION

Sample Number: 1501206-025
Location: 13
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	14.5 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.63 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	32.3 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.06 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.47 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.33 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-025

SAMPLE INFORMATION

Sample Number: 1501206-025
Location: 13
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-026

SAMPLE INFORMATION

Sample Number: 1501206-026 Customer Sample Number:
Location: 13F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.52 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	10.7 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.88 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.49 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.05 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-026

SAMPLE INFORMATION

Sample Number: 1501206-026
Location: 13F
LPR 3815 5TH ST NW FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-027

SAMPLE INFORMATION

Sample Number: 1501206-027 Customer Sample Number:
Location: 14 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/30/2015 8:00 IC/CW 1/30/2015 12:39:40 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	14.3 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.65 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	33.2 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.37 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.78 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.34 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-027

SAMPLE INFORMATION

Sample Number: 1501206-027
Location: 14
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-028

SAMPLE INFORMATION

Sample Number: 1501206-028 Customer Sample Number:
Location: 14F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-029

SAMPLE INFORMATION

Sample Number: 1501206-029
Location: 15
LPR 3815 5TH ST NW UNFILTERED
Customer Sample Number:
Type: Dist.

Collection Date: 1/30/2015
Collection Time: 8:00
Sampler: IC/CW
Received Date and Time: 1/30/2015 12:39:40 PM
Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	15.7 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.58 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	33.8 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.03 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.91 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-029

SAMPLE INFORMATION

Sample Number: 1501206-029
Location: 15
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-030

SAMPLE INFORMATION

Sample Number: 1501206-030 Customer Sample Number:
Location: 15F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-031

SAMPLE INFORMATION

Sample Number: 1501206-031 Customer Sample Number:
Location: H1 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	183 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.72 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	62.6 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	6.04 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	21.5 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.57 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-031

SAMPLE INFORMATION

Sample Number: 1501206-031 Customer Sample Number:
Location: H1 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter Method MCL MDL RDL Result Analysis Date Analyst

Reviewed By: *Robert P. Hoffa* 2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-032

SAMPLE INFORMATION

Sample Number: 1501206-032
Location: H2
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-033

SAMPLE INFORMATION

Sample Number: 1501206-033 Customer Sample Number:
Location: H3 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter Method MCL MDL RDL Result Analysis Date Analyst

Reviewed By: *Robert P. Hoffa* 2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-034

SAMPLE INFORMATION

Sample Number: 1501206-034 Customer Sample Number:
Location: H4 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	32.4 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.71 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	42.3 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.23 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.06 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.98 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-034

SAMPLE INFORMATION

Sample Number: 1501206-034 Customer Sample Number:
Location: H4 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-035

SAMPLE INFORMATION

Sample Number: 1501206-035 Customer Sample Number:
Location: H5 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	94.4 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.72 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	44.7 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.38 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	18.6 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.66 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-035

SAMPLE INFORMATION

Sample Number: 1501206-035 Customer Sample Number:
Location: H5 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-036

SAMPLE INFORMATION

Sample Number: 1501206-036
Location: H6
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-037

SAMPLE INFORMATION

Sample Number: 1501206-037
Customer Sample Number:
Location: H7
Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 1/30/2015
Collection Time: 8:00
Sampler: IC/CW
Received Date and Time: 1/30/2015 12:39:40 PM
Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	39.9 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.61 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	39.9 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.29 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.41 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.76 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-037

SAMPLE INFORMATION

Sample Number: 1501206-037 Customer Sample Number:
Location: H7 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-038

SAMPLE INFORMATION

Sample Number: 1501206-038 Customer Sample Number:
Location: H8 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	29.1 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.60 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	36.7 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.37 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.48 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.84 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-038

SAMPLE INFORMATION

Sample Number: 1501206-038 Customer Sample Number:
Location: H8 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-039

SAMPLE INFORMATION

Sample Number: 1501206-039 Customer Sample Number:
Location: H9 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-040

SAMPLE INFORMATION

Sample Number: 1501206-040 Customer Sample Number:
Location: H10 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-041

SAMPLE INFORMATION

Sample Number: 1501206-041 Customer Sample Number:
Location: H11 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-042

SAMPLE INFORMATION

Sample Number: 1501206-042 Customer Sample Number:
Location: H12 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	18.6 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.55 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	34.6 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.01 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.86 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.63 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 2/10/2015
 Report Number: M- W1501206-042

SAMPLE INFORMATION

Sample Number: 1501206-042 Customer Sample Number:
 Location: H12 Type: Dist.
 LPR 3815 5TH ST NW UNFILTERED
 Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/10/2015
 Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-043

SAMPLE INFORMATION

Sample Number: 1501206-043 Customer Sample Number:
Location: H13 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-044

SAMPLE INFORMATION

Sample Number: 1501206-044
Location: H14
LPR 3815 5TH ST NW UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 1/30/2015
Collection Time: 8:00
Sampler: IC/CW
Received Date and Time: 1/30/2015 12:39:40 PM
Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	20.4 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.54 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	33.4 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.91 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.09 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.40 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-044

SAMPLE INFORMATION

Sample Number: 1501206-044 Customer Sample Number:
Location: H14 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/10/2015
Report Number: M- W1501206-045

SAMPLE INFORMATION

Sample Number: 1501206-045 Customer Sample Number:
Location: H15 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 1/30/2015 Collection Time: 8:00 Sampler: IC/CW Received Date and Time: 1/30/2015 12:39:40 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/10/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-001

SAMPLE INFORMATION

Sample Number: 1501129-001
Location: 1
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	15.1 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.64 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	87.9 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.93 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	240 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.96 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-001


SAMPLE INFORMATION

Sample Number: 1501129-001
Location: 1
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/11/2015
Robert P. Hoffa * Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-002

SAMPLE INFORMATION

Sample Number: 1501129-002
Location: 1F
LPR 2914 45TH ST NW (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter Method MCL MDL RDL Result Analysis Date Analyst

Reviewed By: *Robert P. Hoffa* 2/11/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-003

SAMPLE INFORMATION

Sample Number: 1501129-003
Location: 02
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/11/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 2/11/2015
 Report Number: M- W1501129-004

SAMPLE INFORMATION

Sample Number: 1501129-004 Customer Sample Number:
 Location: 02F Type: Dist.
 LPR 2914 45TH ST NW (FILTERED)
 Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
 1/21/2015 7:00 CW 1/21/2015 11:05:29 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/11/2015
 Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-005

SAMPLE INFORMATION

Sample Number: 1501129-005
Location: 03
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	13.4 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.11 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	331 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.29 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	198 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-005

SAMPLE INFORMATION

Sample Number: 1501129-005 Customer Sample Number:
Location: 03 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/21/2015 7:00 CW 1/21/2015 11:05:29 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/11/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-006

SAMPLE INFORMATION

Sample Number: 1501129-006 Customer Sample Number:
Location: 03F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/21/2015 7:00 CW 1/21/2015 11:05:29 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/11/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-007

SAMPLE INFORMATION

Sample Number: 1501129-007
Location: 04
LPR 2914 45TH ST NW (UNFILTERED)
Customer Sample Number:
Type: Dist.
Collection Date: 1/21/2015
Collection Time: 7:00
Sampler: CW
Received Date and Time: 1/21/2015 11:05:29 AM
Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	14.1 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.08 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	375 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.42 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	311 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-007

SAMPLE INFORMATION

Sample Number: 1501129-007
Location: 04
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/11/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 2/11/2015
 Report Number: M- W1501129-008

SAMPLE INFORMATION

Sample Number: 1501129-008 Customer Sample Number:
 Location: 04F Type: Dist.
 LPR 2914 45TH ST NW (FILTERED)
 Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
 1/21/2015 7:00 CW 1/21/2015 11:05:29 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/11/2015
 Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-009

SAMPLE INFORMATION

Sample Number: 1501129-009
Location: 05
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	14.4 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	6.77 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	318 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.42 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	272 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 2/11/2015
 Report Number: M- W1501129-009

SAMPLE INFORMATION

Sample Number: 1501129-009 Customer Sample Number:
 Location: 05 Type: Dist.
 LPR 2914 45TH ST NW (UNFILTERED)
 Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
 1/21/2015 7:00 CW 1/21/2015 11:05:29 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/11/2015
 Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-010

SAMPLE INFORMATION

Sample Number: 1501129-010
Customer Sample Number:
Location: 05F
Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: 1/21/2015
Collection Time: 7:00
Sampler: CW
Received Date and Time: 1/21/2015 11:05:29 AM
Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	6.52 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.92 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	215 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-010

SAMPLE INFORMATION

Sample Number: 1501129-010
Location: 05F
LPR 2914 45TH ST NW (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/11/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-011

SAMPLE INFORMATION

Sample Number: 1501129-011
Location: 06
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	14.9 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.32 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	384 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.92 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	262 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.53 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-011

SAMPLE INFORMATION

Sample Number: 1501129-011
Location: 06
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/11/2015

[Illegible signature]

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-012

SAMPLE INFORMATION

Sample Number: 1501129-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/21/2015 7:00 CW 1/21/2015 11:05:29 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/11/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-013

SAMPLE INFORMATION

Sample Number: 1501129-013
Location: 07
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	15.9 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.22 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	240 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.10 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	176 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.32 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-013

SAMPLE INFORMATION

Sample Number: 1501129-013
Location: 07
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/11/2015

Ü[à^! ÚËP [~aÛBç * Šca[|æ[!^ Á æ æ^!

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-014

SAMPLE INFORMATION

Sample Number: 1501129-014
Location: 07F
LPR 2914 45TH ST NW (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter Method MCL MDL RDL Result Analysis Date Analyst

Reviewed By: *Robert P. Hoffa* 2/11/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-015

SAMPLE INFORMATION

Sample Number: 1501129-015
Location: 08
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/11/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-016

SAMPLE INFORMATION

Sample Number: 1501129-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter Method MCL MDL RDL Result Analysis Date Analyst

Reviewed By: *Robert P. Hoffa* 2/11/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-017

SAMPLE INFORMATION

Sample Number: 1501129-017
Location: 09
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/11/2015
Date

Ü[à^! ÚËP [~aÜBç * Šca[|æ[!^ Á æ æ ^!

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-018

SAMPLE INFORMATION

Sample Number: 1501129-018
Location: 09F
LPR 2914 45TH ST NW (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter Method MCL MDL RDL Result Analysis Date Analyst

Reviewed By: *Robert P. Hoffa* 2/11/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-019

SAMPLE INFORMATION

Sample Number: 1501129-019
Location: 10
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	15.7 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.90 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	141 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.17 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	127 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.54 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-019

SAMPLE INFORMATION

Sample Number: 1501129-019
Location: 10
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/11/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-020

SAMPLE INFORMATION

Sample Number: 1501129-020
Location: 10F
LPR 2914 45TH ST NW (FILTERED)
Customer Sample Number:
Type: Dist.
Collection Date: 1/21/2015
Collection Time: 7:00
Sampler: CW
Received Date and Time: 1/21/2015 11:05:29 AM
Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.79 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.17 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	113 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-020

SAMPLE INFORMATION

Sample Number: 1501129-020 Customer Sample Number:
Location: 10F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/21/2015 7:00 CW 1/21/2015 11:05:29 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/11/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-021

SAMPLE INFORMATION

Sample Number: 1501129-021
Location: 11
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/11/2015

Ü[à^! ÚËP[~aÛBç * Šca[|æ[!^ Á æ æ ^!

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-022

SAMPLE INFORMATION

Sample Number: 1501129-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/11/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-023

SAMPLE INFORMATION

Sample Number: 1501129-023
Location: 12
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
1/21/2015	7:00	CW	1/21/2015 11:05:29 AM	LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	15.7 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.57 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	134 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.12 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	95.6 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.67 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-023

SAMPLE INFORMATION

Sample Number: 1501129-023
Location: 12
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/11/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-024

SAMPLE INFORMATION

Sample Number: 1501129-024 Customer Sample Number:
Location: 12F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.59 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.48 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	87.5 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-024

SAMPLE INFORMATION

Sample Number: 1501129-024
Location: 12F
LPR 2914 45TH ST NW (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/11/2015

Ü[à^! ÚËP [~aÜBç * Šca[|æ[!^ Á æ æ ^!

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-025

SAMPLE INFORMATION

Sample Number: 1501129-025
Location: 13
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	16.1 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.52 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	133 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.71 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	77.5 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.86 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-025

SAMPLE INFORMATION

Sample Number: 1501129-025
Location: 13
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/11/2015

*Ü[à^! ÚËP[~aÛBç * Šca[|æ[!^ Á æ æ^!*

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-026

SAMPLE INFORMATION

Sample Number: 1501129-026
Location: 13F
LPR 2914 45TH ST NW (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/11/2015

Ü[à^! ÚËP [~aÜBç * Šca[|æ[!^ Á æ æ ^!

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-027

SAMPLE INFORMATION

Sample Number: 1501129-027
Location: 14
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/11/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-028

SAMPLE INFORMATION

Sample Number: 1501129-028
Location: 14F
LPR 2914 45TH ST NW (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.33 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.94 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	56.7 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-028

SAMPLE INFORMATION

Sample Number: 1501129-028
Location: 14F
LPR 2914 45TH ST NW (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/11/2015

*Ü[à^! ÚËP [~aÛBç * Šca[|æ[!^ Á æ æ^!*

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-029

SAMPLE INFORMATION

Sample Number: 1501129-029
Location: 15
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/11/2015

Ü[à^! ÚËP [~aÛBç * Šca[|æ[!^ Á æ æ ^!

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-030

SAMPLE INFORMATION

Sample Number: 1501129-030
Location: 15F
LPR 2914 45TH ST NW (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/11/2015

Ü[à^! ÚËP [~aÜBç * Šca[|æ[!^ Á æ æ^!

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-031

SAMPLE INFORMATION

Sample Number: 1501129-031 Customer Sample Number:
Location: H1 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/21/2015 7:00 CW 1/21/2015 11:05:29 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/11/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-032

SAMPLE INFORMATION

Sample Number: 1501129-032 Customer Sample Number:
Location: H2 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter Method MCL MDL RDL Result Analysis Date Analyst

Reviewed By: *Robert P. Hoffa* 2/11/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-033

SAMPLE INFORMATION

Sample Number: 1501129-033 Customer Sample Number:
Location: H3 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	16.3 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.50 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	128 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.52 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	66.9 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.62 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-033

SAMPLE INFORMATION

Sample Number: 1501129-033 Customer Sample Number:
Location: H3 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter Method MCL MDL RDL Result Analysis Date Analyst

Reviewed By: *Robert P. Hoffa* 2/11/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-034

SAMPLE INFORMATION

Sample Number: 1501129-034 Customer Sample Number:
Location: H4 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/21/2015 7:00 CW 1/21/2015 11:05:29 AM LGallimore

Parameter Method MCL MDL RDL Result Analysis Date Analyst

Reviewed By: *Robert P. Hoffa* 2/11/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-035

SAMPLE INFORMATION

Sample Number: 1501129-035 Customer Sample Number:
Location: H5 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter Method MCL MDL RDL Result Analysis Date Analyst

Reviewed By: *Robert P. Hoffa* 2/11/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-036

SAMPLE INFORMATION

Sample Number: 1501129-036
Location: H6
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	16.5 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.70 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	129 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.27 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	56.6 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.27 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-036

SAMPLE INFORMATION

Sample Number: 1501129-036
Location: H6
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/11/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-038

SAMPLE INFORMATION

Sample Number: 1501129-038 Customer Sample Number:
Location: H8 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/21/2015 7:00 CW 1/21/2015 11:05:29 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/11/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-039

SAMPLE INFORMATION

Sample Number: 1501129-039 Customer Sample Number:
Location: H9 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: 1/21/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 1/21/2015 11:05:29 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	16.5 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.60 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	131 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.62 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	44.0 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.25 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-039

SAMPLE INFORMATION

Sample Number: 1501129-039 Customer Sample Number:
Location: H9 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/21/2015 7:00 CW 1/21/2015 11:05:29 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/11/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-040

SAMPLE INFORMATION

Sample Number: 1501129-040 Customer Sample Number:
Location: H10 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/21/2015 7:00 CW 1/21/2015 11:05:29 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/11/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-042

SAMPLE INFORMATION

Sample Number: 1501129-042 Customer Sample Number:
Location: H12 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/21/2015 7:00 CW 1/21/2015 11:05:29 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/11/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-043

SAMPLE INFORMATION

Sample Number: 1501129-043 Customer Sample Number:
Location: H13 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/21/2015 7:00 CW 1/21/2015 11:05:29 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/11/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-044

SAMPLE INFORMATION

Sample Number: 1501129-044 Customer Sample Number:
Location: H14 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/21/2015 7:00 CW 1/21/2015 11:05:29 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	16.4 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.61 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	128 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.02 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	43.5 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.50 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-044

SAMPLE INFORMATION

Sample Number: 1501129-044 Customer Sample Number:
Location: H14 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/21/2015 7:00 CW 1/21/2015 11:05:29 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/11/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-045

SAMPLE INFORMATION

Sample Number: 1501129-045
Customer Sample Number:
Location: H15
Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: 1/21/2015
Collection Time: 7:00
Sampler: CW
Received Date and Time: 1/21/2015 11:05:29 AM
Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	17.5 ug/L	2/4/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.76 ug/L	2/4/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	137 ug/L	2/4/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.06 ug/L	2/4/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	41.0 ug/L	2/4/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.42 ug/L	2/4/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/11/2015
Report Number: M- W1501129-045

SAMPLE INFORMATION

Sample Number: 1501129-045 Customer Sample Number:
Location: H15 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
1/21/2015 7:00 CW 1/21/2015 11:05:29 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/11/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/13/2015
Report Number: M- W1502021-001

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-001
Location: 1
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	25.6 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	17.8 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	23.6 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-001

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-001
Location: 1
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Robert P. Hoffa * Laboratory Manager

2/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/13/2015
Report Number: M- W1502021-002

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-002
Location: 1F
LPR 2139 N ST NW, FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	17.4 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.2 ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	15.2 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	21.4 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.2 ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-002

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-002
Location: 1F
LPR 2139 N ST NW, FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-003

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-003
Location: 02
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	21.0 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.2 ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	14.5 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.52 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.2 ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-003

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-003
Location: 02
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/13/2015

Ü[à^! ÚË[~aÜBç * Šca[|æ[!^ Á æ æ ^!

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/13/2015
Report Number: M- W1502021-004

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-004
Location: 02F
LPR 2139 N ST NW, FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015	Collection Time: 15:00	Sampler: IC/DM	Received Date and Time: 2/4/2015 9:56:08 AM	Received By: MMoore
------------------------------	---------------------------	-------------------	--	------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	16.9 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.2 ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	12.9 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.21 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-004

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-004
Location: 02F
LPR 2139 N ST NW, FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/13/2015
Report Number: M- W1502021-005

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-005
Location: 03
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015	Collection Time: 15:00	Sampler: IC/DM	Received Date and Time: 2/4/2015 9:56:08 AM	Received By: MMoore
------------------------------	---------------------------	-------------------	--	------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	20.9 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.2 ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	13.1 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.80 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.2 ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-005

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-005
Location: 03
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/13/2015
Report Number: M- W1502021-006

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-006
Location: 03F
LPR 2139 N ST NW, FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015	Collection Time: 15:00	Sampler: IC/DM	Received Date and Time: 2/4/2015 9:56:08 AM	Received By: MMoore
------------------------------	---------------------------	-------------------	--	------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	15.6 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	11.5 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	8.97 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-006

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-006
Location: 03F
LPR 2139 N ST NW, FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/13/2015

Ü[à^!ÁËP[~aÖBç * Šca[|æ[!^ Á æ æ ^!

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/13/2015
Report Number: M- W1502021-007

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-007
Location: 04
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	20.0 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	11.1 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.54 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.2 ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-007

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-007
Location: 04
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/13/2015
Report Number: M- W1502021-008

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-008
Location: 04F
LPR 2139 N ST NW, FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	14.3 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.2 ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	9.56 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.91 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-008

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-008
Location: 04F
LPR 2139 N ST NW, FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/13/2015
Report Number: M- W1502021-009

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-009
Location: 05
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	19.1 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.2 ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	12.6 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.12 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-009

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-009
Location: 05
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/13/2015
Report Number: M- W1502021-010

SAMPLE INFORMATION

Sample Number: 1502021-010
Location: 05F
LPR 2139 N ST NW, FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	14.6 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	11.3 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.94 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-010

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-010
Location: 05F
LPR 2139 N ST NW, FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/13/2015
Report Number: M- W1502021-011

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-011
Location: 06
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015	Collection Time: 15:00	Sampler: IC/DM	Received Date and Time: 2/4/2015 9:56:08 AM	Received By: MMoore
------------------------------	---------------------------	-------------------	--	------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	21.1 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	10.8 ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	14.5 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.14 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-011

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-011
Location: 06
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/13/2015

Ü[à^! ÚËP[~aËBç * Šca[|æ[!^ Á æ æ ^!

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/13/2015
Report Number: M- W1502021-012

SAMPLE INFORMATION

Sample Number: 1502021-012
Location: 06F
LPR 2139 N ST NW, FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	14.0 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.2 ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	12.7 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.48 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-012

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-012
Location: 06F
LPR 2139 N ST NW, FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/13/2015
Report Number: M- W1502021-013

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-013
Location: 07
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015	Collection Time: 15:00	Sampler: IC/DM	Received Date and Time: 2/4/2015 9:56:08 AM	Received By: MMoore
------------------------------	---------------------------	-------------------	--	------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	22.8 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	14.0 ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	12.2 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.04 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-013

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-013
Location: 07
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/13/2015
Report Number: M- W1502021-014

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-014
Location: 07F
LPR 2139 N ST NW, FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	12.5 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	10.4 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.03 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-014

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-014
Location: 07F
LPR 2139 N ST NW, FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/13/2015

Ü[à^!ÁË[~aÖBç * Šca[|æ[!^ Á æ æ ^!

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/13/2015
Report Number: M- W1502021-015

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-015
Location: 08
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015	Collection Time: 15:00	Sampler: IC/DM	Received Date and Time: 2/4/2015 9:56:08 AM	Received By: MMoore
------------------------------	---------------------------	-------------------	--	------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	23.1 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	14.7 ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	11.8 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.90 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-015

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-015
Location: 08
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/13/2015
Report Number: M- W1502021-016

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-016
Location: 08F
LPR 2139 N ST NW, FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	12.8 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	10.2 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	11.1 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-016

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-016
Location: 08F
LPR 2139 N ST NW, FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/13/2015
Report Number: M- W1502021-017

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-017
Location: 09
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	22.2 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	13.5 ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	11.4 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.64 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-017

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-017
Location: 09
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-018

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-018
Location: 09F
LPR 2139 N ST NW, FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	12.0 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	9.74 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.39 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-018

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-018
Location: 09F
LPR 2139 N ST NW, FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/13/2015
Report Number: M- W1502021-019

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-019
Location: 10
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	21.2 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	12.1 ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	10.6 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.52 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-019

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-019
Location: 10
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/13/2015
Report Number: M- W1502021-020

SAMPLE INFORMATION

Sample Number: 1502021-020
Location: 10F
LPR 2139 N ST NW, FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	11.7 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	9.43 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.80 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-020

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-020
Location: 10F
LPR 2139 N ST NW, FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/13/2015
Report Number: M- W1502021-021

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-021
Location: 11
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015	Collection Time: 15:00	Sampler: IC/DM	Received Date and Time: 2/4/2015 9:56:08 AM	Received By: MMoore
------------------------------	---------------------------	-------------------	--	------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	22.1 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	13.6 ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	10.6 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.63 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-021

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-021
Location: 11
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/13/2015
Report Number: M- W1502021-022

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-022
Location: 11F
LPR 2139 N ST NW, FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015	Collection Time: 15:00	Sampler: IC/DM	Received Date and Time: 2/4/2015 9:56:08 AM	Received By: MMoore
------------------------------	---------------------------	-------------------	--	------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	11.8 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	9.25 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.69 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-022

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-022
Location: 11F
LPR 2139 N ST NW, FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/13/2015
Report Number: M- W1502021-023

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-023
Location: 12
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015	Collection Time: 15:00	Sampler: IC/DM	Received Date and Time: 2/4/2015 9:56:08 AM	Received By: MMoore
------------------------------	---------------------------	-------------------	--	------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	20.0 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	9.38 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.53 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-023

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-023

Customer Sample Number:

Location: 12

Type: Dist.

LPR 2139 N ST NW, UNFILTERED

Collection Date:
2/3/2015

Collection Time:
15:00


Sampler:
IC/DM

Received Date and Time:
2/4/2015 9:56:08 AM

Received By:
MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



2/13/2015

Ü[à^!óÁË[~aÖBç * Šca[|æ[!^ Á æ æ ^!

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-024

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-024
Location: 12F
LPR 2139 N ST NW, FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	11.4 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.26 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.77 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-024

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-024
Location: 12F
LPR 2139 N ST NW, FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/13/2015
Report Number: M- W1502021-025

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-025
Location: H1
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	23.4 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	13.7 ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	9.66 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.84 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-025

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-025
Location: H1
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/13/2015
Report Number: M- W1502021-026

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-026
Location: H2
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	22.2 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	13.3 ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.54 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.06 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-026

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-026
Location: H2
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/13/2015

Ü[à^! ÚËP[~aËBç * Šca[|æ[!^ Á æ æ ^!

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/13/2015
Report Number: M- W1502021-027

SAMPLE INFORMATION

Sample Number: 1502021-027
Location: H3
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	23.9 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	16.0 ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.80 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.83 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-027

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-027

Customer Sample Number:

Location: H3

Type: Dist.

LPR 2139 N ST NW, UNFILTERED

Collection Date:
2/3/2015

Collection Time:
15:00


Sampler:
IC/DM

Received Date and Time:
2/4/2015 9:56:08 AM

Received By:
MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



2/13/2015

Ü[à^!óÚË[~aÖBç * Šca[|æ[!^ Á æ æ ^!

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/13/2015
Report Number: M- W1502021-028

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-028
Location: H4
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	32.9 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.40 ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	30.2 ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	6.70 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.84 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-028

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-028
Location: H4
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-029

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-029
Location: H5
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	35.2 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.67 ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	48.7 ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.47 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.80 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-029

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-029
Location: H5
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/13/2015
Report Number: M- W1502021-030

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-030
Location: H6
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015	Collection Time: 15:00	Sampler: IC/DM	Received Date and Time: 2/4/2015 9:56:08 AM	Received By: MMoore
------------------------------	---------------------------	-------------------	--	------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	33.5 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.78 ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	50.6 ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.68 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.86 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-030

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-030
Location: H6
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/13/2015
Report Number: M- W1502021-031

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-031
Location: H7
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	36.5 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.42 ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	91.7 ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.37 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.90 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-031

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-031
Location: H7
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/13/2015
Report Number: M- W1502021-032

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-032
Location: H8
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015	Collection Time: 15:00	Sampler: IC/DM	Received Date and Time: 2/4/2015 9:56:08 AM	Received By: MMoore
------------------------------	---------------------------	-------------------	--	------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	38.9 ug/L	2/15/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.56 ug/L	2/15/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	73.5 ug/L	2/15/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.29 ug/L	2/15/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.46 ug/L	2/15/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	2/15/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-032

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-032
Location: H8
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/13/2015
Report Number: M- W1502021-033

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-033
Location: H9
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	42.5 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.62 ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	153 ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.22 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.11 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-033

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-033
Location: H9
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*

2/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-034

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-034
Location: H10
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	39.3 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.21 ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	151 ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.60 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.66 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/13/2015
Report Number: M- W1502021-034

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-034
Location: H10
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/13/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/13/2015
Report Number: M- W1502021-035

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-035
Location: H11
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	36.4 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.63 ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	59.8 ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.18 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.84 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-035

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


SAMPLE INFORMATION

Sample Number: 1502021-035
Location: H11
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/13/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority

Report Date: 2/13/2015
Report Number: M- W1502021-036

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1502021-036
Location: H12
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015 Collection Time: 15:00 Sampler: IC/DM Received Date and Time: 2/4/2015 9:56:08 AM Received By: MMoore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	41.8 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.38 ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	160 ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.46 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.12 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority

Report Date: 2/13/2015
Report Number: M- W1502021-036

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


SAMPLE INFORMATION

Sample Number: 1502021-036
Location: H12
LPR 2139 N ST NW, UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/3/2015	Collection Time: 15:00	Sampler: IC/DM	Received Date and Time: 2/4/2015 9:56:08 AM	Received By: MMoore
------------------------------	---------------------------	-------------------	--	------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  2/13/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-001

SAMPLE INFORMATION

Sample Number: 1502026-001 Customer Sample Number:
Location: 1 Type: Dist.
LPR 1936 SUMMIT PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/4/2015 7:00 CW 2/4/2015 12:30:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-002

SAMPLE INFORMATION

Sample Number: 1502026-002
Location: 1F
LPR 1936 SUMMIT PL NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/4/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 2/4/2015 12:30:24 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	19.6 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.04 ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	21.7 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	70.4 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-002

SAMPLE INFORMATION

Sample Number: 1502026-002 Customer Sample Number:
Location: 1F Type: Dist.
LPR 1936 SUMMIT PL NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/4/2015 7:00 CW 2/4/2015 12:30:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-003

SAMPLE INFORMATION

Sample Number: 1502026-003 Customer Sample Number:
Location: 02 Type: Dist.
LPR 1936 SUMMIT PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/4/2015 7:00 CW 2/4/2015 12:30:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-004

SAMPLE INFORMATION

Sample Number: 1502026-004 Customer Sample Number:
Location: 02F Type: Dist.
LPR 1936 SUMMIT PL NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/4/2015 7:00 CW 2/4/2015 12:30:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-005

SAMPLE INFORMATION

Sample Number: 1502026-005 Customer Sample Number:
Location: 03 Type: Dist.
LPR 1936 SUMMIT PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/4/2015 7:00 CW 2/4/2015 12:30:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-006

SAMPLE INFORMATION

Sample Number: 1502026-006 Customer Sample Number:
Location: 03F Type: Dist.
LPR 1936 SUMMIT PL NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/4/2015 7:00 CW 2/4/2015 12:30:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-007

SAMPLE INFORMATION

Sample Number: 1502026-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 1936 SUMMIT PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/4/2015 7:00 CW 2/4/2015 12:30:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-008

SAMPLE INFORMATION

Sample Number: 1502026-008 Customer Sample Number:
Location: 04F Type: Dist.
LPR 1936 SUMMIT PL NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/4/2015 7:00 CW 2/4/2015 12:30:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-009

SAMPLE INFORMATION

Sample Number: 1502026-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 1936 SUMMIT PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/4/2015 7:00 CW 2/4/2015 12:30:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-010

SAMPLE INFORMATION

Sample Number: 1502026-010 Customer Sample Number:
Location: 05F Type: Dist.
LPR 1936 SUMMIT PL NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/4/2015 7:00 CW 2/4/2015 12:30:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-011

SAMPLE INFORMATION

Sample Number: 1502026-011 Customer Sample Number:
Location: 06 Type: Dist.
LPR 1936 SUMMIT PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/4/2015 7:00 CW 2/4/2015 12:30:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-012

SAMPLE INFORMATION

Sample Number: 1502026-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 1936 SUMMIT PL NE FILTERED
Collection Date: 2/4/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 2/4/2015 12:30:24 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	10.2 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	17.1 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.58 ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-013

SAMPLE INFORMATION

Sample Number: 1502026-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 1936 SUMMIT PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/4/2015 7:00 CW 2/4/2015 12:30:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-014

SAMPLE INFORMATION

Sample Number: 1502026-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 1936 SUMMIT PL NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/4/2015 7:00 CW 2/4/2015 12:30:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-015

SAMPLE INFORMATION

Sample Number: 1502026-015
Location: 08
LPR 1936 SUMMIT PL NE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 2/4/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 2/4/2015 12:30:24 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	12.9 ug/L	2/12/2014	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.2 ug/L	2/12/2014	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/12/2014	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	10.3 ug/L	2/12/2014	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.06 ug/L	2/12/2014	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.42 ug/L	2/12/2014	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-015

SAMPLE INFORMATION

Sample Number: 1502026-015 Customer Sample Number:
Location: 08 Type: Dist.
LPR 1936 SUMMIT PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/4/2015 7:00 CW 2/4/2015 12:30:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-016

SAMPLE INFORMATION

Sample Number: 1502026-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 1936 SUMMIT PL NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/4/2015 7:00 CW 2/4/2015 12:30:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-017

SAMPLE INFORMATION

Sample Number: 1502026-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 1936 SUMMIT PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/4/2015 7:00 CW 2/4/2015 12:30:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-018

SAMPLE INFORMATION

Sample Number: 1502026-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 1936 SUMMIT PL NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/4/2015 7:00 CW 2/4/2015 12:30:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-019

SAMPLE INFORMATION

Sample Number: 1502026-019 Customer Sample Number:
Location: 10 Type: Dist.
LPR 1936 SUMMIT PL NE UNFILTERED

Collection Date: 2/4/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 2/4/2015 12:30:24 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	12.6 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.62 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.25 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.36 ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-019

SAMPLE INFORMATION

Sample Number: 1502026-019 Customer Sample Number:
Location: 10 Type: Dist.
LPR 1936 SUMMIT PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/4/2015 7:00 CW 2/4/2015 12:30:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-020

SAMPLE INFORMATION

Sample Number: 1502026-020 Customer Sample Number:
Location: 10F Type: Dist.
LPR 1936 SUMMIT PL NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/4/2015 7:00 CW 2/4/2015 12:30:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-021

SAMPLE INFORMATION

Sample Number: 1502026-021 Customer Sample Number:
Location: 11 Type: Dist.
LPR 1936 SUMMIT PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/4/2015 7:00 CW 2/4/2015 12:30:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-022

SAMPLE INFORMATION

Sample Number: 1502026-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 1936 SUMMIT PL NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/4/2015 7:00 CW 2/4/2015 12:30:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-023

SAMPLE INFORMATION

Sample Number: 1502026-023
Location: 12
LPR 1936 SUMMIT PL NE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
2/4/2015	7:00	CW	2/4/2015 12:30:24 PM	JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	14.7 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.86 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.60 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.23 ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-023

SAMPLE INFORMATION

Sample Number: 1502026-023 Customer Sample Number:
Location: 12 Type: Dist.
LPR 1936 SUMMIT PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/4/2015 7:00 CW 2/4/2015 12:30:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-024

SAMPLE INFORMATION

Sample Number: 1502026-024 Customer Sample Number:
Location: 12F Type: Dist.
LPR 1936 SUMMIT PL NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/4/2015 7:00 CW 2/4/2015 12:30:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-025

SAMPLE INFORMATION

Sample Number: 1502026-025 Customer Sample Number:
Location: H1 Type: Dist.
LPR 1936 SUMMIT PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/4/2015 7:00 CW 2/4/2015 12:30:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-027

SAMPLE INFORMATION

Sample Number: 1502026-027 Customer Sample Number:
Location: H3 Type: Dist.
LPR 1936 SUMMIT PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/4/2015 7:00 CW 2/4/2015 12:30:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-028

SAMPLE INFORMATION

Sample Number: 1502026-028 Customer Sample Number:
Location: H4 Type: Dist.
LPR 1936 SUMMIT PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/4/2015 7:00 CW 2/4/2015 12:30:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-029

SAMPLE INFORMATION

Sample Number: 1502026-029 Customer Sample Number:
Location: H5 Type: Dist.
LPR 1936 SUMMIT PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/4/2015 7:00 CW 2/4/2015 12:30:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-030

SAMPLE INFORMATION

Sample Number: 1502026-030 Customer Sample Number:
Location: H6 Type: Dist.
LPR 1936 SUMMIT PL NE UNFILTERED

Collection Date: 2/4/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 2/4/2015 12:30:24 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	19.2 ug/L	2/12/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	2/12/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	2/12/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	6.96 ug/L	2/12/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.12 ug/L	2/12/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	2/12/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-030

SAMPLE INFORMATION

Sample Number: 1502026-030 Customer Sample Number:
Location: H6 Type: Dist.
LPR 1936 SUMMIT PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/4/2015 7:00 CW 2/4/2015 12:30:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-031

SAMPLE INFORMATION

Sample Number: 1502026-031 Customer Sample Number:
Location: H7 Type: Dist.
LPR 1936 SUMMIT PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/4/2015 7:00 CW 2/4/2015 12:30:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-033

SAMPLE INFORMATION

Sample Number: 1502026-033 Customer Sample Number:
Location: H9 Type: Dist.
LPR 1936 SUMMIT PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/4/2015 7:00 CW 2/4/2015 12:30:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-034

SAMPLE INFORMATION

Sample Number: 1502026-034 Customer Sample Number:
Location: H10 Type: Dist.
LPR 1936 SUMMIT PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/4/2015 7:00 CW 2/4/2015 12:30:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-035

SAMPLE INFORMATION

Sample Number: 1502026-035 Customer Sample Number:
Location: H11 Type: Dist.
LPR 1936 SUMMIT PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/4/2015 7:00 CW 2/4/2015 12:30:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 2/23/2015
Report Number: M- W1502026-036

SAMPLE INFORMATION

Sample Number: 1502026-036 Customer Sample Number:
Location: H12 Type: Dist.
LPR 1936 SUMMIT PL NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/4/2015 7:00 CW 2/4/2015 12:30:24 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 2/23/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-001

SAMPLE INFORMATION

Sample Number: 1502149-001
Location: 01
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
2/20/2015	7:00	CW/DC	2/20/2015 10:31:51 AM	JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	11.3 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	9.98 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	162 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.88 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	381 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.24 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-003

SAMPLE INFORMATION

Sample Number: 1502149-003
Location: 02
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
2/20/2015	7:00	CW/DC	2/20/2015 10:31:51 AM	JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	9.77 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	190 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.01 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	346 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.80 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-003

SAMPLE INFORMATION

Sample Number: 1502149-003
Location: 02
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/20/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 2/20/2015 10:31:51 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-004

SAMPLE INFORMATION

Sample Number: 1502149-004 Customer Sample Number:
Location: 02F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-005

SAMPLE INFORMATION

Sample Number: 1502149-005
Location: 03
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/20/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 2/20/2015 10:31:51 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	10.6 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8 2x dilution	ug/L	ug/L	20 ug/L	570 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.60 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	254 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.77 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-005


SAMPLE INFORMATION

Sample Number: 1502149-005
Location: 03
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
2/20/2015	7:00	CW/DC	2/20/2015 10:31:51 AM	JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: 
Robert P. Hoffa, Acting Laboratory Manager

4/1/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-006

SAMPLE INFORMATION

Sample Number: 1502149-006 Customer Sample Number:
Location: 03F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: 2/20/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 2/20/2015 10:31:51 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	10.2 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.68 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	173 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-006

SAMPLE INFORMATION

Sample Number: 1502149-006 Customer Sample Number:
Location: 03F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-007

SAMPLE INFORMATION

Sample Number: 1502149-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-009

SAMPLE INFORMATION

Sample Number: 1502149-009
Location: 05
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
2/20/2015	7:00	CW/DC	2/20/2015 10:31:51 AM	JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.10 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	385 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.01 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	298 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-009

SAMPLE INFORMATION

Sample Number: 1502149-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-011

SAMPLE INFORMATION

Sample Number: 1502149-011 Customer Sample Number:
Location: 06 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: 2/20/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 2/20/2015 10:31:51 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	10.6 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	9.02 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	392 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.98 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	303 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.23 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-012

SAMPLE INFORMATION

Sample Number: 1502149-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: 2/20/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 2/20/2015 10:31:51 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.72 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.08 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	226 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-012

SAMPLE INFORMATION

Sample Number: 1502149-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: 2/20/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 2/20/2015 10:31:51 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-013

SAMPLE INFORMATION

Sample Number: 1502149-013
Location: 07
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
2/20/2015	7:00	CW/DC	2/20/2015 10:31:51 AM	JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	11.1 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	6.90 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	241 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	18.5 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	223 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.42 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-013

SAMPLE INFORMATION

Sample Number: 1502149-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-014

SAMPLE INFORMATION

Sample Number: 1502149-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-015

SAMPLE INFORMATION

Sample Number: 1502149-015
Location: 08
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/20/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 2/20/2015 10:31:51 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	11.1 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.85 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	165 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	16.6 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	203 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.05 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-015

SAMPLE INFORMATION

Sample Number: 1502149-015 Customer Sample Number:
Location: 08 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-016

SAMPLE INFORMATION

Sample Number: 1502149-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-017

SAMPLE INFORMATION

Sample Number: 1502149-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: 2/20/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 2/20/2015 10:31:51 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	11.3 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.57 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	144 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	10.6 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	200 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.47 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-017

SAMPLE INFORMATION

Sample Number: 1502149-017
Location: 09
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/20/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 2/20/2015 10:31:51 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-018

SAMPLE INFORMATION

Sample Number: 1502149-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-019

SAMPLE INFORMATION

Sample Number: 1502149-019
Location: 10
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/20/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 2/20/2015 10:31:51 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-020

SAMPLE INFORMATION

Sample Number: 1502149-020 Customer Sample Number:
Location: 10F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-022

SAMPLE INFORMATION

Sample Number: 1502149-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: 2/20/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 2/20/2015 10:31:51 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.62 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.71 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	127 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-022

SAMPLE INFORMATION

Sample Number: 1502149-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-023

SAMPLE INFORMATION

Sample Number: 1502149-023
Location: 12
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/20/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 2/20/2015 10:31:51 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	10.7 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.69 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	118 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.03 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	133 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.25 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-023

SAMPLE INFORMATION

Sample Number: 1502149-023 Customer Sample Number:
Location: 12 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-024

SAMPLE INFORMATION

Sample Number: 1502149-024 Customer Sample Number:
Location: 12F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-025

SAMPLE INFORMATION

Sample Number: 1502149-025
Location: 13
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/20/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 2/20/2015 10:31:51 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	10.6 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.34 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	102 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.58 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	108 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.62 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-025

SAMPLE INFORMATION

Sample Number: 1502149-025 Customer Sample Number:
Location: 13 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-027

SAMPLE INFORMATION

Sample Number: 1502149-027 Customer Sample Number:
Location: 14 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-028

SAMPLE INFORMATION

Sample Number: 1502149-028 Customer Sample Number:
Location: 14F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: 2/20/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 2/20/2015 10:31:51 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.84 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.54 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	77.8 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.14 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-028

SAMPLE INFORMATION

Sample Number: 1502149-028 Customer Sample Number:
Location: 14F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-029

SAMPLE INFORMATION

Sample Number: 1502149-029
Location: 15
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
2/20/2015	7:00	CW/DC	2/20/2015 10:31:51 AM	JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.72 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	65.4 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.89 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	73.3 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.08 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-029

SAMPLE INFORMATION

Sample Number: 1502149-029
Location: 15
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/20/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 2/20/2015 10:31:51 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-030

SAMPLE INFORMATION

Sample Number: 1502149-030 Customer Sample Number:
Location: 15F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-031

SAMPLE INFORMATION

Sample Number: 1502149-031
Location: 16
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
2/20/2015	7:00	CW/DC	2/20/2015 10:31:51 AM	JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.64 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	58.0 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.56 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	65.5 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.93 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-031

SAMPLE INFORMATION

Sample Number: 1502149-031 Customer Sample Number:
Location: 16 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-032

SAMPLE INFORMATION

Sample Number: 1502149-032 Customer Sample Number:
Location: 16F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: 2/20/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 2/20/2015 10:31:51 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.50 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.17 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	60.7 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.44 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-032

SAMPLE INFORMATION

Sample Number: 1502149-032
Location: 16F
LPR 2914 45TH ST NW (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/20/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 2/20/2015 10:31:51 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-033

SAMPLE INFORMATION

Sample Number: 1502149-033
Location: 17
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
2/20/2015	7:00	CW/DC	2/20/2015 10:31:51 AM	JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.52 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	55.0 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.20 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	60.5 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.86 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-033

SAMPLE INFORMATION

Sample Number: 1502149-033 Customer Sample Number:
Location: 17 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-034

SAMPLE INFORMATION

Sample Number: 1502149-034
Location: 17F
LPR 2914 45TH ST NW (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/20/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 2/20/2015 10:31:51 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.48 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.89 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	57.5 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.49 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-034

SAMPLE INFORMATION

Sample Number: 1502149-034 Customer Sample Number:
Location: 17F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-035

SAMPLE INFORMATION

Sample Number: 1502149-035
Location: 18
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
2/20/2015	7:00	CW/DC	2/20/2015 10:31:51 AM	JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.38 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	55.5 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.73 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	54.2 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.66 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-035

SAMPLE INFORMATION

Sample Number: 1502149-035 Customer Sample Number:
Location: 18 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-037

SAMPLE INFORMATION

Sample Number: 1502149-037
Location: 19
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/20/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 2/20/2015 10:31:51 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.57 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	61.2 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.59 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	54.4 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.62 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-039

SAMPLE INFORMATION

Sample Number: 1502149-039
Location: 20
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
2/20/2015	7:00	CW/DC	2/20/2015 10:31:51 AM	JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.56 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	67.1 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.38 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	51.2 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.49 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-040

SAMPLE INFORMATION

Sample Number: 1502149-040 Customer Sample Number:
Location: 20F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: 2/20/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 2/20/2015 10:31:51 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.58 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.24 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	49.6 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.40 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-040

SAMPLE INFORMATION

Sample Number: 1502149-040 Customer Sample Number:
Location: 20F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-041

SAMPLE INFORMATION

Sample Number: 1502149-041
Location: H1
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/20/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 2/20/2015 10:31:51 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	15.3 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.23 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	196 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.36 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	99.9 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	6.96 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-041

SAMPLE INFORMATION

Sample Number: 1502149-041 Customer Sample Number:
Location: H1 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-042

SAMPLE INFORMATION

Sample Number: 1502149-042 Customer Sample Number:
Location: H2 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-043

SAMPLE INFORMATION

Sample Number: 1502149-043
Location: H3
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 2/20/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 2/20/2015 10:31:51 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	12.9 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.54 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	230 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.80 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	102 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.76 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-044

SAMPLE INFORMATION

Sample Number: 1502149-044 Customer Sample Number:
Location: H4 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: 2/20/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 2/20/2015 10:31:51 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	11.4 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.62 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	179 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.55 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	93.9 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.24 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-044

SAMPLE INFORMATION

Sample Number: 1502149-044 Customer Sample Number:
Location: H4 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-045

SAMPLE INFORMATION

Sample Number: 1502149-045 Customer Sample Number:
Location: H5 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: 2/20/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 2/20/2015 10:31:51 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	12.4 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.34 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	141 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.35 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	81.6 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.81 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-045

SAMPLE INFORMATION

Sample Number: 1502149-045 Customer Sample Number:
Location: H5 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-046

SAMPLE INFORMATION

Sample Number: 1502149-046 Customer Sample Number:
Location: H6 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: 2/20/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 2/20/2015 10:31:51 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	11.6 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.47 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	136 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.29 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	69.1 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.71 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-046

SAMPLE INFORMATION

Sample Number: 1502149-046 Customer Sample Number:
Location: H6 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-047

SAMPLE INFORMATION

Sample Number: 1502149-047 Customer Sample Number:
Location: H7 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-048

SAMPLE INFORMATION

Sample Number: 1502149-048 Customer Sample Number:
Location: H8 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-049

SAMPLE INFORMATION

Sample Number: 1502149-049 Customer Sample Number:
Location: H9 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: 2/20/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 2/20/2015 10:31:51 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	10.9 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.07 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	120 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.48 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	54.3 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.68 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-049

SAMPLE INFORMATION

Sample Number: 1502149-049 Customer Sample Number:
Location: H9 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-050

SAMPLE INFORMATION

Sample Number: 1502149-050 Customer Sample Number:
Location: H10 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-051

SAMPLE INFORMATION

Sample Number: 1502149-051 Customer Sample Number:
Location: H11 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: 2/20/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 2/20/2015 10:31:51 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	10.9 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.11 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	117 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.78 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	60.1 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.21 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-051

SAMPLE INFORMATION

Sample Number: 1502149-051 Customer Sample Number:
Location: H11 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-052

SAMPLE INFORMATION

Sample Number: 1502149-052 Customer Sample Number:
Location: H12 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-054

SAMPLE INFORMATION

Sample Number: 1502149-054 Customer Sample Number:
Location: H14 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-055

SAMPLE INFORMATION

Sample Number: 1502149-055 Customer Sample Number:
Location: H15 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-057

SAMPLE INFORMATION

Sample Number: 1502149-057 Customer Sample Number:
Location: H17 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-058

SAMPLE INFORMATION

Sample Number: 1502149-058 Customer Sample Number:
Location: H18 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-059

SAMPLE INFORMATION

Sample Number: 1502149-059 Customer Sample Number:
Location: H19 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: 2/20/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 2/20/2015 10:31:51 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	10.8 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.84 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	109 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.02 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	40.6 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.15 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-059

SAMPLE INFORMATION

Sample Number: 1502149-059 Customer Sample Number:
Location: H19 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1502149-060

SAMPLE INFORMATION

Sample Number: 1502149-060 Customer Sample Number:
Location: H20 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
2/20/2015 7:00 CW/DC 2/20/2015 10:31:51 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-001

SAMPLE INFORMATION

Sample Number: 1503040-001
Location: 01
LPR 3755 MCKINLEY ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 3/3/2015 Collection Time: 7:00 Sampler: CW/DVC Received Date and Time: 3/6/2015 11:36:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	13.5 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.76 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	103 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	86.8 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	743 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	123 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-001

SAMPLE INFORMATION

Sample Number: 1503040-001 Customer Sample Number:
Location: 01 Type: Dist.
LPR 3755 MCKINLEY ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/3/2015 7:00 CW/DVC 3/6/2015 11:36:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-002

SAMPLE INFORMATION

Sample Number: 1503040-002 Customer Sample Number:
Location: 01F Type: Dist.
LPR 3755 MCKINLEY ST NW (FILTERED)
Collection Date: 3/3/2015 Collection Time: 7:00 Sampler: CW/DVC Received Date and Time: 3/6/2015 11:36:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	61.2 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	224 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.08 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-002

SAMPLE INFORMATION

Sample Number: 1503040-002 Customer Sample Number:
Location: 01F Type: Dist.
LPR 3755 MCKINLEY ST NW (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/3/2015 7:00 CW/DVC 3/6/2015 11:36:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-003

SAMPLE INFORMATION

Sample Number: 1503040-003 Customer Sample Number:
Location: 02 Type: Dist.
LPR 3755 MCKINLEY ST NW (UNFILTERED)
Collection Date: 3/3/2015 Collection Time: 7:00 Sampler: CW/DVC Received Date and Time: 3/6/2015 11:36:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.54 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	91.4 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	69.3 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	34.4 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.11 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-003

SAMPLE INFORMATION

Sample Number: 1503040-003 Customer Sample Number:
Location: 02 Type: Dist.
LPR 3755 MCKINLEY ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/3/2015 7:00 CW/DVC 3/6/2015 11:36:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-004

SAMPLE INFORMATION

Sample Number: 1503040-004 Customer Sample Number:
Location: 02F Type: Dist.
LPR 3755 MCKINLEY ST NW (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/3/2015 7:00 CW/DVC 3/6/2015 11:36:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-005

SAMPLE INFORMATION

Sample Number: 1503040-005 Customer Sample Number:
Location: 03 Type: Dist.
LPR 3755 MCKINLEY ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/3/2015 7:00 CW/DVC 3/6/2015 11:36:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-006

SAMPLE INFORMATION

Sample Number: 1503040-006 Customer Sample Number:
Location: 03F Type: Dist.
LPR 3755 MCKINLEY ST NW (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/3/2015 7:00 CW/DVC 3/6/2015 11:36:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-008

SAMPLE INFORMATION

Sample Number: 1503040-008 Customer Sample Number:
Location: 04F Type: Dist.
LPR 3755 MCKINLEY ST NW (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/3/2015 7:00 CW/DVC 3/6/2015 11:36:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-009

SAMPLE INFORMATION

Sample Number: 1503040-009
Location: 05
LPR 3755 MCKINLEY ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 3/3/2015 Collection Time: 7:00 Sampler: CW/DVC Received Date and Time: 3/6/2015 11:36:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	13.8 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	81.6 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	22.1 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	15.0 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-009

SAMPLE INFORMATION

Sample Number: 1503040-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 3755 MCKINLEY ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/3/2015 7:00 CW/DVC 3/6/2015 11:36:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-010

SAMPLE INFORMATION

Sample Number: 1503040-010 Customer Sample Number:
Location: 05F Type: Dist.
LPR 3755 MCKINLEY ST NW (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/3/2015 7:00 CW/DVC 3/6/2015 11:36:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-011

SAMPLE INFORMATION

Sample Number: 1503040-011 Customer Sample Number:
Location: 06 Type: Dist.
LPR 3755 MCKINLEY ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/3/2015 7:00 CW/DVC 3/6/2015 11:36:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-012

SAMPLE INFORMATION

Sample Number: 1503040-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 3755 MCKINLEY ST NW (FILTERED)
Collection Date: 3/3/2015 Collection Time: 7:00 Sampler: CW/DVC Received Date and Time: 3/6/2015 11:36:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.18 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	16.4 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	15.7 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-012

SAMPLE INFORMATION

Sample Number: 1503040-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 3755 MCKINLEY ST NW (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/3/2015 7:00 CW/DVC 3/6/2015 11:36:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-013

SAMPLE INFORMATION

Sample Number: 1503040-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 3755 MCKINLEY ST NW (UNFILTERED)
Collection Date: 3/3/2015 Collection Time: 7:00 Sampler: CW/DVC Received Date and Time: 3/6/2015 11:36:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	10.9 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.01 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	89.7 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	11.7 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	12.9 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	10.6 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-013

SAMPLE INFORMATION

Sample Number: 1503040-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 3755 MCKINLEY ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/3/2015 7:00 CW/DVC 3/6/2015 11:36:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-014

SAMPLE INFORMATION

Sample Number: 1503040-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 3755 MCKINLEY ST NW (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/3/2015 7:00 CW/DVC 3/6/2015 11:36:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-015

SAMPLE INFORMATION

Sample Number: 1503040-015 Customer Sample Number:
Location: 08 Type: Dist.
LPR 3755 MCKINLEY ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/3/2015 7:00 CW/DVC 3/6/2015 11:36:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.82 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	83.6 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.69 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	10.3 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	14.0 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-015

SAMPLE INFORMATION

Sample Number: 1503040-015 Customer Sample Number:
Location: 08 Type: Dist.
LPR 3755 MCKINLEY ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/3/2015 7:00 CW/DVC 3/6/2015 11:36:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-016

SAMPLE INFORMATION

Sample Number: 1503040-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 3755 MCKINLEY ST NW (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/3/2015 7:00 CW/DVC 3/6/2015 11:36:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-017

SAMPLE INFORMATION

Sample Number: 1503040-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 3755 MCKINLEY ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/3/2015 7:00 CW/DVC 3/6/2015 11:36:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-018

SAMPLE INFORMATION

Sample Number: 1503040-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 3755 MCKINLEY ST NW (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/3/2015 7:00 CW/DVC 3/6/2015 11:36:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-019

SAMPLE INFORMATION

Sample Number: 1503040-019 Customer Sample Number:
Location: 10 Type: Dist.
LPR 3755 MCKINLEY ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/3/2015 7:00 CW/DVC 3/6/2015 11:36:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-020

SAMPLE INFORMATION

Sample Number: 1503040-020 Customer Sample Number:
Location: 10F Type: Dist.
LPR 3755 MCKINLEY ST NW (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/3/2015 7:00 CW/DVC 3/6/2015 11:36:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-021

SAMPLE INFORMATION

Sample Number: 1503040-021 Customer Sample Number:
Location: 11 Type: Dist.
LPR 3755 MCKINLEY ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/3/2015 7:00 CW/DVC 3/6/2015 11:36:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-022

SAMPLE INFORMATION

Sample Number: 1503040-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 3755 MCKINLEY ST NW (FILTERED)
Collection Date: 3/3/2015 Collection Time: 7:00 Sampler: CW/DVC Received Date and Time: 3/6/2015 11:36:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.60 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	6.82 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	9.33 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.45 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-022

SAMPLE INFORMATION

Sample Number: 1503040-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 3755 MCKINLEY ST NW (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/3/2015 7:00 CW/DVC 3/6/2015 11:36:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-023

SAMPLE INFORMATION

Sample Number: 1503040-023 Customer Sample Number:
Location: 12 Type: Dist.
LPR 3755 MCKINLEY ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/3/2015 7:00 CW/DVC 3/6/2015 11:36:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-024

SAMPLE INFORMATION

Sample Number: 1503040-024 Customer Sample Number:
Location: 12F Type: Dist.
LPR 3755 MCKINLEY ST NW (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/3/2015 7:00 CW/DVC 3/6/2015 11:36:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-025

SAMPLE INFORMATION

Sample Number: 1503040-025 Customer Sample Number:
Location: H1 Type: Dist.
LPR 3755 MCKINLEY ST NW (UNFILTERED)
Collection Date: 3/3/2015 Collection Time: 7:00 Sampler: CW/DVC Received Date and Time: 3/6/2015 11:36:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	10.3 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.35 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	98.1 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	25.2 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	46.1 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.38 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-026

SAMPLE INFORMATION

Sample Number: 1503040-026 Customer Sample Number:
Location: H2 Type: Dist.
LPR 3755 MCKINLEY ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/3/2015 7:00 CW/DVC 3/6/2015 11:36:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-027

SAMPLE INFORMATION

Sample Number: 1503040-027 Customer Sample Number:
Location: H3 Type: Dist.
LPR 3755 MCKINLEY ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/3/2015 7:00 CW/DVC 3/6/2015 11:36:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-028

SAMPLE INFORMATION

Sample Number: 1503040-028 Customer Sample Number:
Location: H4 Type: Dist.
LPR 3755 MCKINLEY ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/3/2015 7:00 CW/DVC 3/6/2015 11:36:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-029

SAMPLE INFORMATION

Sample Number: 1503040-029 Customer Sample Number:
Location: H5 Type: Dist.
LPR 3755 MCKINLEY ST NW (UNFILTERED)
Collection Date: 3/3/2015 Collection Time: 7:00 Sampler: CW/DVC Received Date and Time: 3/6/2015 11:36:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	10.2 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.43 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	101 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	19.3 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	59.0 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.69 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-029

SAMPLE INFORMATION

Sample Number: 1503040-029 Customer Sample Number:
Location: H5 Type: Dist.
LPR 3755 MCKINLEY ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/3/2015 7:00 CW/DVC 3/6/2015 11:36:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-030

SAMPLE INFORMATION

Sample Number: 1503040-030 Customer Sample Number:
Location: H6 Type: Dist.
LPR 3755 MCKINLEY ST NW (UNFILTERED)
Collection Date: 3/3/2015 Collection Time: 7:00 Sampler: CW/DVC Received Date and Time: 3/6/2015 11:36:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.51 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	104 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	15.5 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	18.8 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.0 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-030

SAMPLE INFORMATION

Sample Number: 1503040-030 Customer Sample Number:
Location: H6 Type: Dist.
LPR 3755 MCKINLEY ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/3/2015 7:00 CW/DVC 3/6/2015 11:36:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-031

SAMPLE INFORMATION

Sample Number: 1503040-031 Customer Sample Number:
Location: H7 Type: Dist.
LPR 3755 MCKINLEY ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/3/2015 7:00 CW/DVC 3/6/2015 11:36:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-032

SAMPLE INFORMATION

Sample Number: 1503040-032 Customer Sample Number:
Location: H8 Type: Dist.
LPR 3755 MCKINLEY ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/3/2015 7:00 CW/DVC 3/6/2015 11:36:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-034

SAMPLE INFORMATION

Sample Number: 1503040-034 Customer Sample Number:
Location: H10 Type: Dist.
LPR 3755 MCKINLEY ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/3/2015 7:00 CW/DVC 3/6/2015 11:36:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-035

SAMPLE INFORMATION

Sample Number: 1503040-035 Customer Sample Number:
Location: H11 Type: Dist.
LPR 3755 MCKINLEY ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/3/2015 7:00 CW/DVC 3/6/2015 11:36:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503040-036

SAMPLE INFORMATION

Sample Number: 1503040-036 Customer Sample Number:
Location: H12 Type: Dist.
LPR 3755 MCKINLEY ST NW (UNFILTERED)
Collection Date: 3/3/2015 Collection Time: 7:00 Sampler: CW/DVC Received Date and Time: 3/6/2015 11:36:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	10.7 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.83 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	144 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.52 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	11.0 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-001

SAMPLE INFORMATION

Sample Number: 1503099-001
Location: 01
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 3/13/2015 Collection Time: 8:00 Sampler: IC/ CW Received Date and Time: 3/13/2015 12:43:31 PM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	24.7 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.59 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	29.7 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.24 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	36.2 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-001

SAMPLE INFORMATION

Sample Number: 1503099-001
Location: 01
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 3/13/2015 Collection Time: 8:00 Sampler: IC/ CW Received Date and Time: 3/13/2015 12:43:31 PM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-003

SAMPLE INFORMATION

Sample Number: 1503099-003
Location: 02
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 3/13/2015 Collection Time: 8:00 Sampler: IC/ CW Received Date and Time: 3/13/2015 12:43:31 PM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	18.9 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.69 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	33.1 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.20 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	9.38 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.0 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-003

SAMPLE INFORMATION

Sample Number: 1503099-003
Location: 02
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 3/13/2015 Collection Time: 8:00 Sampler: IC/ CW Received Date and Time: 3/13/2015 12:43:31 PM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-004

SAMPLE INFORMATION

Sample Number: 1503099-004 Customer Sample Number:
Location: 02F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/13/2015 8:00 IC/ CW 3/13/2015 12:43:31 PM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-005

SAMPLE INFORMATION

Sample Number: 1503099-005
Location: 03
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 3/13/2015 Collection Time: 8:00 Sampler: IC/ CW Received Date and Time: 3/13/2015 12:43:31 PM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	17.4 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.70 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	33.5 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.25 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.17 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.57 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-005

SAMPLE INFORMATION

Sample Number: 1503099-005
Location: 03
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 3/13/2015 Collection Time: 8:00 Sampler: IC/ CW Received Date and Time: 3/13/2015 12:43:31 PM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-006

SAMPLE INFORMATION

Sample Number: 1503099-006 Customer Sample Number:
Location: 03F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/13/2015 8:00 IC/ CW 3/13/2015 12:43:31 PM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-007

SAMPLE INFORMATION

Sample Number: 1503099-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 3/13/2015 Collection Time: 8:00 Sampler: IC/ CW Received Date and Time: 3/13/2015 12:43:31 PM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	32.8 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.64 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	31.6 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.59 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	29.6 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.07 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-007

SAMPLE INFORMATION

Sample Number: 1503099-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/13/2015 8:00 IC/ CW 3/13/2015 12:43:31 PM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-008

SAMPLE INFORMATION

Sample Number: 1503099-008 Customer Sample Number:
Location: 04F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/13/2015 8:00 IC/ CW 3/13/2015 12:43:31 PM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-009

SAMPLE INFORMATION

Sample Number: 1503099-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/13/2015 8:00 IC/ CW 3/13/2015 12:43:31 PM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-010

SAMPLE INFORMATION

Sample Number: 1503099-010 Customer Sample Number:
Location: 05F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: 3/13/2015 Collection Time: 8:00 Sampler: IC/ CW Received Date and Time: 3/13/2015 12:43:31 PM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-011

SAMPLE INFORMATION

Sample Number: 1503099-011
Location: 06
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 3/13/2015 Collection Time: 8:00 Sampler: IC/ CW Received Date and Time: 3/13/2015 12:43:31 PM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	20.6 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.79 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	39.2 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.48 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.67 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.12 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-011

SAMPLE INFORMATION

Sample Number: 1503099-011 Customer Sample Number:
Location: 06 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/13/2015 8:00 IC/ CW 3/13/2015 12:43:31 PM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-012

SAMPLE INFORMATION

Sample Number: 1503099-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/13/2015 8:00 IC/ CW 3/13/2015 12:43:31 PM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-013

SAMPLE INFORMATION

Sample Number: 1503099-013
Location: 07
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 3/13/2015 Collection Time: 8:00 Sampler: IC/ CW Received Date and Time: 3/13/2015 12:43:31 PM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	18.3 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.16 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	41.1 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.74 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	9.87 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.08 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-014

SAMPLE INFORMATION

Sample Number: 1503099-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: 3/13/2015 Collection Time: 8:00 Sampler: IC/ CW Received Date and Time: 3/13/2015 12:43:31 PM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-015

SAMPLE INFORMATION

Sample Number: 1503099-015
Location: 08
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
3/13/2015	8:00	IC/ CW	3/13/2015 12:43:31 PM	TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	15.9 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.00 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	43.0 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.06 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	9.11 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.46 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-016

SAMPLE INFORMATION

Sample Number: 1503099-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: 3/13/2015 Collection Time: 8:00 Sampler: IC/ CW Received Date and Time: 3/13/2015 12:43:31 PM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.07 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.91 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	10.5 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.90 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-017

SAMPLE INFORMATION

Sample Number: 1503099-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/13/2015 8:00 IC/ CW 3/13/2015 12:43:31 PM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-018

SAMPLE INFORMATION

Sample Number: 1503099-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: 3/13/2015 Collection Time: 8:00 Sampler: IC/ CW Received Date and Time: 3/13/2015 12:43:31 PM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.82 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.35 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.09 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.62 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-018

SAMPLE INFORMATION

Sample Number: 1503099-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/13/2015 8:00 IC/ CW 3/13/2015 12:43:31 PM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-019

SAMPLE INFORMATION

Sample Number: 1503099-019
Location: 10
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 3/13/2015 Collection Time: 8:00 Sampler: IC/ CW Received Date and Time: 3/13/2015 12:43:31 PM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	16.8 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.72 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	43.3 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.07 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.68 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.95 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-019

SAMPLE INFORMATION

Sample Number: 1503099-019
Location: 10
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 3/13/2015 Collection Time: 8:00 Sampler: IC/ CW Received Date and Time: 3/13/2015 12:43:31 PM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-020

SAMPLE INFORMATION

Sample Number: 1503099-020 Customer Sample Number:
Location: 10F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: 3/13/2015 Collection Time: 8:00 Sampler: IC/ CW Received Date and Time: 3/13/2015 12:43:31 PM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.72 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.81 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	6.54 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.39 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-021

SAMPLE INFORMATION

Sample Number: 1503099-021
Location: 11
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 3/13/2015 Collection Time: 8:00 Sampler: IC/ CW Received Date and Time: 3/13/2015 12:43:31 PM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	17.6 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.36 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	43.3 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.75 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.62 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.42 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-021

SAMPLE INFORMATION

Sample Number: 1503099-021
Location: 11
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 3/13/2015 Collection Time: 8:00 Sampler: IC/ CW Received Date and Time: 3/13/2015 12:43:31 PM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-023

SAMPLE INFORMATION

Sample Number: 1503099-023
Location: 12
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 3/13/2015 Collection Time: 8:00 Sampler: IC/ CW Received Date and Time: 3/13/2015 12:43:31 PM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	16.9 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.69 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	44.6 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.72 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.06 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.46 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-023

SAMPLE INFORMATION

Sample Number: 1503099-023 Customer Sample Number:
Location: 12 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/13/2015 8:00 IC/ CW 3/13/2015 12:43:31 PM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-025

SAMPLE INFORMATION

Sample Number: 1503099-025
Location: 13
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 3/13/2015 Collection Time: 8:00 Sampler: IC/ CW Received Date and Time: 3/13/2015 12:43:31 PM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	17.8 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.97 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	45.2 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.69 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.42 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.47 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-025

SAMPLE INFORMATION

Sample Number: 1503099-025 Customer Sample Number:
Location: 13 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/13/2015 8:00 IC/ CW 3/13/2015 12:43:31 PM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-026

SAMPLE INFORMATION

Sample Number: 1503099-026 Customer Sample Number:
Location: 13F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/13/2015 8:00 IC/ CW 3/13/2015 12:43:31 PM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-027

SAMPLE INFORMATION

Sample Number: 1503099-027
Location: 14
LPR 3815 5TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 3/13/2015 Collection Time: 8:00 Sampler: IC/ CW Received Date and Time: 3/13/2015 12:43:31 PM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	19.4 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.81 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	45.1 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.30 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.32 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.33 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-027

SAMPLE INFORMATION

Sample Number: 1503099-027 Customer Sample Number:
Location: 14 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/13/2015 8:00 IC/ CW 3/13/2015 12:43:31 PM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-028

SAMPLE INFORMATION

Sample Number: 1503099-028 Customer Sample Number:
Location: 14F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/13/2015 8:00 IC/ CW 3/13/2015 12:43:31 PM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-029

SAMPLE INFORMATION

Sample Number: 1503099-029
Location: 15
LPR 3815 5TH ST NW UNFILTERED
Customer Sample Number:
Type: Dist.

Collection Date: 3/13/2015
Collection Time: 8:00
Sampler: IC/ CW
Received Date and Time: 3/13/2015 12:43:31 PM
Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	20.1 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.68 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	44.5 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.12 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.42 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-029

SAMPLE INFORMATION

Sample Number: 1503099-029 Customer Sample Number:
Location: 15 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/13/2015 8:00 IC/ CW 3/13/2015 12:43:31 PM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-030

SAMPLE INFORMATION

Sample Number: 1503099-030 Customer Sample Number:
Location: 15F Type: Dist.
LPR 3815 5TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/13/2015 8:00 IC/ CW 3/13/2015 12:43:31 PM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-031

SAMPLE INFORMATION

Sample Number: 1503099-031 Customer Sample Number:
Location: H1 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 3/13/2015 Collection Time: 8:00 Sampler: IC/ CW Received Date and Time: 3/13/2015 12:43:31 PM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	251 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.89 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	110 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.19 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	17.5 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.38 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-033

SAMPLE INFORMATION

Sample Number: 1503099-033 Customer Sample Number:
Location: H3 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/13/2015 8:00 IC/ CW 3/13/2015 12:43:31 PM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-034

SAMPLE INFORMATION

Sample Number: 1503099-034 Customer Sample Number:
Location: H4 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED

Collection Date: 3/13/2015 Collection Time: 8:00 Sampler: IC/ CW Received Date and Time: 3/13/2015 12:43:31 PM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	44.9 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.73 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	53.3 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.22 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	6.38 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.70 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-034

SAMPLE INFORMATION

Sample Number: 1503099-034 Customer Sample Number:
Location: H4 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/13/2015 8:00 IC/ CW 3/13/2015 12:43:31 PM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-035

SAMPLE INFORMATION

Sample Number: 1503099-035 Customer Sample Number:
Location: H5 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 3/13/2015 Collection Time: 8:00 Sampler: IC/ CW Received Date and Time: 3/13/2015 12:43:31 PM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	49.8 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.77 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	53.5 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.20 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	15.5 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.93 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-035

SAMPLE INFORMATION

Sample Number: 1503099-035 Customer Sample Number:
Location: H5 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/13/2015 8:00 IC/ CW 3/13/2015 12:43:31 PM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-036

SAMPLE INFORMATION

Sample Number: 1503099-036 Customer Sample Number:
Location: H6 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 3/13/2015 Collection Time: 8:00 Sampler: IC/ CW Received Date and Time: 3/13/2015 12:43:31 PM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	36.9 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.67 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	49.5 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.11 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.03 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.12 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-036

SAMPLE INFORMATION

Sample Number: 1503099-036 Customer Sample Number:
Location: H6 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/13/2015 8:00 IC/ CW 3/13/2015 12:43:31 PM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-037

SAMPLE INFORMATION

Sample Number: 1503099-037 Customer Sample Number:
Location: H7 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 3/13/2015 Collection Time: 8:00 Sampler: IC/ CW Received Date and Time: 3/13/2015 12:43:31 PM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	32.6 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.63 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	47.5 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.09 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.41 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.05 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-038

SAMPLE INFORMATION

Sample Number: 1503099-038 Customer Sample Number:
Location: H8 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 3/13/2015 Collection Time: 8:00 Sampler: IC/ CW Received Date and Time: 3/13/2015 12:43:31 PM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	33.2 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.73 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	49.9 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.51 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.38 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.30 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-039

SAMPLE INFORMATION

Sample Number: 1503099-039 Customer Sample Number:
Location: H9 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 3/13/2015 Collection Time: 8:00 Sampler: IC/ CW Received Date and Time: 3/13/2015 12:43:31 PM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	31.0 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.65 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	46.2 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.11 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.37 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.27 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-039

SAMPLE INFORMATION

Sample Number: 1503099-039 Customer Sample Number:
Location: H9 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/13/2015 8:00 IC/ CW 3/13/2015 12:43:31 PM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-040

SAMPLE INFORMATION

Sample Number: 1503099-040 Customer Sample Number:
Location: H10 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 3/13/2015 Collection Time: 8:00 Sampler: IC/ CW Received Date and Time: 3/13/2015 12:43:31 PM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	31.2 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.63 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	44.6 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.98 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.89 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.02 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-040

SAMPLE INFORMATION

Sample Number: 1503099-040 Customer Sample Number:
Location: H10 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/13/2015 8:00 IC/ CW 3/13/2015 12:43:31 PM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-041

SAMPLE INFORMATION

Sample Number: 1503099-041 Customer Sample Number:
Location: H11 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 3/13/2015 Collection Time: 8:00 Sampler: IC/ CW Received Date and Time: 3/13/2015 12:43:31 PM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	28.9 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.63 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	45.1 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.88 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.30 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.18 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-041

SAMPLE INFORMATION

Sample Number: 1503099-041 Customer Sample Number:
Location: H11 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/13/2015 8:00 IC/ CW 3/13/2015 12:43:31 PM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-042

SAMPLE INFORMATION

Sample Number: 1503099-042 Customer Sample Number:
Location: H12 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 3/13/2015 Collection Time: 8:00 Sampler: IC/ CW Received Date and Time: 3/13/2015 12:43:31 PM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	28.7 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.61 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	52.6 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.32 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.93 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.11 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-042

SAMPLE INFORMATION

Sample Number: 1503099-042 Customer Sample Number:
Location: H12 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/13/2015 8:00 IC/ CW 3/13/2015 12:43:31 PM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-043

SAMPLE INFORMATION

Sample Number: 1503099-043 Customer Sample Number:
Location: H13 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/13/2015 8:00 IC/ CW 3/13/2015 12:43:31 PM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-044

SAMPLE INFORMATION

Sample Number: 1503099-044 Customer Sample Number:
Location: H14 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/13/2015 8:00 IC/ CW 3/13/2015 12:43:31 PM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-045

SAMPLE INFORMATION

Sample Number: 1503099-045 Customer Sample Number:
Location: H15 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: 3/13/2015 Collection Time: 8:00 Sampler: IC/ CW Received Date and Time: 3/13/2015 12:43:31 PM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	28.5 ug/L	3/23/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.64 ug/L	3/23/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	44.8 ug/L	3/23/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.18 ug/L	3/23/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.65 ug/L	3/23/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	3/23/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/1/2015
Report Number: M- W1503099-045

SAMPLE INFORMATION

Sample Number: 1503099-045 Customer Sample Number:
Location: H15 Type: Dist.
LPR 3815 5TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/13/2015 8:00 IC/ CW 3/13/2015 12:43:31 PM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/1/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 4/24/2015
Report Number: M- W1504027-001

SAMPLE INFORMATION

Sample Number: 1504027-001 Customer Sample Number:
Location: 1 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/31/2015 7:00 CW/DC 4/3/2015 11:04:22 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-002

SAMPLE INFORMATION

Sample Number: 1504027-002 Customer Sample Number:
Location: 1F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 3/31/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 4/3/2015 11:04:22 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/24/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-003

SAMPLE INFORMATION

Sample Number: 1504027-003
Location: 02
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 3/31/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 4/3/2015 11:04:22 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	16.6 ug/L	4/6/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	4/6/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	4/6/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.67 ug/L	4/6/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.02 ug/L	4/6/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.48 ug/L	4/6/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-003

SAMPLE INFORMATION


Sample Number: 1504027-003
Location: 02
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 3/31/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 4/3/2015 11:04:22 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 4/24/2015
Report Number: M- W1504027-004

SAMPLE INFORMATION

Sample Number: 1504027-004 Customer Sample Number:
Location: 02F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/31/2015 7:00 CW/DC 4/3/2015 11:04:22 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-005

SAMPLE INFORMATION

Sample Number: 1504027-005
Location: 03
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
3/31/2015	7:00	CW/DC	4/3/2015 11:04:22 AM	LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	16.9 ug/L	4/6/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	4/6/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	4/6/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.46 ug/L	4/6/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	6.19 ug/L	4/6/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.57 ug/L	4/6/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-005

SAMPLE INFORMATION


Sample Number: 1504027-005
Location: 03
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 3/31/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 4/3/2015 11:04:22 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 4/24/2015
Report Number: M- W1504027-007

SAMPLE INFORMATION

Sample Number: 1504027-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/31/2015 7:00 CW/DC 4/3/2015 11:04:22 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-008

SAMPLE INFORMATION

Sample Number: 1504027-008 Customer Sample Number:
Location: 04F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 3/31/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 4/3/2015 11:04:22 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	14.7 ug/L	4/6/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	4/6/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	4/6/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.78 ug/L	4/6/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	6.58 ug/L	4/6/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	4/6/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 4/24/2015
Report Number: M- W1504027-008

SAMPLE INFORMATION

Sample Number: 1504027-008 Customer Sample Number:
Location: 04F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/31/2015 7:00 CW/DC 4/3/2015 11:04:22 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-009

SAMPLE INFORMATION

Sample Number: 1504027-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: 3/31/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 4/3/2015 11:04:22 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	16.4 ug/L	4/6/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	4/6/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	4/6/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.17 ug/L	4/6/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.83 ug/L	4/6/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.92 ug/L	4/6/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 4/24/2015
Report Number: M- W1504027-010

SAMPLE INFORMATION

Sample Number: 1504027-010 Customer Sample Number:
Location: 05F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/31/2015 7:00 CW/DC 4/3/2015 11:04:22 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-011

SAMPLE INFORMATION

Sample Number: 1504027-011
Location: 06
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
3/31/2015	7:00	CW/DC	4/3/2015 11:04:22 AM	LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	15.4 ug/L	4/6/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	4/6/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	4/6/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	9.04 ug/L	4/6/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	6.45 ug/L	4/6/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.13 ug/L	4/6/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-011

SAMPLE INFORMATION


Sample Number: 1504027-011
Location: 06
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 3/31/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 4/3/2015 11:04:22 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 4/24/2015
Report Number: M- W1504027-012

SAMPLE INFORMATION

Sample Number: 1504027-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 3/31/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 4/3/2015 11:04:22 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-013

SAMPLE INFORMATION

Sample Number: 1504027-013
Location: 07
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
3/31/2015	7:00	CW/DC	4/3/2015 11:04:22 AM	LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	13.4 ug/L	4/6/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	4/6/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	4/6/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	10.2 ug/L	4/6/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.02 ug/L	4/6/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.27 ug/L	4/6/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-013

SAMPLE INFORMATION


Sample Number: 1504027-013
Location: 07
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 3/31/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 4/3/2015 11:04:22 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 4/24/2015
Report Number: M- W1504027-014

SAMPLE INFORMATION

Sample Number: 1504027-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/31/2015 7:00 CW/DC 4/3/2015 11:04:22 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-015

SAMPLE INFORMATION

Sample Number: 1504027-015
Location: 08
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
3/31/2015	7:00	CW/DC	4/3/2015 11:04:22 AM	LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	12.0 ug/L	4/6/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	4/6/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	4/6/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.56 ug/L	4/6/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	6.14 ug/L	4/6/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.34 ug/L	4/6/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-015

SAMPLE INFORMATION


Sample Number: 1504027-015
Location: 08
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 3/31/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 4/3/2015 11:04:22 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-016

SAMPLE INFORMATION

Sample Number: 1504027-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/31/2015 7:00 CW/DC 4/3/2015 11:04:22 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:

Robert P. Hoffa

Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-017

SAMPLE INFORMATION


Sample Number: 1504027-017
Location: 09
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 3/31/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 4/3/2015 11:04:22 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 4/24/2015
Report Number: M- W1504027-018

SAMPLE INFORMATION

Sample Number: 1504027-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/31/2015 7:00 CW/DC 4/3/2015 11:04:22 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-019

SAMPLE INFORMATION

Sample Number: 1504027-019
Location: 10
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
3/31/2015	7:00	CW/DC	4/3/2015 11:04:22 AM	LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	11.7 ug/L	4/6/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	4/6/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	4/6/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	6.13 ug/L	4/6/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	9.79 ug/L	4/6/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.54 ug/L	4/6/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-019

SAMPLE INFORMATION


Sample Number: 1504027-019
Location: 10
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 3/31/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 4/3/2015 11:04:22 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 4/24/2015
Report Number: M- W1504027-020

SAMPLE INFORMATION

Sample Number: 1504027-020 Customer Sample Number:
Location: 10F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/31/2015 7:00 CW/DC 4/3/2015 11:04:22 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-021

SAMPLE INFORMATION


Sample Number: 1504027-021
Location: 11
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 3/31/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 4/3/2015 11:04:22 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-023

SAMPLE INFORMATION

Sample Number: 1504027-023
Location: 12
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
3/31/2015	7:00	CW/DC	4/3/2015 11:04:22 AM	LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	11.7 ug/L	4/6/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	4/6/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	4/6/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.30 ug/L	4/6/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	17.0 ug/L	4/6/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.76 ug/L	4/6/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-023

SAMPLE INFORMATION


Sample Number: 1504027-023
Location: 12
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 3/31/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 4/3/2015 11:04:22 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 4/24/2015
Report Number: M- W1504027-024

SAMPLE INFORMATION

Sample Number: 1504027-024 Customer Sample Number:
Location: 12F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/31/2015 7:00 CW/DC 4/3/2015 11:04:22 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-025

SAMPLE INFORMATION

Sample Number: 1504027-025
Location: 13
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 3/31/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 4/3/2015 11:04:22 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	12.3 ug/L	4/6/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	4/6/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	4/6/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	6.87 ug/L	4/6/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	13.4 ug/L	4/6/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.32 ug/L	4/6/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-025

SAMPLE INFORMATION


Sample Number: 1504027-025
Location: 13
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 3/31/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 4/3/2015 11:04:22 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 4/24/2015
Report Number: M- W1504027-026

SAMPLE INFORMATION

Sample Number: 1504027-026 Customer Sample Number:
Location: 13F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/31/2015 7:00 CW/DC 4/3/2015 11:04:22 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-027

SAMPLE INFORMATION

Sample Number: 1504027-027
Location: 14
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 3/31/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 4/3/2015 11:04:22 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	12.7 ug/L	4/6/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	4/6/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	4/6/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.58 ug/L	4/6/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	8.86 ug/L	4/6/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.04 ug/L	4/6/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 4/24/2015
Report Number: M- W1504027-027

SAMPLE INFORMATION

Sample Number: 1504027-027
Location: 14
LPR 411 7TH ST NE (UNFILTERED)
Customer Sample Number:
Type: Dist.
Collection Date: 3/31/2015
Collection Time: 7:00
Sampler: CW/DC
Received Date and Time: 4/3/2015 11:04:22 AM
Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 4/24/2015
Report Number: M- W1504027-028

SAMPLE INFORMATION

Sample Number: 1504027-028 Customer Sample Number:
Location: 14F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/31/2015 7:00 CW/DC 4/3/2015 11:04:22 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-029

SAMPLE INFORMATION

Sample Number: 1504027-029
Location: 15
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 3/31/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 4/3/2015 11:04:22 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	13.1 ug/L	4/6/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	4/6/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	4/6/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.00 ug/L	4/6/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	6.58 ug/L	4/6/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.68 ug/L	4/6/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-029

SAMPLE INFORMATION


Sample Number: 1504027-029
Location: 15
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 3/31/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 4/3/2015 11:04:22 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 4/24/2015
Report Number: M- W1504027-030

SAMPLE INFORMATION

Sample Number: 1504027-030 Customer Sample Number:
Location: 15F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/31/2015 7:00 CW/DC 4/3/2015 11:04:22 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-031

SAMPLE INFORMATION

Sample Number: 1504027-031
Location: 16
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
3/31/2015	7:00	CW/DC	4/3/2015 11:04:22 AM	LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	13.4 ug/L	4/6/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	4/6/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	4/6/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.57 ug/L	4/6/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.20 ug/L	4/6/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.25 ug/L	4/6/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-031

SAMPLE INFORMATION


Sample Number: 1504027-031
Location: 16
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 3/31/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 4/3/2015 11:04:22 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-032

SAMPLE INFORMATION

Sample Number: 1504027-032 Customer Sample Number:
Location: 16F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 3/31/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 4/3/2015 11:04:22 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	11.7 ug/L	4/6/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	4/6/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	4/6/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.12 ug/L	4/6/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	6.90 ug/L	4/6/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	4/6/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 4/24/2015
Report Number: M- W1504027-032

SAMPLE INFORMATION

Sample Number: 1504027-032 Customer Sample Number:
Location: 16F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/31/2015 7:00 CW/DC 4/3/2015 11:04:22 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-033

SAMPLE INFORMATION

Sample Number: 1504027-033
Location: 17
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 3/31/2015	Collection Time: 7:00	Sampler: CW/DC	Received Date and Time: 4/3/2015 11:04:22 AM	Received By: LGallimore
-------------------------------	--------------------------	-------------------	---	----------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	13.5 ug/L	4/6/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	4/6/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	4/6/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.35 ug/L	4/6/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.42 ug/L	4/6/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	4/6/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 4/24/2015
Report Number: M- W1504027-033

SAMPLE INFORMATION

Sample Number: 1504027-033 Customer Sample Number:
Location: 17 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/31/2015 7:00 CW/DC 4/3/2015 11:04:22 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 4/24/2015
Report Number: M- W1504027-034

SAMPLE INFORMATION

Sample Number: 1504027-034 Customer Sample Number:
Location: 17F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 3/31/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 4/3/2015 11:04:22 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-035

SAMPLE INFORMATION

Sample Number: 1504027-035
Location: 18
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 3/31/2015	Collection Time: 7:00	Sampler: CW/DC	Received Date and Time: 4/3/2015 11:04:22 AM	Received By: LGallimore
-------------------------------	--------------------------	-------------------	---	----------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	13.8 ug/L	4/6/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	4/6/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	4/6/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.06 ug/L	4/6/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.02 ug/L	4/6/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	4/6/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-035

SAMPLE INFORMATION


Sample Number: 1504027-035
Location: 18
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 3/31/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 4/3/2015 11:04:22 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-037

SAMPLE INFORMATION

Sample Number: 1504027-037
Location: 19
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 3/31/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 4/3/2015 11:04:22 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	13.8 ug/L	4/6/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	4/6/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	4/6/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.98 ug/L	4/6/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.80 ug/L	4/6/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	4/6/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-037

SAMPLE INFORMATION


Sample Number: 1504027-037
Location: 19
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 3/31/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 4/3/2015 11:04:22 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 4/24/2015
Report Number: M- W1504027-038

SAMPLE INFORMATION

Sample Number: 1504027-038 Customer Sample Number:
Location: 19F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 3/31/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 4/3/2015 11:04:22 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-039

SAMPLE INFORMATION

Sample Number: 1504027-039
Location: 20
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 3/31/2015	Collection Time: 7:00	Sampler: CW/DC	Received Date and Time: 4/3/2015 11:04:22 AM	Received By: LGallimore
-------------------------------	--------------------------	-------------------	---	----------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	13.8 ug/L	4/6/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	4/6/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	4/6/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.94 ug/L	4/6/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.72 ug/L	4/6/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	4/6/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-039

SAMPLE INFORMATION


Sample Number: 1504027-039
Location: 20
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 3/31/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 4/3/2015 11:04:22 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-040

SAMPLE INFORMATION


Sample Number: 1504027-040
Location: 20F
LPR 411 7TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 3/31/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 4/3/2015 11:04:22 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-041

SAMPLE INFORMATION

Sample Number: 1504027-041 Customer Sample Number:
Location: H1 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: 3/31/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 4/3/2015 11:04:22 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8 5X dilution	ug/L	ug/L	50 ug/L	809 ug/L	4/6/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	52.4 ug/L	4/6/2015	RHoffa
Iron	EPA 200.8 5 X dilution	ug/L	ug/L	50 ug/L	879 ug/L	4/6/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	409 ug/L	4/6/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	134 ug/L	4/6/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	251 ug/L	4/6/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 4/24/2015
Report Number: M- W1504027-041

SAMPLE INFORMATION

Sample Number: 1504027-041 Customer Sample Number:
Location: H1 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/31/2015 7:00 CW/DC 4/3/2015 11:04:22 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 4/24/2015
Report Number: M- W1504027-042

SAMPLE INFORMATION

Sample Number: 1504027-042 Customer Sample Number:
Location: H2 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/31/2015 7:00 CW/DC 4/3/2015 11:04:22 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-043

SAMPLE INFORMATION

Sample Number: 1504027-043 Customer Sample Number:
Location: H3 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/31/2015 7:00 CW/DC 4/3/2015 11:04:22 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 4/24/2015
Robert P. Hoffa, Acting Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-044

SAMPLE INFORMATION

Sample Number: 1504027-044 Customer Sample Number:
Location: H4 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: 3/31/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 4/3/2015 11:04:22 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	98.0 ug/L	4/6/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.03 ug/L	4/6/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	74.9 ug/L	4/6/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	58.1 ug/L	4/6/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	24.9 ug/L	4/6/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	30.4 ug/L	4/6/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 4/24/2015
Report Number: M- W1504027-044

SAMPLE INFORMATION

Sample Number: 1504027-044 Customer Sample Number:
Location: H4 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/31/2015 7:00 CW/DC 4/3/2015 11:04:22 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-045

SAMPLE INFORMATION

Sample Number: 1504027-045 Customer Sample Number:
Location: H5 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: 3/31/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 4/3/2015 11:04:22 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	75.7 ug/L	4/6/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.92 ug/L	4/6/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	53.7 ug/L	4/6/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	43.4 ug/L	4/6/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	16.8 ug/L	4/6/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	22.8 ug/L	4/6/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 4/24/2015
Report Number: M- W1504027-045

SAMPLE INFORMATION

Sample Number: 1504027-045 Customer Sample Number:
Location: H5 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/31/2015 7:00 CW/DC 4/3/2015 11:04:22 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 4/24/2015
Report Number: M- W1504027-046

SAMPLE INFORMATION

Sample Number: 1504027-046 Customer Sample Number:
Location: H6 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/31/2015 7:00 CW/DC 4/3/2015 11:04:22 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 4/24/2015
Report Number: M- W1504027-047

SAMPLE INFORMATION

Sample Number: 1504027-047 Customer Sample Number:
Location: H7 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/31/2015 7:00 CW/DC 4/3/2015 11:04:22 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-048

SAMPLE INFORMATION

Sample Number: 1504027-048 Customer Sample Number:
Location: H8 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: 3/31/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 4/3/2015 11:04:22 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	52.5 ug/L	4/6/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.62 ug/L	4/6/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	31.6 ug/L	4/6/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	29.3 ug/L	4/6/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	14.3 ug/L	4/6/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	13.5 ug/L	4/6/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 4/24/2015
Report Number: M- W1504027-048

SAMPLE INFORMATION

Sample Number: 1504027-048 Customer Sample Number:
Location: H8 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/31/2015 7:00 CW/DC 4/3/2015 11:04:22 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-049

SAMPLE INFORMATION

Sample Number: 1504027-049
Location: H9
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 3/31/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 4/3/2015 11:04:22 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	44.1 ug/L	4/6/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.41 ug/L	4/6/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	26.6 ug/L	4/6/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	24.4 ug/L	4/6/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	12.0 ug/L	4/6/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	11.1 ug/L	4/6/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 4/24/2015
Report Number: M- W1504027-049

SAMPLE INFORMATION

Sample Number: 1504027-049 Customer Sample Number:
Location: H9 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/31/2015 7:00 CW/DC 4/3/2015 11:04:22 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 4/24/2015
Report Number: M- W1504027-050

SAMPLE INFORMATION

Sample Number: 1504027-050 Customer Sample Number:
Location: H10 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/31/2015 7:00 CW/DC 4/3/2015 11:04:22 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 4/24/2015
Report Number: M- W1504027-051

SAMPLE INFORMATION

Sample Number: 1504027-051 Customer Sample Number:
Location: H11 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/31/2015 7:00 CW/DC 4/3/2015 11:04:22 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 4/24/2015
Report Number: M- W1504027-052

SAMPLE INFORMATION

Sample Number: 1504027-052 Customer Sample Number:
Location: H12 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/31/2015 7:00 CW/DC 4/3/2015 11:04:22 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 4/24/2015
Report Number: M- W1504027-053

SAMPLE INFORMATION

Sample Number: 1504027-053 Customer Sample Number:
Location: H13 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/31/2015 7:00 CW/DC 4/3/2015 11:04:22 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-054

SAMPLE INFORMATION

Sample Number: 1504027-054 Customer Sample Number:
Location: H14 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: 3/31/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 4/3/2015 11:04:22 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	35.8 ug/L	4/6/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.0 ug/L	4/6/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	19.3 ug/L	4/6/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	19.5 ug/L	4/6/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	8.54 ug/L	4/6/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.07 ug/L	4/6/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 4/24/2015
Report Number: M- W1504027-054

SAMPLE INFORMATION

Sample Number: 1504027-054 Customer Sample Number:
Location: H14 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/31/2015 7:00 CW/DC 4/3/2015 11:04:22 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 4/24/2015
Report Number: M- W1504027-055

SAMPLE INFORMATION

Sample Number: 1504027-055 Customer Sample Number:
Location: H15 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/31/2015 7:00 CW/DC 4/3/2015 11:04:22 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-056

SAMPLE INFORMATION

Sample Number: 1504027-056 Customer Sample Number:
Location: H16 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/31/2015 7:00 CW/DC 4/3/2015 11:04:22 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:

Robert P. Hoffa

Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 4/24/2015
Report Number: M- W1504027-057

SAMPLE INFORMATION

Sample Number: 1504027-057 Customer Sample Number:
Location: H17 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/31/2015 7:00 CW/DC 4/3/2015 11:04:22 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/24/2015
Report Number: M- W1504027-058

SAMPLE INFORMATION

Sample Number: 1504027-058 Customer Sample Number:
Location: H18 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: 3/31/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 4/3/2015 11:04:22 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	28.0 ug/L	4/6/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	4/6/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	15.0 ug/L	4/6/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	15.3 ug/L	4/6/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.72 ug/L	4/6/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.60 ug/L	4/6/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 4/24/2015
Report Number: M- W1504027-058

SAMPLE INFORMATION

Sample Number: 1504027-058 Customer Sample Number:
Location: H18 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/31/2015 7:00 CW/DC 4/3/2015 11:04:22 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 4/24/2015
Report Number: M- W1504027-059

SAMPLE INFORMATION

Sample Number: 1504027-059 Customer Sample Number:
Location: H19 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
3/31/2015 7:00 CW/DC 4/3/2015 11:04:22 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/24/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-001

SAMPLE INFORMATION

Sample Number: 1504085-001
Location: 1
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Laboratory Manager

5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-002

SAMPLE INFORMATION

Sample Number: 1504085-002 Customer Sample Number:
Location: 1F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-003

SAMPLE INFORMATION

Sample Number: 1504085-003
Location: 02
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	5/5/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.07 ug/L	5/5/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	59.1 ug/L	5/5/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.47 ug/L	5/5/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	262 ug/L	5/5/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.69 ug/L	5/5/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-003

SAMPLE INFORMATION

Sample Number: 1504085-003
Location: 02
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date: 5/13/2015

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-004

SAMPLE INFORMATION

Sample Number: 1504085-004 Customer Sample Number:
Location: 02F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-005

SAMPLE INFORMATION

Sample Number: 1504085-005
Location: 03
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	10.8 ug/L	5/5/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.25 ug/L	5/5/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	585 ug/L	5/5/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.64 ug/L	5/5/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	198 ug/L	5/5/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.42 ug/L	5/5/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-005

SAMPLE INFORMATION

Sample Number: 1504085-005 Customer Sample Number:
Location: 03 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/10/2015 7:00 IC/CW 4/10/2015 12:27:11 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-006

SAMPLE INFORMATION

Sample Number: 1504085-006
Location: 03F
LPR 2914 45TH ST NW (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter Method MCL MDL RDL Result Analysis Date Analyst

Reviewed By: *Robert P. Hoffa*
Ü[à^! ÚËP [~aËöa[!a[!^ Á a[æ ^!

5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-007

SAMPLE INFORMATION

Sample Number: 1504085-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/10/2015 7:00 IC/CW 4/10/2015 12:27:11 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-008

SAMPLE INFORMATION

Sample Number: 1504085-008 Customer Sample Number:
Location: 04F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-009

SAMPLE INFORMATION

Sample Number: 1504085-009
Location: 05
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	11.0 ug/L	5/5/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.59 ug/L	5/5/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	231 ug/L	5/5/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.61 ug/L	5/5/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	224 ug/L	5/5/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.65 ug/L	5/5/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-009

SAMPLE INFORMATION

Sample Number: 1504085-009
Location: 05
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date: 5/13/2015

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-010

SAMPLE INFORMATION

Sample Number: 1504085-010 Customer Sample Number:
Location: 05F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/10/2015 7:00 IC/CW 4/10/2015 12:27:11 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-011

SAMPLE INFORMATION

Sample Number: 1504085-011
Location: 06
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:

Ü[à^!óÚËP[~aËöa[!a[!^ Á a[a^!

5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-012

SAMPLE INFORMATION

Sample Number: 1504085-012
Location: 06F
LPR 2914 45TH ST NW (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Ü[à^! ÚËP [~aËöa[!a[!^ Á a[æ ^!

5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-013

SAMPLE INFORMATION

Sample Number: 1504085-013
Location: 07
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
4/10/2015	7:00	IC/CW	4/10/2015 12:27:11 PM	LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	12.7 ug/L	5/5/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.13 ug/L	5/5/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	198 ug/L	5/5/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.72 ug/L	5/5/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	153 ug/L	5/5/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.84 ug/L	5/5/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-013

SAMPLE INFORMATION

Sample Number: 1504085-013
Location: 07
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Ü[à^! ÚËP [~aËöa[!a[!^ Á a[æ ^!

5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-014

SAMPLE INFORMATION

Sample Number: 1504085-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/10/2015 7:00 IC/CW 4/10/2015 12:27:11 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-015

SAMPLE INFORMATION

Sample Number: 1504085-015
Location: 08
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	12.6 ug/L	5/5/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.03 ug/L	5/5/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	114 ug/L	5/5/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	10.1 ug/L	5/5/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	134 ug/L	5/5/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.20 ug/L	5/5/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-015

SAMPLE INFORMATION

Sample Number: 1504085-015 Customer Sample Number:
Location: 08 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/10/2015 7:00 IC/CW 4/10/2015 12:27:11 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-016

SAMPLE INFORMATION

Sample Number: 1504085-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/10/2015 7:00 IC/CW 4/10/2015 12:27:11 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-017

SAMPLE INFORMATION

Sample Number: 1504085-017
Location: 09
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date: 5/13/2015

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-018

SAMPLE INFORMATION

Sample Number: 1504085-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-019

SAMPLE INFORMATION

Sample Number: 1504085-019
Location: 10
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Ü[à^! ÚËP [~aËöa[!a[!^ Á a[a[^!

5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-020

SAMPLE INFORMATION

Sample Number: 1504085-020 Customer Sample Number:
Location: 10F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-021

SAMPLE INFORMATION

Sample Number: 1504085-021
Location: 11
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date: 5/13/2015

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-022

SAMPLE INFORMATION

Sample Number: 1504085-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/10/2015 7:00 IC/CW 4/10/2015 12:27:11 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-023

SAMPLE INFORMATION

Sample Number: 1504085-023
Location: 12
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	12.9 ug/L	5/5/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.52 ug/L	5/5/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	76.8 ug/L	5/5/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.96 ug/L	5/5/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	106 ug/L	5/5/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.67 ug/L	5/5/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-023

SAMPLE INFORMATION

Sample Number: 1504085-023
Location: 12
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date

5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-024

SAMPLE INFORMATION

Sample Number: 1504085-024 Customer Sample Number:
Location: 12F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/10/2015 7:00 IC/CW 4/10/2015 12:27:11 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-025

SAMPLE INFORMATION

Sample Number: 1504085-025
Location: 13
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	15.6 ug/L	5/5/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.41 ug/L	5/5/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	81.8 ug/L	5/5/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.25 ug/L	5/5/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	87.1 ug/L	5/5/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.79 ug/L	5/5/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-025

SAMPLE INFORMATION

Sample Number: 1504085-025
Location: 13
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date: 5/13/2015

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-026

SAMPLE INFORMATION

Sample Number: 1504085-026 Customer Sample Number:
Location: 13F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-027

SAMPLE INFORMATION

Sample Number: 1504085-027
Location: 14
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter Method MCL MDL RDL Result Analysis Date Analyst

Reviewed By: *Robert P. Hoffa*

5/13/2015

Ü[à^!ÁËP[~aËöa[!æ[!^ Á a æ ^!

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-028

SAMPLE INFORMATION

Sample Number: 1504085-028
Location: 14F
LPR 2914 45TH ST NW (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Ü[à^! ÚËP [~aËöa[!a[!^ Á a[æ ^!

5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-029

SAMPLE INFORMATION

Sample Number: 1504085-029
Location: 15
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
4/10/2015	7:00	IC/CW	4/10/2015 12:27:11 PM	LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	13.6 ug/L	5/5/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.09 ug/L	5/5/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	49.0 ug/L	5/5/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.62 ug/L	5/5/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	59.6 ug/L	5/5/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.91 ug/L	5/5/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-029

SAMPLE INFORMATION

Sample Number: 1504085-029
Location: 15
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter Method MCL MDL RDL Result Analysis Date Analyst

Reviewed By: *Robert P. Hoffa*
Ü[à^! ÚËP [~aËöa[!a[!^ Á a[æ ^!

5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-030

SAMPLE INFORMATION

Sample Number: 1504085-030
Location: 15F
LPR 2914 45TH ST NW (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter Method MCL MDL RDL Result Analysis Date Analyst

Reviewed By: *Robert P. Hoffa*
Ü[à^! ÚËP [~aËöa[!a[!^ Á a[æ ^!

5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-031

SAMPLE INFORMATION

Sample Number: 1504085-031
Location: 16
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
4/10/2015	7:00	IC/CW	4/10/2015 12:27:11 PM	LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	14.0 ug/L	5/5/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.04 ug/L	5/5/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	39.7 ug/L	5/5/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.73 ug/L	5/5/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	54.0 ug/L	5/5/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.82 ug/L	5/5/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-031

SAMPLE INFORMATION

Sample Number: 1504085-031
Location: 16
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date: 5/13/2015

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-032

SAMPLE INFORMATION

Sample Number: 1504085-032 Customer Sample Number:
Location: 16F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	10.2 ug/L	5/5/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	5/5/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	5/5/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.81 ug/L	5/5/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	48.3 ug/L	5/5/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	5/5/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-032

SAMPLE INFORMATION

Sample Number: 1504085-032
Location: 16F
LPR 2914 45TH ST NW (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date: 5/13/2015

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-033

SAMPLE INFORMATION

Sample Number: 1504085-033
Location: 17
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
4/10/2015	7:00	IC/CW	4/10/2015 12:27:11 PM	LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	13.6 ug/L	5/5/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.04 ug/L	5/5/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	35.7 ug/L	5/5/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.79 ug/L	5/5/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	50.0 ug/L	5/5/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.71 ug/L	5/5/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-033

SAMPLE INFORMATION

Sample Number: 1504085-033
Location: 17
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date: 5/13/2015

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-034

SAMPLE INFORMATION

Sample Number: 1504085-034
Location: 17F
LPR 2914 45TH ST NW (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Ü[à^! ÚËP [~aËöa[!a[!^ Á a[æ ^!

5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-035

SAMPLE INFORMATION

Sample Number: 1504085-035
Location: 18
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	13.5 ug/L	5/5/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.02 ug/L	5/5/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	31.2 ug/L	5/5/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.06 ug/L	5/5/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	47.2 ug/L	5/5/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.64 ug/L	5/5/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-035

SAMPLE INFORMATION

Sample Number: 1504085-035
Location: 18
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date: 5/13/2015

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-036

SAMPLE INFORMATION

Sample Number: 1504085-036 Customer Sample Number:
Location: 18F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	10.5 ug/L	5/5/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	5/5/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	5/5/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.42 ug/L	5/5/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	44.1 ug/L	5/5/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	5/5/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-036

SAMPLE INFORMATION

Sample Number: 1504085-036 Customer Sample Number:
Location: 18F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/10/2015 7:00 IC/CW 4/10/2015 12:27:11 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-037

SAMPLE INFORMATION

Sample Number: 1504085-037
Location: 19
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date

5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-038

SAMPLE INFORMATION

Sample Number: 1504085-038 Customer Sample Number:
Location: 19F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	10.5 ug/L	5/5/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	5/5/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	5/5/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.76 ug/L	5/5/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	43.7 ug/L	5/5/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	5/5/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-038

SAMPLE INFORMATION

Sample Number: 1504085-038
Location: 19F
LPR 2914 45TH ST NW (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Ü[à^! ÚËP [~aËöa[!a[!^ Á a[æ ^!

5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-039

SAMPLE INFORMATION

Sample Number: 1504085-039
Location: 20
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
4/10/2015	7:00	IC/CW	4/10/2015 12:27:11 PM	LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	13.4 ug/L	5/5/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.09 ug/L	5/5/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	31.8 ug/L	5/5/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.73 ug/L	5/5/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	43.6 ug/L	5/5/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.63 ug/L	5/5/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-039

SAMPLE INFORMATION

Sample Number: 1504085-039
Location: 20
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date: 5/13/2015

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-040

SAMPLE INFORMATION

Sample Number: 1504085-040 Customer Sample Number:
Location: 20F Type: Dist.
LPR 2914 45TH ST NW (FILTERED)
Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-041

SAMPLE INFORMATION

Sample Number: 1504085-041 Customer Sample Number:
Location: H1 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/10/2015 7:00 IC/CW 4/10/2015 12:27:11 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-042

SAMPLE INFORMATION

Sample Number: 1504085-042 Customer Sample Number:
Location: H2 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	19.7 ug/L	5/5/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.53 ug/L	5/5/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	137 ug/L	5/5/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.59 ug/L	5/5/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	97.1 ug/L	5/5/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.21 ug/L	5/5/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-042

SAMPLE INFORMATION

Sample Number: 1504085-042
Location: H2
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter Method MCL MDL RDL Result Analysis Date Analyst

Reviewed By: *Robert P. Hoffa*

5/13/2015

Ü[à^! ÚËP[~aËöa[!a[!^ Á a[æ ^!

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-043

SAMPLE INFORMATION

Sample Number: 1504085-043 Customer Sample Number:
Location: H3 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-044

SAMPLE INFORMATION

Sample Number: 1504085-044 Customer Sample Number:
Location: H4 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-045

SAMPLE INFORMATION

Sample Number: 1504085-045 Customer Sample Number:
Location: H5 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-046

SAMPLE INFORMATION

Sample Number: 1504085-046 Customer Sample Number:
Location: H6 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-047

SAMPLE INFORMATION

Sample Number: 1504085-047 Customer Sample Number:
Location: H7 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	16.7 ug/L	5/5/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.79 ug/L	5/5/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	88.2 ug/L	5/5/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.85 ug/L	5/5/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	52.4 ug/L	5/5/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.59 ug/L	5/5/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-047

SAMPLE INFORMATION

Sample Number: 1504085-047 Customer Sample Number:
Location: H7 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-048

SAMPLE INFORMATION

Sample Number: 1504085-048 Customer Sample Number:
Location: H8 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/10/2015 7:00 IC/CW 4/10/2015 12:27:11 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-049

SAMPLE INFORMATION

Sample Number: 1504085-049 Customer Sample Number:
Location: H9 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	17.1 ug/L	5/5/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.95 ug/L	5/5/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	73.4 ug/L	5/5/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.21 ug/L	5/5/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	48.0 ug/L	5/5/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.89 ug/L	5/5/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-049

SAMPLE INFORMATION

Sample Number: 1504085-049 Customer Sample Number:
Location: H9 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-050

SAMPLE INFORMATION

Sample Number: 1504085-050 Customer Sample Number:
Location: H10 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/10/2015 7:00 IC/CW 4/10/2015 12:27:11 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-051

SAMPLE INFORMATION

Sample Number: 1504085-051 Customer Sample Number:
Location: H11 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-052

SAMPLE INFORMATION

Sample Number: 1504085-052 Customer Sample Number:
Location: H12 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-053

SAMPLE INFORMATION

Sample Number: 1504085-053 Customer Sample Number:
Location: H13 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/10/2015 7:00 IC/CW 4/10/2015 12:27:11 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-054

SAMPLE INFORMATION

Sample Number: 1504085-054 Customer Sample Number:
Location: H14 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	17.0 ug/L	5/5/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.09 ug/L	5/5/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	77.4 ug/L	5/5/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.92 ug/L	5/5/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	44.4 ug/L	5/5/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.14 ug/L	5/5/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-054

SAMPLE INFORMATION

Sample Number: 1504085-054
Location: H14
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter Method MCL MDL RDL Result Analysis Date Analyst

Reviewed By: *Robert P. Hoffa*

5/13/2015

Ü[à^! ÚËP[~aËöa[!a[!^ Á a[æ ^!

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-055

SAMPLE INFORMATION

Sample Number: 1504085-055 Customer Sample Number:
Location: H15 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/10/2015 7:00 IC/CW 4/10/2015 12:27:11 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-056

SAMPLE INFORMATION

Sample Number: 1504085-056 Customer Sample Number:
Location: H16 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/10/2015 7:00 IC/CW 4/10/2015 12:27:11 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-057

SAMPLE INFORMATION

Sample Number: 1504085-057
Location: H17
LPR 2914 45TH ST NW (UNFILTERED)
Customer Sample Number:
Type: Dist.
Collection Date: 4/10/2015
Collection Time: 7:00
Sampler: IC/CW
Received Date and Time: 4/10/2015 12:27:11 PM
Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	17.1 ug/L	5/5/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.08 ug/L	5/5/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	66.2 ug/L	5/5/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.06 ug/L	5/5/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	37.4 ug/L	5/5/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.29 ug/L	5/5/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-057

SAMPLE INFORMATION

Sample Number: 1504085-057 Customer Sample Number:
Location: H17 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/10/2015 7:00 IC/CW 4/10/2015 12:27:11 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-058

SAMPLE INFORMATION

Sample Number: 1504085-058 Customer Sample Number:
Location: H18 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-059

SAMPLE INFORMATION

Sample Number: 1504085-059
Location: H19
LPR 2914 45TH ST NW (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 4/10/2015 Collection Time: 7:00 Sampler: IC/CW Received Date and Time: 4/10/2015 12:27:11 PM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date: 5/13/2015

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1504085-060

SAMPLE INFORMATION

Sample Number: 1504085-060 Customer Sample Number:
Location: H20 Type: Dist.
LPR 2914 45TH ST NW (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
4/10/2015 7:00 IC/CW 4/10/2015 12:27:11 PM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-001

SAMPLE INFORMATION

Sample Number: 1505004-001
Location: 01a
LPR 5205 BLAINE ST NE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:30 Sampler: IC Received Date and Time: 5/1/2015 12:28:20 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date: 5/13/2015

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-002

SAMPLE INFORMATION

Sample Number: 1505004-002
Location: 01b
LPR 5205 BLAINE ST NE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:30 Sampler: IC Received Date and Time: 5/1/2015 12:28:20 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	31.5 ug/L	5/11/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.2 ug/L	5/11/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	5/11/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	17.5 ug/L	5/11/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	53.2 ug/L	5/11/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	5/11/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-002

SAMPLE INFORMATION

Sample Number: 1505004-002
Location: 01b
LPR 5205 BLAINE ST NE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:30 Sampler: IC Received Date and Time: 5/1/2015 12:28:20 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Ü[à^!ÁËP[~aËöa[!a[!^ Á a[æ ^!

5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-003

SAMPLE INFORMATION

Sample Number: 1505004-003 Customer Sample Number:
Location: 01c Type: Dist.
LPR 5205 BLAINE ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/1/2015 7:30 IC 5/1/2015 12:28:20 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-004

SAMPLE INFORMATION

Sample Number: 1505004-004 Customer Sample Number:
Location: 01d Type: Dist.
LPR 5205 BLAINE ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/1/2015 7:30 IC 5/1/2015 12:28:20 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-005

SAMPLE INFORMATION

Sample Number: 1505004-005
Location: 02
LPR 5205 BLAINE ST NE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:30 Sampler: IC Received Date and Time: 5/1/2015 12:28:20 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	26.1 ug/L	5/11/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	5/11/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	17.0 ug/L	5/11/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	15.4 ug/L	5/11/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	26.8 ug/L	5/11/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.2 ug/L	5/11/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-005

SAMPLE INFORMATION

Sample Number: 1505004-005
Location: 02
LPR 5205 BLAINE ST NE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:30 Sampler: IC Received Date and Time: 5/1/2015 12:28:20 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date: 5/13/2015

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-006

SAMPLE INFORMATION

Sample Number: 1505004-006 Customer Sample Number:
Location: 03 Type: Dist.
LPR 5205 BLAINE ST NE UNFILTERED
Collection Date: 5/1/2015 Collection Time: 7:30 Sampler: IC Received Date and Time: 5/1/2015 12:28:20 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	26.6 ug/L	5/11/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	5/11/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	21.5 ug/L	5/11/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	20.4 ug/L	5/11/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	22.5 ug/L	5/11/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.2 ug/L	5/11/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-006

SAMPLE INFORMATION

Sample Number: 1505004-006 Customer Sample Number:
Location: 03 Type: Dist.
LPR 5205 BLAINE ST NE UNFILTERED
Collection Date: 5/1/2015 Collection Time: 7:30 Sampler: IC Received Date and Time: 5/1/2015 12:28:20 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-007

SAMPLE INFORMATION

Sample Number: 1505004-007
Location: 04
LPR 5205 BLAINE ST NE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:30 Sampler: IC Received Date and Time: 5/1/2015 12:28:20 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	26.3 ug/L	5/11/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	5/11/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	14.4 ug/L	5/11/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	15.3 ug/L	5/11/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	13.0 ug/L	5/11/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	5/11/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-007

SAMPLE INFORMATION

Sample Number: 1505004-007
Location: 04
LPR 5205 BLAINE ST NE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:30 Sampler: IC Received Date and Time: 5/1/2015 12:28:20 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Ü[à^!ÁËP[~aËöa[!a[!^ Á a[æ ^!

5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-008

SAMPLE INFORMATION

Sample Number: 1505004-008
Location: 05
LPR 5205 BLAINE ST NE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:30 Sampler: IC Received Date and Time: 5/1/2015 12:28:20 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	25.6 ug/L	5/11/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	5/11/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	5/11/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	13.2 ug/L	5/11/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	18.0 ug/L	5/11/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	5/11/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-008

SAMPLE INFORMATION

Sample Number: 1505004-008
Location: 05
LPR 5205 BLAINE ST NE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:30 Sampler: IC Received Date and Time: 5/1/2015 12:28:20 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date: 5/13/2015

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-009

SAMPLE INFORMATION

Sample Number: 1505004-009
Location: 06
LPR 5205 BLAINE ST NE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
5/1/2015	7:30	IC	5/1/2015 12:28:20 PM	JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	25.4 ug/L	5/11/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	5/11/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	12.8 ug/L	5/11/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.68 ug/L	5/11/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.26 ug/L	5/11/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	5/11/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-009

SAMPLE INFORMATION

Sample Number: 1505004-009
Location: 06
LPR 5205 BLAINE ST NE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:30 Sampler: IC Received Date and Time: 5/1/2015 12:28:20 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date: 5/13/2015

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-010

SAMPLE INFORMATION

Sample Number: 1505004-010
Location: 07
LPR 5205 BLAINE ST NE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:30 Sampler: IC Received Date and Time: 5/1/2015 12:28:20 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	25.1 ug/L	5/11/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	5/11/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	5/11/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.06 ug/L	5/11/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.31 ug/L	5/11/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	5/11/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-010

SAMPLE INFORMATION

Sample Number: 1505004-010
Location: 07
LPR 5205 BLAINE ST NE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:30 Sampler: IC Received Date and Time: 5/1/2015 12:28:20 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date: 5/13/2015

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-011

SAMPLE INFORMATION

Sample Number: 1505004-011
Location: 08
LPR 5205 BLAINE ST NE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:30 Sampler: IC Received Date and Time: 5/1/2015 12:28:20 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	25.6 ug/L	5/11/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	5/11/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	5/11/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	6.44 ug/L	5/11/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.66 ug/L	5/11/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	5/11/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-011

SAMPLE INFORMATION

Sample Number: 1505004-011
Location: 08
LPR 5205 BLAINE ST NE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:30 Sampler: IC Received Date and Time: 5/1/2015 12:28:20 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Ü[à^!ÁËP[~aËöa[!a[!^ Á a[æ ^!

5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-012

SAMPLE INFORMATION

Sample Number: 1505004-012
Location: 09
LPR 5205 BLAINE ST NE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:30 Sampler: IC Received Date and Time: 5/1/2015 12:28:20 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	25.0 ug/L	5/11/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	5/11/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	5/11/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.87 ug/L	5/11/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.84 ug/L	5/11/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	5/11/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-012

SAMPLE INFORMATION

Sample Number: 1505004-012
Location: 09
LPR 5205 BLAINE ST NE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:30 Sampler: IC Received Date and Time: 5/1/2015 12:28:20 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Ü[à^!ÁËP[~aËöa[!a[!^ Á a[æ ^!

5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-013

SAMPLE INFORMATION

Sample Number: 1505004-013
Location: 10
LPR 5205 BLAINE ST NE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:30 Sampler: IC Received Date and Time: 5/1/2015 12:28:20 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	23.5 ug/L	5/11/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.2 ug/L	5/11/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	5/11/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.18 ug/L	5/11/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.08 ug/L	5/11/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	5/11/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-013

SAMPLE INFORMATION

Sample Number: 1505004-013
Location: 10
LPR 5205 BLAINE ST NE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:30 Sampler: IC Received Date and Time: 5/1/2015 12:28:20 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Ü[à^!ÁËP[~aËöa[!a[!^ Á a[æ ^!

5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-014

SAMPLE INFORMATION

Sample Number: 1505004-014
Location: 11
LPR 5205 BLAINE ST NE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:30 Sampler: IC Received Date and Time: 5/1/2015 12:28:20 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Ü[à^!ÁËP[~aËöa[!a[!^ Á a[æ ^!

5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-015

SAMPLE INFORMATION

Sample Number: 1505004-015
Location: 12
LPR 5205 BLAINE ST NE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:30 Sampler: IC Received Date and Time: 5/1/2015 12:28:20 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	25.2 ug/L	5/11/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	5/11/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	5/11/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.90 ug/L	5/11/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	14.9 ug/L	5/11/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	5/11/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-015

SAMPLE INFORMATION

Sample Number: 1505004-015
Location: 12
LPR 5205 BLAINE ST NE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:30 Sampler: IC Received Date and Time: 5/1/2015 12:28:20 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date: 5/13/2015

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-016

SAMPLE INFORMATION

Sample Number: 1505004-016
Location: H1
LPR 5205 BLAINE ST NE UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 5/1/2015
Collection Time: 7:30
Sampler: IC
Received Date and Time: 5/1/2015 12:28:20 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-017

SAMPLE INFORMATION

Sample Number: 1505004-017 Customer Sample Number:
Location: H2 Type: Dist.
LPR 5205 BLAINE ST NE UNFILTERED
Collection Date: 5/1/2015 Collection Time: 7:30 Sampler: IC Received Date and Time: 5/1/2015 12:28:20 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	37.8 ug/L	5/11/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.0 ug/L	5/11/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	36.9 ug/L	5/11/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	17.8 ug/L	5/11/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	8.78 ug/L	5/11/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.98 ug/L	5/11/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-017

SAMPLE INFORMATION

Sample Number: 1505004-017 Customer Sample Number:
Location: H2 Type: Dist.
LPR 5205 BLAINE ST NE UNFILTERED
Collection Date: 5/1/2015 Collection Time: 7:30 Sampler: IC Received Date and Time: 5/1/2015 12:28:20 PM Received By: JCross

Parameter Method MCL MDL RDL Result Analysis Date Analyst

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-018

SAMPLE INFORMATION

Sample Number: 1505004-018 Customer Sample Number:
Location: H3 Type: Dist.
LPR 5205 BLAINE ST NE UNFILTERED
Collection Date: 5/1/2015 Collection Time: 7:30 Sampler: IC Received Date and Time: 5/1/2015 12:28:20 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	34.5 ug/L	5/11/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	5/11/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	32.8 ug/L	5/11/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	15.9 ug/L	5/11/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.10 ug/L	5/11/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.91 ug/L	5/11/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-018

SAMPLE INFORMATION

Sample Number: 1505004-018 Customer Sample Number:
Location: H3 Type: Dist.
LPR 5205 BLAINE ST NE UNFILTERED
Collection Date: 5/1/2015 Collection Time: 7:30 Sampler: IC Received Date and Time: 5/1/2015 12:28:20 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-019

SAMPLE INFORMATION

Sample Number: 1505004-019
Location: H4
LPR 5205 BLAINE ST NE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:30 Sampler: IC Received Date and Time: 5/1/2015 12:28:20 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	29.0 ug/L	5/11/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	5/11/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	23.3 ug/L	5/11/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	13.2 ug/L	5/11/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.35 ug/L	5/11/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.60 ug/L	5/11/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-019

SAMPLE INFORMATION

Sample Number: 1505004-019 Customer Sample Number:
Location: H4 Type: Dist.
LPR 5205 BLAINE ST NE UNFILTERED
Collection Date: 5/1/2015 Collection Time: 7:30 Sampler: IC Received Date and Time: 5/1/2015 12:28:20 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-020

SAMPLE INFORMATION

Sample Number: 1505004-020 Customer Sample Number:
Location: H5 Type: Dist.
LPR 5205 BLAINE ST NE UNFILTERED
Collection Date: 5/1/2015 Collection Time: 7:30 Sampler: IC Received Date and Time: 5/1/2015 12:28:20 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	29.0 ug/L	5/11/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	5/11/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	17.6 ug/L	5/11/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.23 ug/L	5/11/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.81 ug/L	5/11/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.53 ug/L	5/11/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-020

SAMPLE INFORMATION

Sample Number: 1505004-020 Customer Sample Number:
Location: H5 Type: Dist.
LPR 5205 BLAINE ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/1/2015 7:30 IC 5/1/2015 12:28:20 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-021

SAMPLE INFORMATION

Sample Number: 1505004-021 Customer Sample Number:
Location: H6 Type: Dist.
LPR 5205 BLAINE ST NE UNFILTERED
Collection Date: 5/1/2015 Collection Time: 7:30 Sampler: IC Received Date and Time: 5/1/2015 12:28:20 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-022

SAMPLE INFORMATION

Sample Number: 1505004-022 Customer Sample Number:
Location: H7 Type: Dist.
LPR 5205 BLAINE ST NE UNFILTERED
Collection Date: 5/1/2015 Collection Time: 7:30 Sampler: IC Received Date and Time: 5/1/2015 12:28:20 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-023

SAMPLE INFORMATION

Sample Number: 1505004-023
Location: H8
LPR 5205 BLAINE ST NE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:30 Sampler: IC Received Date and Time: 5/1/2015 12:28:20 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	29.4 ug/L	5/11/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	5/11/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	12.7 ug/L	5/11/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.19 ug/L	5/11/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	6.22 ug/L	5/11/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.07 ug/L	5/11/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-023

SAMPLE INFORMATION

Sample Number: 1505004-023
Location: H8
LPR 5205 BLAINE ST NE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:30 Sampler: IC Received Date and Time: 5/1/2015 12:28:20 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Ü[à^!ÁËP[~aËöa[!a[!^ Á a[æ ^!

5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-024

SAMPLE INFORMATION

Sample Number: 1505004-024 Customer Sample Number:
Location: H9 Type: Dist.
LPR 5205 BLAINE ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/1/2015 7:30 IC 5/1/2015 12:28:20 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-025

SAMPLE INFORMATION

Sample Number: 1505004-025 Customer Sample Number:
Location: H10 Type: Dist.
LPR 5205 BLAINE ST NE UNFILTERED
Collection Date: 5/1/2015 Collection Time: 7:30 Sampler: IC Received Date and Time: 5/1/2015 12:28:20 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-026

SAMPLE INFORMATION

Sample Number: 1505004-026
Customer Sample Number:
Location: B1
Type: Dist.
LPR 5205 BLAINE ST NE (BATH TUB-COLD) UNFILTERED

Collection Date: 5/1/2015
Collection Time: 7:30
Sampler: IC
Received Date and Time: 5/1/2015 12:28:20 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	25.4 ug/L	5/11/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	5/11/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	11.8 ug/L	5/11/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	52.0 ug/L	5/11/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	15.2 ug/L	5/11/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	5/11/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-026

SAMPLE INFORMATION

Sample Number: 1505004-026 Customer Sample Number:
Location: B1 Type: Dist.
LPR 5205 BLAINE ST NE (BATH TUB-COLD) UNFILTERED
Collection Date: 5/1/2015 Collection Time: 7:30 Sampler: IC Received Date and Time: 5/1/2015 12:28:20 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-027

SAMPLE INFORMATION

Sample Number: 1505004-027 Customer Sample Number:
Location: B2 Type: Dist.
LPR 5205 BLAINE ST NE (BATH TUB -HOT) UNFILTERED
Collection Date: 5/1/2015 Collection Time: 7:30 Sampler: IC Received Date and Time: 5/1/2015 12:28:20 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/13/2015
Report Number: M- W1505004-028

SAMPLE INFORMATION

Sample Number: 1505004-028 Customer Sample Number:
Location: K1 Type: Dist.
LPR 5205 BLAINE ST NE (KITCHEN) FILTERED
Collection Date: 5/1/2015 Collection Time: 7:30 Sampler: IC Received Date and Time: 5/1/2015 12:28:20 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/13/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-001

SAMPLE INFORMATION

Sample Number: 1505006-001 Customer Sample Number:
Location: 1 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/1/2015 7:00 CW/DC 5/1/2015 12:45:19 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/27/2015
Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-002

SAMPLE INFORMATION

Sample Number: 1505006-002 Customer Sample Number:
Location: 1F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	18.2 ug/L	5/7/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	5/7/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	5/7/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	21.3 ug/L	5/7/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	15.4 ug/L	5/7/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	5/7/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-002

SAMPLE INFORMATION

Sample Number: 1505006-002 Customer Sample Number:
Location: 1F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/27/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-003

SAMPLE INFORMATION

Sample Number: 1505006-003
Location: 02
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015	Collection Time: 7:00	Sampler: CW/DC	Received Date and Time: 5/1/2015 12:45:19 PM	Received By: JCross
------------------------------	--------------------------	-------------------	---	------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	25.0 ug/L	5/7/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	5/7/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	18.5 ug/L	5/7/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	13.4 ug/L	5/7/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	6.30 ug/L	5/7/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.98 ug/L	5/7/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-003

SAMPLE INFORMATION

Sample Number: 1505006-003
Location: 02
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date: 5/27/2015

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-004

SAMPLE INFORMATION

Sample Number: 1505006-004 Customer Sample Number:
Location: 02F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/27/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-005

SAMPLE INFORMATION

Sample Number: 1505006-005
Location: 03
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015	Collection Time: 7:00	Sampler: CW/DC	Received Date and Time: 5/1/2015 12:45:19 PM	Received By: JCross
------------------------------	--------------------------	-------------------	---	------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	24.8 ug/L	5/7/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	5/7/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	16.2 ug/L	5/7/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	12.6 ug/L	5/7/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.24 ug/L	5/7/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.23 ug/L	5/7/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-005

SAMPLE INFORMATION

Sample Number: 1505006-005
Location: 03
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Ü[à^!ÁËP[~aËa[!a[!^ Á a æ ^!

5/27/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-006

SAMPLE INFORMATION

Sample Number: 1505006-006
Location: 03F
LPR 411 7TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Ü[à^!ÁËP[~aËa[!a[!^ Á a æ ^!

5/27/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-007

SAMPLE INFORMATION

Sample Number: 1505006-007
Location: 04
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	25.0 ug/L	5/7/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	5/7/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	16.9 ug/L	5/7/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	13.1 ug/L	5/7/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.87 ug/L	5/7/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.67 ug/L	5/7/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-007

SAMPLE INFORMATION

Sample Number: 1505006-007
Location: 04
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date: 5/27/2015

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-008

SAMPLE INFORMATION

Sample Number: 1505006-008 Customer Sample Number:
Location: 04F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/27/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-009

SAMPLE INFORMATION

Sample Number: 1505006-009
Location: 05
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015	Collection Time: 7:00	Sampler: CW/DC	Received Date and Time: 5/1/2015 12:45:19 PM	Received By: JCross
------------------------------	--------------------------	-------------------	---	------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	25.2 ug/L	5/7/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	5/7/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	17.1 ug/L	5/7/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	13.1 ug/L	5/7/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.89 ug/L	5/7/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.74 ug/L	5/7/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-009

SAMPLE INFORMATION

Sample Number: 1505006-009
Location: 05
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date: 5/27/2015

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-010

SAMPLE INFORMATION

Sample Number: 1505006-010 Customer Sample Number:
Location: 05F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/27/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-011

SAMPLE INFORMATION

Sample Number: 1505006-011
Location: 06
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	25.3 ug/L	5/7/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	5/7/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	18.7 ug/L	5/7/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	13.8 ug/L	5/7/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.08 ug/L	5/7/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.00 ug/L	5/7/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-011

SAMPLE INFORMATION

Sample Number: 1505006-011
Location: 06
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Ü[à^!ÁËP[~aËa[!a[!^ Á a æ ^!

5/27/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-012

SAMPLE INFORMATION

Sample Number: 1505006-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	19.6 ug/L	5/7/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	5/7/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	5/7/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	11.9 ug/L	5/7/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.50 ug/L	5/7/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	5/7/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-012

SAMPLE INFORMATION

Sample Number: 1505006-012
Location: 06F
LPR 411 7TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date: 5/27/2015

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-013

SAMPLE INFORMATION

Sample Number: 1505006-013
Location: 07
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	24.0 ug/L	5/7/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	5/7/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	18.3 ug/L	5/7/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	15.9 ug/L	5/7/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.40 ug/L	5/7/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.52 ug/L	5/7/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-013

SAMPLE INFORMATION

Sample Number: 1505006-013
Location: 07
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date: 5/27/2015

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-014

SAMPLE INFORMATION

Sample Number: 1505006-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/27/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-015

SAMPLE INFORMATION

Sample Number: 1505006-015
Location: 08
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	20.9 ug/L	5/7/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	5/7/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	18.4 ug/L	5/7/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	17.5 ug/L	5/7/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.68 ug/L	5/7/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.48 ug/L	5/7/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-015

SAMPLE INFORMATION

Sample Number: 1505006-015
Location: 08
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Ü[à^!ÁËP[~aËa[!a[!^ Á a æ ^!

5/27/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-016

SAMPLE INFORMATION

Sample Number: 1505006-016
Location: 08F
LPR 411 7TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date: 5/27/2015

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-017

SAMPLE INFORMATION

Sample Number: 1505006-017
Location: 09
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	19.3 ug/L	5/7/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	5/7/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	17.4 ug/L	5/7/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	15.1 ug/L	5/7/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	6.13 ug/L	5/7/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	13.6 ug/L	5/7/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-017

SAMPLE INFORMATION

Sample Number: 1505006-017
Location: 09
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Ü[à^!ÁËP[~aËa[!a[!^ Á a æ ^!

5/27/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-018

SAMPLE INFORMATION

Sample Number: 1505006-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/27/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-019

SAMPLE INFORMATION

Sample Number: 1505006-019
Location: 10
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015	Collection Time: 7:00	Sampler: CW/DC	Received Date and Time: 5/1/2015 12:45:19 PM	Received By: JCross
------------------------------	--------------------------	-------------------	---	------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	19.6 ug/L	5/7/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	5/7/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	17.6 ug/L	5/7/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	21.3 ug/L	5/7/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.80 ug/L	5/7/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	35.6 ug/L	5/7/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-019

SAMPLE INFORMATION

Sample Number: 1505006-019
Location: 10
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date: 5/27/2015

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-020

SAMPLE INFORMATION

Sample Number: 1505006-020
Location: 10F
LPR 411 7TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	14.8 ug/L	5/7/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	5/7/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	5/7/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	17.4 ug/L	5/7/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.78 ug/L	5/7/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.17 ug/L	5/7/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-020

SAMPLE INFORMATION

Sample Number: 1505006-020
Location: 10F
LPR 411 7TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date: 5/27/2015

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-021

SAMPLE INFORMATION

Sample Number: 1505006-021
Location: 11
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015	Collection Time: 7:00	Sampler: CW/DC	Received Date and Time: 5/1/2015 12:45:19 PM	Received By: JCross
------------------------------	--------------------------	-------------------	---	------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	19.9 ug/L	5/7/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	5/7/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	16.9 ug/L	5/7/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	70.2 ug/L	5/7/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	12.4 ug/L	5/7/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	209 ug/L	5/7/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-021

SAMPLE INFORMATION

Sample Number: 1505006-021
Location: 11
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Ü[à^!ÁËP[~aËöa[!a[!^ Á a æ ^!

5/27/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-022

SAMPLE INFORMATION

Sample Number: 1505006-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/27/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-023

SAMPLE INFORMATION

Sample Number: 1505006-023
Location: 12
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	15.2 ug/L	5/7/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	5/7/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	17.9 ug/L	5/7/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	184 ug/L	5/7/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	62.4 ug/L	5/7/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	242 ug/L	5/7/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-023

SAMPLE INFORMATION

Sample Number: 1505006-023
Location: 12
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date: 5/27/2015

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-024

SAMPLE INFORMATION

Sample Number: 1505006-024 Customer Sample Number:
Location: 12F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/27/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-025

SAMPLE INFORMATION

Sample Number: 1505006-025
Location: 13
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015	Collection Time: 7:00	Sampler: CW/DC	Received Date and Time: 5/1/2015 12:45:19 PM	Received By: JCross
------------------------------	--------------------------	-------------------	---	------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	13.8 ug/L	5/7/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	5/7/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	16.0 ug/L	5/7/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	216 ug/L	5/7/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	204 ug/L	5/7/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	65.7 ug/L	5/7/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-025

SAMPLE INFORMATION

Sample Number: 1505006-025
Location: 13
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date: 5/27/2015

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-026

SAMPLE INFORMATION

Sample Number: 1505006-026
Location: 13F
LPR 411 7TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date: 5/27/2015

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-027

SAMPLE INFORMATION

Sample Number: 1505006-027
Location: 14
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	14.3 ug/L	5/7/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	5/7/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	18.0 ug/L	5/7/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	210 ug/L	5/7/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	232 ug/L	5/7/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	18.1 ug/L	5/7/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-027

SAMPLE INFORMATION

Sample Number: 1505006-027
Location: 14
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date: 5/27/2015

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-028

SAMPLE INFORMATION

Sample Number: 1505006-028
Location: 14F
LPR 411 7TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Ü[à^!ÁËP[~aËa[!a[!^ Á a æ ^!

5/27/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-029

SAMPLE INFORMATION

Sample Number: 1505006-029
Location: 15
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	14.6 ug/L	5/7/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.0 ug/L	5/7/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	20.0 ug/L	5/7/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	248 ug/L	5/7/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	225 ug/L	5/7/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.93 ug/L	5/7/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-029

SAMPLE INFORMATION

Sample Number: 1505006-029
Location: 15
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date: 5/27/2015

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-030

SAMPLE INFORMATION

Sample Number: 1505006-030 Customer Sample Number:
Location: 15F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/27/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-031

SAMPLE INFORMATION

Sample Number: 1505006-031
Location: 16
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
5/1/2015	7:00	CW/DC	5/1/2015 12:45:19 PM	JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	14.6 ug/L	5/7/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	5/7/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	19.3 ug/L	5/7/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	266 ug/L	5/7/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	132 ug/L	5/7/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.33 ug/L	5/7/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-031

SAMPLE INFORMATION

Sample Number: 1505006-031
Location: 16
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Ü[à^!ÁËP[~aËöa[!a[!^ Á a æ ^!

5/27/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-032

SAMPLE INFORMATION

Sample Number: 1505006-032 Customer Sample Number:
Location: 16F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	5/7/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	5/7/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	5/7/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	218 ug/L	5/7/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	123 ug/L	5/7/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.0 ug/L	5/7/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-032

SAMPLE INFORMATION

Sample Number: 1505006-032 Customer Sample Number:
Location: 16F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/27/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-033

SAMPLE INFORMATION

Sample Number: 1505006-033
Location: 17
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015	Collection Time: 7:00	Sampler: CW/DC	Received Date and Time: 5/1/2015 12:45:19 PM	Received By: JCross
------------------------------	--------------------------	-------------------	---	------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	15.2 ug/L	5/7/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	5/7/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	18.5 ug/L	5/7/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	253 ug/L	5/7/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	55.7 ug/L	5/7/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.86 ug/L	5/7/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-033

SAMPLE INFORMATION

Sample Number: 1505006-033
Location: 17
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Ü[à^!ÁËP[~aËa[!a[!^ Á a æ ^!

5/27/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-034

SAMPLE INFORMATION

Sample Number: 1505006-034 Customer Sample Number:
Location: 17F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/27/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-035

SAMPLE INFORMATION

Sample Number: 1505006-035
Location: 18
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	19.0 ug/L	5/7/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	5/7/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	18.1 ug/L	5/7/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	163 ug/L	5/7/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	20.5 ug/L	5/7/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.92 ug/L	5/7/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-035

SAMPLE INFORMATION

Sample Number: 1505006-035
Location: 18
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date: 5/27/2015

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-036

SAMPLE INFORMATION

Sample Number: 1505006-036
Location: 18F
LPR 411 7TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Ü[à^! ÚËP[~aËöa[!a[!^ Á a[æ ^!

5/27/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-037

SAMPLE INFORMATION

Sample Number: 1505006-037
Location: 19
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015	Collection Time: 7:00	Sampler: CW/DC	Received Date and Time: 5/1/2015 12:45:19 PM	Received By: JCross
------------------------------	--------------------------	-------------------	---	------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	19.0 ug/L	5/7/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	5/7/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	17.2 ug/L	5/7/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	166 ug/L	5/7/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	16.6 ug/L	5/7/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.62 ug/L	5/7/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-037

SAMPLE INFORMATION

Sample Number: 1505006-037
Location: 19
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Ü[à^!ÁËP[~aËöa[!a[!^ Á a æ ^!

5/27/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-038

SAMPLE INFORMATION

Sample Number: 1505006-038
Location: 19F
LPR 411 7TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date: 5/27/2015

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-039

SAMPLE INFORMATION

Sample Number: 1505006-039
Location: 20
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	18.4 ug/L	5/7/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	5/7/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	17.0 ug/L	5/7/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	160 ug/L	5/7/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	13.1 ug/L	5/7/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.04 ug/L	5/7/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-039

SAMPLE INFORMATION

Sample Number: 1505006-039
Location: 20
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Ü[à^!ÁËP[~aËa[!a[!^ Á a æ ^!

5/27/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-040

SAMPLE INFORMATION

Sample Number: 1505006-040
Location: 20F
LPR 411 7TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	13.0 ug/L	5/7/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	5/7/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	5/7/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	130 ug/L	5/7/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	12.0 ug/L	5/7/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	5/7/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-040

SAMPLE INFORMATION

Sample Number: 1505006-040
Location: 20F
LPR 411 7TH ST NE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date: 5/27/2015

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-041

SAMPLE INFORMATION

Sample Number: 1505006-041
Location: H1
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date: 5/27/2015

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-042

SAMPLE INFORMATION

Sample Number: 1505006-042
Location: H2
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Ü[à^!ÁËP[~aËöa[!a[!^ Á a[æ ^!

5/27/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-043

SAMPLE INFORMATION

Sample Number: 1505006-043
Location: H3
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Ü[à^!ÁËP[~aËöa[!a[!^ Á a æ ^!

5/27/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-044

SAMPLE INFORMATION

Sample Number: 1505006-044
Customer Sample Number:
Location: H4
Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)

Collection Date: 5/1/2015
Collection Time: 7:00
Sampler: CW/DC
Received Date and Time: 5/1/2015 12:45:19 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	37.6 ug/L	5/7/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.58 ug/L	5/7/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	37.1 ug/L	5/7/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	49.7 ug/L	5/7/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	16.1 ug/L	5/7/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.92 ug/L	5/7/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-044

SAMPLE INFORMATION

Sample Number: 1505006-044
Location: H4
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date: 5/27/2015

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-045

SAMPLE INFORMATION

Sample Number: 1505006-045
Location: H5
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	37.9 ug/L	5/7/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.55 ug/L	5/7/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	35.3 ug/L	5/7/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	46.1 ug/L	5/7/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	14.4 ug/L	5/7/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	9.02 ug/L	5/7/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-045

SAMPLE INFORMATION

Sample Number: 1505006-045
Location: H5
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date: 5/27/2015

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-046

SAMPLE INFORMATION

Sample Number: 1505006-046
Location: H6
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	37.4 ug/L	5/7/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.53 ug/L	5/7/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	32.4 ug/L	5/7/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	43.9 ug/L	5/7/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	16.0 ug/L	5/7/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.34 ug/L	5/7/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-046

SAMPLE INFORMATION

Sample Number: 1505006-046
Location: H6
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Ü[à^!ÁËP[~aËöa[!a[!^ Á a[æ ^!

5/27/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-047

SAMPLE INFORMATION

Sample Number: 1505006-047 Customer Sample Number:
Location: H7 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/27/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-049

SAMPLE INFORMATION

Sample Number: 1505006-049
Location: H9
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Date: 5/27/2015

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-050

SAMPLE INFORMATION

Sample Number: 1505006-050 Customer Sample Number:
Location: H10 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	36.4 ug/L	5/7/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.48 ug/L	5/7/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	31.5 ug/L	5/7/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	40.3 ug/L	5/7/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	12.5 ug/L	5/7/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	6.59 ug/L	5/7/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-051

SAMPLE INFORMATION

Sample Number: 1505006-051
Location: H11
LPR 411 7TH ST NE (UNFILTERED)
Customer Sample Number:
Type: Dist.
Collection Date: 5/1/2015
Collection Time: 7:00
Sampler: CW/DC
Received Date and Time: 5/1/2015 12:45:19 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	36.1 ug/L	5/7/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.45 ug/L	5/7/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	29.6 ug/L	5/7/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	39.3 ug/L	5/7/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	10.6 ug/L	5/7/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.52 ug/L	5/7/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-051

SAMPLE INFORMATION

Sample Number: 1505006-051 Customer Sample Number:
Location: H11 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/1/2015 7:00 CW/DC 5/1/2015 12:45:19 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/27/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-052

SAMPLE INFORMATION

Sample Number: 1505006-052 Customer Sample Number:
Location: H12 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/27/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-053

SAMPLE INFORMATION

Sample Number: 1505006-053
Location: H13
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	34.8 ug/L	5/11/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.46 ug/L	5/11/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	28.2 ug/L	5/11/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	40.5 ug/L	5/11/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	10.0 ug/L	5/11/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.98 ug/L	5/11/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-053

SAMPLE INFORMATION

Sample Number: 1505006-053 Customer Sample Number:
Location: H13 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/1/2015 7:00 CW/DC 5/1/2015 12:45:19 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/27/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-054

SAMPLE INFORMATION

Sample Number: 1505006-054 Customer Sample Number:
Location: H14 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/1/2015 7:00 CW/DC 5/1/2015 12:45:19 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/27/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-055

SAMPLE INFORMATION

Sample Number: 1505006-055
Location: H15
LPR 411 7TH ST NE (UNFILTERED)
Customer Sample Number:
Type: Dist.
Collection Date: 5/1/2015
Collection Time: 7:00
Sampler: CW/DC
Received Date and Time: 5/1/2015 12:45:19 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Robert P. Hoffa, Laboratory Manager
5/27/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-056

SAMPLE INFORMATION

Sample Number: 1505006-056 Customer Sample Number:
Location: H16 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/27/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-057

SAMPLE INFORMATION

Sample Number: 1505006-057 Customer Sample Number:
Location: H17 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/27/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-058

SAMPLE INFORMATION

Sample Number: 1505006-058 Customer Sample Number:
Location: H18 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/27/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-059

SAMPLE INFORMATION

Sample Number: 1505006-059
Location: H19
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	32.5 ug/L	5/11/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.43 ug/L	5/11/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	27.9 ug/L	5/11/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	55.4 ug/L	5/11/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	11.7 ug/L	5/11/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	13.2 ug/L	5/11/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-059

SAMPLE INFORMATION

Sample Number: 1505006-059 Customer Sample Number:
Location: H19 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: 5/1/2015 Collection Time: 7:00 Sampler: CW/DC Received Date and Time: 5/1/2015 12:45:19 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/27/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 5/27/2015
Report Number: M- W1505006-060

SAMPLE INFORMATION

Sample Number: 1505006-060 Customer Sample Number:
Location: H20 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/1/2015 7:00 CW/DC 5/1/2015 12:45:19 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 5/27/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/9/2015
Report Number: M- W1505145-001

SAMPLE INFORMATION

Sample Number: 1505145-001 Customer Sample Number:
Location: 1a Type: Dist.
LPR 5025 BLAINE ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/19/2015 7:30 IC 5/21/2015 11:48:30 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/9/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/9/2015
Report Number: M- W1505145-002

SAMPLE INFORMATION

Sample Number: 1505145-002 Customer Sample Number:
Location: 1b Type: Dist.
LPR 5025 BLAINE ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/19/2015 7:30 IC 5/21/2015 11:48:30 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/9/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/9/2015
Report Number: M- W1505145-003

SAMPLE INFORMATION

Sample Number: 1505145-003
Location: 1c
LPR 5025 BLAINE ST NE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
5/19/2015	7:30	IC	5/21/2015 11:48:30 AM	JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	41.4 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	15.2 ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	15.3 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	18.3 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.2 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/9/2015
Report Number: M- W1505145-003

SAMPLE INFORMATION

Sample Number: 1505145-003 Customer Sample Number:
Location: 1c Type: Dist.
LPR 5025 BLAINE ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/19/2015 7:30 IC 5/21/2015 11:48:30 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/9/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/9/2015
Report Number: M- W1505145-004

SAMPLE INFORMATION

Sample Number: 1505145-004 Customer Sample Number:
Location: 1d Type: Dist.
LPR 5025 BLAINE ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/19/2015 7:30 IC 5/21/2015 11:48:30 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/9/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/9/2015
Report Number: M- W1505146-001

SAMPLE INFORMATION

Sample Number: 1505146-001 Customer Sample Number:
Location: #1 Type: Dist.
LPR 3209 HIGHLAND PL NW UNFILTERED (LEFT)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/19/2015 7:30 CW 5/21/2015 11:51:34 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/9/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/9/2015
Report Number: M- W1505146-002

SAMPLE INFORMATION

Sample Number: 1505146-002 Customer Sample Number:
Location: #2 Type: Dist.
LPR 3209 HIGHLAND PL NW UNFILTERED (LEFT)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/19/2015 7:30 CW 5/21/2015 11:51:34 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/9/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/9/2015
Report Number: M- W1505146-003

SAMPLE INFORMATION

Sample Number: 1505146-003 Customer Sample Number:
Location: #1 Type: Dist.
LPR 3209 HIGHLAND PL NW UNFILTERED (RIGHT)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/19/2015 7:30 CW 5/21/2015 11:51:34 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/9/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/9/2015
Report Number: M- W1505146-004

SAMPLE INFORMATION

Sample Number: 1505146-004 Customer Sample Number:
Location: #2 Type: Dist.
LPR 3209 HIGHLAND PL NW UNFILTERED (RIGHT)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/19/2015 7:30 CW 5/21/2015 11:51:34 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	34.6 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	111 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.67 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.2 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/9/2015
Report Number: M- W1505146-004

SAMPLE INFORMATION

Sample Number: 1505146-004 Customer Sample Number:
Location: #2 Type: Dist.
LPR 3209 HIGHLAND PL NW UNFILTERED (RIGHT)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/19/2015 7:30 CW 5/21/2015 11:51:34 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/9/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-001

SAMPLE INFORMATION

Sample Number: 1505034-001 Customer Sample Number:
Location: 01 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-002

SAMPLE INFORMATION

Sample Number: 1505034-002 Customer Sample Number:
Location: 01F Type: Dist.
LPR 3111 MLK AVE SE FILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-003

SAMPLE INFORMATION

Sample Number: 1505034-003
Location: 02
LPR 3111 MLK AVE SE UNFILTERED
Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015
Collection Time: 8:00
Sampler: CW/DC
Received Date and Time: 5/6/2015 11:34:10 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	82.5 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	11.0 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8 10x dilution	ug/L	ug/L	100 ug/L	1170 ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	398 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	45.1 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	27.8 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-003

SAMPLE INFORMATION

Sample Number: 1505034-003 Customer Sample Number:
Location: 02 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-004

SAMPLE INFORMATION

Sample Number: 1505034-004
Location: 02F
LPR 3111 MLK AVE SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Robert P. Hoffa, Laboratory Manager

6/11/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-005

SAMPLE INFORMATION

Sample Number: 1505034-005
Location: 03
LPR 3111 MLK AVE SE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	56.9 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	6.72 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8 2x dilution	ug/L	ug/L	20 ug/L	617 ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	245 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	34.3 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	18.5 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-005


SAMPLE INFORMATION

Sample Number: 1505034-005
Location: 03
LPR 3111 MLK AVE SE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: 
Robert P. Hoffa, Laboratory Manager

6/11/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-006

SAMPLE INFORMATION

Sample Number: 1505034-006
Location: 03F
LPR 3111 MLK AVE SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	13.2 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	69.0 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	12.8 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-006

SAMPLE INFORMATION

Sample Number: 1505034-006
Location: 03F
LPR 3111 MLK AVE SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Robert P. Hoffa, Laboratory Manager

6/11/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-007

SAMPLE INFORMATION

Sample Number: 1505034-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-008

SAMPLE INFORMATION

Sample Number: 1505034-008 Customer Sample Number:
Location: 04F Type: Dist.
LPR 3111 MLK AVE SE FILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	14.6 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	43.1 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	8.55 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-008

SAMPLE INFORMATION

Sample Number: 1505034-008 Customer Sample Number:
Location: 04F Type: Dist.
LPR 3111 MLK AVE SE FILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-009

SAMPLE INFORMATION

Sample Number: 1505034-009
Location: 05
LPR 3111 MLK AVE SE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	98.9 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	13.0 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8 5x dilution	ug/L	ug/L	50 ug/L	964 ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	100 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	20.7 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	10.7 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-009

SAMPLE INFORMATION

Sample Number: 1505034-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-010

SAMPLE INFORMATION

Sample Number: 1505034-010 Customer Sample Number:
Location: 05F Type: Dist.
LPR 3111 MLK AVE SE FILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-011

SAMPLE INFORMATION

Sample Number: 1505034-011 Customer Sample Number:
Location: 06 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	48.9 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.10 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	454 ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	32.8 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.82 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.70 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-011

SAMPLE INFORMATION

Sample Number: 1505034-011 Customer Sample Number:
Location: 06 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-012

SAMPLE INFORMATION

Sample Number: 1505034-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 3111 MLK AVE SE FILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-013

SAMPLE INFORMATION

Sample Number: 1505034-013
Location: 07
LPR 3111 MLK AVE SE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	32.8 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.46 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	305 ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	26.1 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	12.2 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.74 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-013

SAMPLE INFORMATION

Sample Number: 1505034-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-014

SAMPLE INFORMATION

Sample Number: 1505034-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 3111 MLK AVE SE FILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-015

SAMPLE INFORMATION

Sample Number: 1505034-015 Customer Sample Number:
Location: 08 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 8:00 CW/DC 5/6/2015 11:34:10 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-016


SAMPLE INFORMATION

Sample Number: 1505034-016
Location: 08F
LPR 3111 MLK AVE SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: 
Robert P. Hoffa, Laboratory Manager

6/11/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-017

SAMPLE INFORMATION

Sample Number: 1505034-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-018

SAMPLE INFORMATION

Sample Number: 1505034-018
Location: 09F
LPR 3111 MLK AVE SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Robert P. Hoffa, Laboratory Manager

6/11/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-019

SAMPLE INFORMATION

Sample Number: 1505034-019 Customer Sample Number:
Location: 10 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-020

SAMPLE INFORMATION

Sample Number: 1505034-020
Location: 10F
LPR 3111 MLK AVE SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015	Collection Time: 8:00	Sampler: CW/DC	Received Date and Time: 5/6/2015 11:34:10 AM	Received By: JCross
------------------------------	--------------------------	-------------------	---	------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	15.3 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.10 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.78 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.23 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-021

SAMPLE INFORMATION

Sample Number: 1505034-021 Customer Sample Number:
Location: 11 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 8:00 CW/DC 5/6/2015 11:34:10 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-022

SAMPLE INFORMATION

Sample Number: 1505034-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 3111 MLK AVE SE FILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-023

SAMPLE INFORMATION

Sample Number: 1505034-023 Customer Sample Number:
Location: 12 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-024

SAMPLE INFORMATION

Sample Number: 1505034-024
Location: 12F
LPR 3111 MLK AVE SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015	Collection Time: 8:00	Sampler: CW/DC	Received Date and Time: 5/6/2015 11:34:10 AM	Received By: JCross
------------------------------	--------------------------	-------------------	---	------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	16.0 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.11 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.39 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.32 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-024

SAMPLE INFORMATION

Sample Number: 1505034-024 Customer Sample Number:
Location: 12F Type: Dist.
LPR 3111 MLK AVE SE FILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-025

SAMPLE INFORMATION

Sample Number: 1505034-025 Customer Sample Number:
Location: 13 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-026

SAMPLE INFORMATION

Sample Number: 1505034-026 Customer Sample Number:
Location: 13F Type: Dist.
LPR 3111 MLK AVE SE FILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-027

SAMPLE INFORMATION

Sample Number: 1505034-027
Location: 14
LPR 3111 MLK AVE SE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	24.8 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.96 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	228 ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	15.4 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.46 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-027

SAMPLE INFORMATION

Sample Number: 1505034-027 Customer Sample Number:
Location: 14 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 8:00 CW/DC 5/6/2015 11:34:10 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-028

SAMPLE INFORMATION

Sample Number: 1505034-028
Location: 14F
LPR 3111 MLK AVE SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	15.6 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.50 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.22 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.13 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-029

SAMPLE INFORMATION

Sample Number: 1505034-029
Location: 15
LPR 3111 MLK AVE SE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015	Collection Time: 8:00	Sampler: CW/DC	Received Date and Time: 5/6/2015 11:34:10 AM	Received By: JCross
------------------------------	--------------------------	-------------------	---	------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	25.1 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.30 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	230 ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	15.4 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.27 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-029

SAMPLE INFORMATION

Sample Number: 1505034-029 Customer Sample Number:
Location: 15 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 8:00 CW/DC 5/6/2015 11:34:10 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-030

SAMPLE INFORMATION

Sample Number: 1505034-030 Customer Sample Number:
Location: 15F Type: Dist.
LPR 3111 MLK AVE SE FILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-031

SAMPLE INFORMATION

Sample Number: 1505034-031
Location: 16
LPR 3111 MLK AVE SE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	25.9 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.23 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	222 ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	13.9 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.76 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-031


SAMPLE INFORMATION

Sample Number: 1505034-031
Location: 16
LPR 3111 MLK AVE SE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: 
Robert P. Hoffa, Laboratory Manager

6/11/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-032

SAMPLE INFORMATION

Sample Number: 1505034-032 Customer Sample Number:
Location: 16F Type: Dist.
LPR 3111 MLK AVE SE FILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-033

SAMPLE INFORMATION

Sample Number: 1505034-033
Location: 17
LPR 3111 MLK AVE SE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	23.7 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.19 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	222 ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	14.1 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.13 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-033

SAMPLE INFORMATION

Sample Number: 1505034-033 Customer Sample Number:
Location: 17 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-034

SAMPLE INFORMATION

Sample Number: 1505034-034
Location: 17F
LPR 3111 MLK AVE SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	15.1 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.67 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	6.94 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.16 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-034

SAMPLE INFORMATION

Sample Number: 1505034-034 Customer Sample Number:
Location: 17F Type: Dist.
LPR 3111 MLK AVE SE FILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-035

SAMPLE INFORMATION

Sample Number: 1505034-035
Location: 18
LPR 3111 MLK AVE SE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
5/5/2015	8:00	CW/DC	5/6/2015 11:34:10 AM	JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	23.7 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.20 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	219 ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	15.9 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	10.5 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-035

SAMPLE INFORMATION

Sample Number: 1505034-035 Customer Sample Number:
Location: 18 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 8:00 CW/DC 5/6/2015 11:34:10 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-036

SAMPLE INFORMATION

Sample Number: 1505034-036 Customer Sample Number:
Location: 18F Type: Dist.
LPR 3111 MLK AVE SE FILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-037

SAMPLE INFORMATION

Sample Number: 1505034-037
Location: 19
LPR 3111 MLK AVE SE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
5/5/2015	8:00	CW/DC	5/6/2015 11:34:10 AM	JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	23.9 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.21 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	221 ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	13.6 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.85 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-037

SAMPLE INFORMATION

Sample Number: 1505034-037 Customer Sample Number:
Location: 19 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-038

SAMPLE INFORMATION

Sample Number: 1505034-038 Customer Sample Number:
Location: 19F Type: Dist.
LPR 3111 MLK AVE SE FILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-039

SAMPLE INFORMATION

Sample Number: 1505034-039
Location: 20
LPR 3111 MLK AVE SE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	24.8 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.23 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	222 ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	13.7 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.49 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-039

SAMPLE INFORMATION

Sample Number: 1505034-039
Location: 20
LPR 3111 MLK AVE SE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Robert P. Hoffa, Laboratory Manager

6/11/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-040

SAMPLE INFORMATION

Sample Number: 1505034-040
Location: 20F
LPR 3111 MLK AVE SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	15.8 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.80 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	6.99 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	1.92 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-040

SAMPLE INFORMATION

Sample Number: 1505034-040 Customer Sample Number:
Location: 20F Type: Dist.
LPR 3111 MLK AVE SE FILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-041

SAMPLE INFORMATION

Sample Number: 1505034-041 Customer Sample Number:
Location: H1 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 8:00 CW/DC 5/6/2015 11:34:10 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-042

SAMPLE INFORMATION

Sample Number: 1505034-042 Customer Sample Number:
Location: H2 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-043

SAMPLE INFORMATION

Sample Number: 1505034-043 Customer Sample Number:
Location: H3 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-044

SAMPLE INFORMATION

Sample Number: 1505034-044
Customer Sample Number:
Location: H4
Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED

Collection Date: 5/5/2015
Collection Time: 8:00
Sampler: CW/DC
Received Date and Time: 5/6/2015 11:34:10 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	51.5 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.25 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	460 ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	93.5 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	17.2 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.05 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-044

SAMPLE INFORMATION

Sample Number: 1505034-044 Customer Sample Number:
Location: H4 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 8:00 CW/DC 5/6/2015 11:34:10 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-045

SAMPLE INFORMATION

Sample Number: 1505034-045 Customer Sample Number:
Location: H5 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED

Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	46.0 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.43 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	413 ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	69.1 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	14.0 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	6.18 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-045

SAMPLE INFORMATION

Sample Number: 1505034-045 Customer Sample Number:
Location: H5 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-046

SAMPLE INFORMATION

Sample Number: 1505034-046 Customer Sample Number:
Location: H6 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-047

SAMPLE INFORMATION

Sample Number: 1505034-047 Customer Sample Number:
Location: H7 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	33.0 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.93 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	317 ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	43.3 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	8.18 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.10 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-047

SAMPLE INFORMATION

Sample Number: 1505034-047 Customer Sample Number:
Location: H7 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-048

SAMPLE INFORMATION

Sample Number: 1505034-048 Customer Sample Number:
Location: H8 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	32.5 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	6.01 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	321 ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	37.6 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	9.39 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.01 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-048

SAMPLE INFORMATION

Sample Number: 1505034-048 Customer Sample Number:
Location: H8 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-049

SAMPLE INFORMATION

Sample Number: 1505034-049 Customer Sample Number:
Location: H9 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-050

SAMPLE INFORMATION

Sample Number: 1505034-050 Customer Sample Number:
Location: H10 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	31.1 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.88 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	310 ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	32.2 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.54 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.29 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-050

SAMPLE INFORMATION

Sample Number: 1505034-050 Customer Sample Number:
Location: H10 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-051

SAMPLE INFORMATION

Sample Number: 1505034-051 Customer Sample Number:
Location: H11 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-052

SAMPLE INFORMATION

Sample Number: 1505034-052 Customer Sample Number:
Location: H12 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-053

SAMPLE INFORMATION

Sample Number: 1505034-053 Customer Sample Number:
Location: H13 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	30.1 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.95 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	301 ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	27.7 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.06 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.13 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-053

SAMPLE INFORMATION

Sample Number: 1505034-053 Customer Sample Number:
Location: H13 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-054

SAMPLE INFORMATION

Sample Number: 1505034-054 Customer Sample Number:
Location: H14 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-055

SAMPLE INFORMATION

Sample Number: 1505034-055 Customer Sample Number:
Location: H15 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	31.2 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.91 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	296 ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	24.6 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	6.79 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.05 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-055

SAMPLE INFORMATION

Sample Number: 1505034-055 Customer Sample Number:
Location: H15 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-056

SAMPLE INFORMATION

Sample Number: 1505034-056 Customer Sample Number:
Location: H16 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 8:00 CW/DC 5/6/2015 11:34:10 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-057

SAMPLE INFORMATION

Sample Number: 1505034-057 Customer Sample Number:
Location: H17 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-058

SAMPLE INFORMATION

Sample Number: 1505034-058 Customer Sample Number:
Location: H18 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-059

SAMPLE INFORMATION

Sample Number: 1505034-059 Customer Sample Number:
Location: H19 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	26.6 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.85 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	255 ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	21.1 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.83 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.03 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-059

SAMPLE INFORMATION

Sample Number: 1505034-059 Customer Sample Number:
Location: H19 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/11/2015
Report Number: M- W1505034-060

SAMPLE INFORMATION

Sample Number: 1505034-060 Customer Sample Number:
Location: H20 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/5/2015 Collection Time: 8:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:34:10 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/11/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-001

SAMPLE INFORMATION

Sample Number: 1505154-001
Location: 01
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Robert P. Hoffa, Laboratory Manager

6/17/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-002

SAMPLE INFORMATION

Sample Number: 1505154-002 Customer Sample Number:
Location: 01F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	58.7 ug/L	6/8/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.0 ug/L	6/8/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/8/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	48.7 ug/L	6/8/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	51.7 ug/L	6/8/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.93 ug/L	6/8/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-002

SAMPLE INFORMATION

Sample Number: 1505154-002 Customer Sample Number:
Location: 01F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/21/2015 9:00 CW/DC 5/22/2015 8:54:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-003

SAMPLE INFORMATION

Sample Number: 1505154-003
Location: 02
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	61.5 ug/L	6/8/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	6/8/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	27.9 ug/L	6/8/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	54.0 ug/L	6/8/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.07 ug/L	6/8/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	11.2 ug/L	6/8/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-003

SAMPLE INFORMATION

Sample Number: 1505154-003 Customer Sample Number:
Location: 02 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-004

SAMPLE INFORMATION

Sample Number: 1505154-004 Customer Sample Number:
Location: 02F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/21/2015 9:00 CW/DC 5/22/2015 8:54:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-005

SAMPLE INFORMATION

Sample Number: 1505154-005 Customer Sample Number:
Location: 03 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/21/2015 9:00 CW/DC 5/22/2015 8:54:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/17/2015
Report Number: M- W1505154-006

SAMPLE INFORMATION

Sample Number: 1505154-006 Customer Sample Number:
Location: 03F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/21/2015 9:00 CW/DC 5/22/2015 8:54:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-007

SAMPLE INFORMATION

Sample Number: 1505154-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/21/2015 9:00 CW/DC 5/22/2015 8:54:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-008

SAMPLE INFORMATION

Sample Number: 1505154-008 Customer Sample Number:
Location: 04F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	46.8 ug/L	6/8/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	6/8/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/8/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	50.1 ug/L	6/8/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	6.10 ug/L	6/8/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.02 ug/L	6/8/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-008

SAMPLE INFORMATION

Sample Number: 1505154-008 Customer Sample Number:
Location: 04F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/21/2015 9:00 CW/DC 5/22/2015 8:54:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-009

SAMPLE INFORMATION

Sample Number: 1505154-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/21/2015 9:00 CW/DC 5/22/2015 8:54:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-010

SAMPLE INFORMATION

Sample Number: 1505154-010 Customer Sample Number:
Location: 05F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/21/2015 9:00 CW/DC 5/22/2015 8:54:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-011

SAMPLE INFORMATION

Sample Number: 1505154-011
Location: 06
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	52.2 ug/L	6/8/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	6/8/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	29.5 ug/L	6/8/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	58.5 ug/L	6/8/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.98 ug/L	6/8/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	11.4 ug/L	6/8/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-011

SAMPLE INFORMATION

Sample Number: 1505154-011
Location: 06
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Robert P. Hoffa, Laboratory Manager

6/17/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-012

SAMPLE INFORMATION

Sample Number: 1505154-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	42.7 ug/L	6/8/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	6/8/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/8/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	45.4 ug/L	6/8/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.73 ug/L	6/8/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.75 ug/L	6/8/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-012

SAMPLE INFORMATION

Sample Number: 1505154-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-013

SAMPLE INFORMATION

Sample Number: 1505154-013
Location: 07
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	51.6 ug/L	6/8/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	6/8/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	32.7 ug/L	6/8/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	63.1 ug/L	6/8/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.48 ug/L	6/8/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	12.4 ug/L	6/8/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-013


SAMPLE INFORMATION

Sample Number: 1505154-013
Location: 07
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: 
Robert P. Hoffa, Laboratory Manager

6/17/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-014

SAMPLE INFORMATION

Sample Number: 1505154-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-015

SAMPLE INFORMATION

Sample Number: 1505154-015
Location: 08
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	52.4 ug/L	6/8/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	6/8/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	33.2 ug/L	6/8/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	59.4 ug/L	6/8/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.44 ug/L	6/8/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	12.4 ug/L	6/8/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-015

SAMPLE INFORMATION

Sample Number: 1505154-015 Customer Sample Number:
Location: 08 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/21/2015 9:00 CW/DC 5/22/2015 8:54:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-016

SAMPLE INFORMATION

Sample Number: 1505154-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/21/2015 9:00 CW/DC 5/22/2015 8:54:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-017

SAMPLE INFORMATION

Sample Number: 1505154-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	52.9 ug/L	6/8/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.0 ug/L	6/8/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	35.1 ug/L	6/8/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	58.0 ug/L	6/8/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.58 ug/L	6/8/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	13.8 ug/L	6/8/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/17/2015
Report Number: M- W1505154-017

SAMPLE INFORMATION

Sample Number: 1505154-017
Customer Sample Number:
Location: 09
Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: 5/21/2015
Collection Time: 9:00
Sampler: CW/DC
Received Date and Time: 5/22/2015 8:54:58 AM
Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-018

SAMPLE INFORMATION

Sample Number: 1505154-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-019

SAMPLE INFORMATION

Sample Number: 1505154-019
Location: 10
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	54.2 ug/L	6/8/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.06 ug/L	6/8/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	41.9 ug/L	6/8/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	58.7 ug/L	6/8/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.67 ug/L	6/8/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	17.9 ug/L	6/8/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-019

SAMPLE INFORMATION


Sample Number: 1505154-019
Location: 10
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-020

SAMPLE INFORMATION

Sample Number: 1505154-020 Customer Sample Number:
Location: 10F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/21/2015 9:00 CW/DC 5/22/2015 8:54:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-021

SAMPLE INFORMATION

Sample Number: 1505154-021
Location: 11
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	57.2 ug/L	6/8/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.05 ug/L	6/8/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	39.9 ug/L	6/8/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	55.7 ug/L	6/8/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.46 ug/L	6/8/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	18.7 ug/L	6/8/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-021

SAMPLE INFORMATION

Sample Number: 1505154-021
Location: 11
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Robert P. Hoffa, Laboratory Manager

6/17/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-022

SAMPLE INFORMATION

Sample Number: 1505154-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/21/2015 9:00 CW/DC 5/22/2015 8:54:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-023

SAMPLE INFORMATION

Sample Number: 1505154-023
Location: 12
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Robert P. Hoffa, Laboratory Manager

6/17/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-024

SAMPLE INFORMATION

Sample Number: 1505154-024
Location: 12F
LPR 3121 MLK AVE SE (FILTERED)
Customer Sample Number:
Type: Dist.
Collection Date: 5/21/2015
Collection Time: 9:00
Sampler: CW/DC
Received Date and Time: 5/22/2015 8:54:58 AM
Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Robert P. Hoffa, Laboratory Manager
6/17/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-025

SAMPLE INFORMATION

Sample Number: 1505154-025
Location: 13
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	60.6 ug/L	6/8/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.23 ug/L	6/8/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	45.9 ug/L	6/8/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	57.8 ug/L	6/8/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	6.42 ug/L	6/8/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	22.3 ug/L	6/8/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-025

SAMPLE INFORMATION


Sample Number: 1505154-025
Location: 13
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-026

SAMPLE INFORMATION

Sample Number: 1505154-026 Customer Sample Number:
Location: 13F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/21/2015 9:00 CW/DC 5/22/2015 8:54:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-027

SAMPLE INFORMATION

Sample Number: 1505154-027 Customer Sample Number:
Location: 14 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/21/2015 9:00 CW/DC 5/22/2015 8:54:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-028

SAMPLE INFORMATION

Sample Number: 1505154-028 Customer Sample Number:
Location: 14F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/21/2015 9:00 CW/DC 5/22/2015 8:54:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-029

SAMPLE INFORMATION


Sample Number: 1505154-029
Location: 15
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-030

SAMPLE INFORMATION

Sample Number: 1505154-030 Customer Sample Number:
Location: 15F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/21/2015 9:00 CW/DC 5/22/2015 8:54:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-031

SAMPLE INFORMATION

Sample Number: 1505154-031
Location: 16
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	47.0 ug/L	6/8/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.47 ug/L	6/8/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	48.6 ug/L	6/8/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	74.6 ug/L	6/8/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	8.56 ug/L	6/8/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	47.8 ug/L	6/8/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-031


SAMPLE INFORMATION

Sample Number: 1505154-031
Location: 16
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: 
Robert P. Hoffa, Laboratory Manager

6/17/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-032

SAMPLE INFORMATION

Sample Number: 1505154-032 Customer Sample Number:
Location: 16F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	42.6 ug/L	6/8/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	6/8/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/8/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	45.6 ug/L	6/8/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.69 ug/L	6/8/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.16 ug/L	6/8/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-032


SAMPLE INFORMATION

Sample Number: 1505154-032
Location: 16F
LPR 3121 MLK AVE SE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: 
Robert P. Hoffa, Laboratory Manager

6/17/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-033

SAMPLE INFORMATION

Sample Number: 1505154-033
Location: 17
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Robert P. Hoffa, Laboratory Manager

6/17/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-034

SAMPLE INFORMATION

Sample Number: 1505154-034
Customer Sample Number:
Location: 17F
Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: 5/21/2015
Collection Time: 9:00
Sampler: CW/DC
Received Date and Time: 5/22/2015 8:54:58 AM
Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Robert P. Hoffa, Laboratory Manager
6/17/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-035

SAMPLE INFORMATION

Sample Number: 1505154-035
Location: 18
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	47.3 ug/L	6/8/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.46 ug/L	6/8/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	50.5 ug/L	6/8/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	92.0 ug/L	6/8/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	10.7 ug/L	6/8/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.68 ug/L	6/8/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-035

SAMPLE INFORMATION


Sample Number: 1505154-035
Location: 18
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-036

SAMPLE INFORMATION

Sample Number: 1505154-036
Location: 18F
LPR 3121 MLK AVE SE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	40.9 ug/L	6/8/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	6/8/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/8/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	46.0 ug/L	6/8/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	6.30 ug/L	6/8/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	6/8/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-037

SAMPLE INFORMATION

Sample Number: 1505154-037
Location: 19
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	46.6 ug/L	6/8/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.47 ug/L	6/8/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	53.2 ug/L	6/8/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	82.4 ug/L	6/8/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	13.1 ug/L	6/8/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.56 ug/L	6/8/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-037

SAMPLE INFORMATION

Sample Number: 1505154-037 Customer Sample Number:
Location: 19 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/21/2015 9:00 CW/DC 5/22/2015 8:54:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-038

SAMPLE INFORMATION

Sample Number: 1505154-038 Customer Sample Number:
Location: 19F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/21/2015 9:00 CW/DC 5/22/2015 8:54:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-039

SAMPLE INFORMATION

Sample Number: 1505154-039
Location: 20
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	48.9 ug/L	6/8/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.52 ug/L	6/8/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	56.6 ug/L	6/8/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	58.1 ug/L	6/8/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.00 ug/L	6/8/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.08 ug/L	6/8/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-039

SAMPLE INFORMATION

Sample Number: 1505154-039
Location: 20
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Robert P. Hoffa, Laboratory Manager

6/17/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-040

SAMPLE INFORMATION

Sample Number: 1505154-040
Location: 20F
LPR 3121 MLK AVE SE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	42.6 ug/L	6/8/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	6/8/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/8/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	37.0 ug/L	6/8/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.17 ug/L	6/8/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.2 ug/L	6/8/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-040

SAMPLE INFORMATION


Sample Number: 1505154-040
Location: 20F
LPR 3121 MLK AVE SE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/17/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-041

SAMPLE INFORMATION

Sample Number: 1505154-041 Customer Sample Number:
Location: H1 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/21/2015 9:00 CW/DC 5/22/2015 8:54:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-042

SAMPLE INFORMATION

Sample Number: 1505154-042 Customer Sample Number:
Location: H2 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-043

SAMPLE INFORMATION

Sample Number: 1505154-043 Customer Sample Number:
Location: H3 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/21/2015 9:00 CW/DC 5/22/2015 8:54:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-044

SAMPLE INFORMATION

Sample Number: 1505154-044 Customer Sample Number:
Location: H4 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-045

SAMPLE INFORMATION

Sample Number: 1505154-045 Customer Sample Number:
Location: H5 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/21/2015 9:00 CW/DC 5/22/2015 8:54:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-046

SAMPLE INFORMATION

Sample Number: 1505154-046 Customer Sample Number:
Location: H6 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/21/2015 9:00 CW/DC 5/22/2015 8:54:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-047

SAMPLE INFORMATION

Sample Number: 1505154-047 Customer Sample Number:
Location: H7 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/21/2015 9:00 CW/DC 5/22/2015 8:54:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-048

SAMPLE INFORMATION

Sample Number: 1505154-048 Customer Sample Number:
Location: H8 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	49.3 ug/L	6/8/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.15 ug/L	6/8/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	58.0 ug/L	6/8/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	18.2 ug/L	6/8/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.66 ug/L	6/8/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	12.2 ug/L	6/8/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-048

SAMPLE INFORMATION

Sample Number: 1505154-048 Customer Sample Number:
Location: H8 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/21/2015 9:00 CW/DC 5/22/2015 8:54:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-049

SAMPLE INFORMATION

Sample Number: 1505154-049 Customer Sample Number:
Location: H9 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/21/2015 9:00 CW/DC 5/22/2015 8:54:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-050

SAMPLE INFORMATION

Sample Number: 1505154-050 Customer Sample Number:
Location: H10 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/21/2015 9:00 CW/DC 5/22/2015 8:54:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-051

SAMPLE INFORMATION

Sample Number: 1505154-051
Customer Sample Number:
Location: H11
Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: 5/21/2015
Collection Time: 9:00
Sampler: CW/DC
Received Date and Time: 5/22/2015 8:54:58 AM
Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	45.6 ug/L	6/8/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.45 ug/L	6/8/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	54.8 ug/L	6/8/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	16.2 ug/L	6/8/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.50 ug/L	6/8/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.75 ug/L	6/8/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-051

SAMPLE INFORMATION

Sample Number: 1505154-051 Customer Sample Number:
Location: H11 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/21/2015 9:00 CW/DC 5/22/2015 8:54:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-052

SAMPLE INFORMATION

Sample Number: 1505154-052 Customer Sample Number:
Location: H12 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/21/2015 9:00 CW/DC 5/22/2015 8:54:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-053

SAMPLE INFORMATION

Sample Number: 1505154-053 Customer Sample Number:
Location: H13 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	53.6 ug/L	6/8/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.61 ug/L	6/8/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	70.7 ug/L	6/8/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	16.5 ug/L	6/8/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.13 ug/L	6/8/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	24.9 ug/L	6/8/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-053

SAMPLE INFORMATION

Sample Number: 1505154-053 Customer Sample Number:
Location: H13 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/21/2015 9:00 CW/DC 5/22/2015 8:54:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-054

SAMPLE INFORMATION

Sample Number: 1505154-054 Customer Sample Number:
Location: H14 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/21/2015 9:00 CW/DC 5/22/2015 8:54:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-055

SAMPLE INFORMATION

Sample Number: 1505154-055
Customer Sample Number:
Location: H15
Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: 5/21/2015
Collection Time: 9:00
Sampler: CW/DC
Received Date and Time: 5/22/2015 8:54:58 AM
Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Robert P. Hoffa, Laboratory Manager
6/17/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-056

SAMPLE INFORMATION

Sample Number: 1505154-056 Customer Sample Number:
Location: H16 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	44.1 ug/L	6/8/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.56 ug/L	6/8/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	56.0 ug/L	6/8/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	41.6 ug/L	6/8/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.79 ug/L	6/8/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	37.1 ug/L	6/8/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-056

SAMPLE INFORMATION

Sample Number: 1505154-056 Customer Sample Number:
Location: H16 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/21/2015 9:00 CW/DC 5/22/2015 8:54:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-057

SAMPLE INFORMATION

Sample Number: 1505154-057 Customer Sample Number:
Location: H17 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	43.4 ug/L	6/8/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.56 ug/L	6/8/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	52.9 ug/L	6/8/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	48.4 ug/L	6/8/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.30 ug/L	6/8/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	25.0 ug/L	6/8/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-057

SAMPLE INFORMATION

Sample Number: 1505154-057 Customer Sample Number:
Location: H17 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/21/2015 9:00 CW/DC 5/22/2015 8:54:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-058

SAMPLE INFORMATION

Sample Number: 1505154-058 Customer Sample Number:
Location: H18 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	44.5 ug/L	6/8/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.57 ug/L	6/8/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	69.1 ug/L	6/8/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	76.7 ug/L	6/8/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.81 ug/L	6/8/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	37.0 ug/L	6/8/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-058

SAMPLE INFORMATION

Sample Number: 1505154-058 Customer Sample Number:
Location: H18 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/21/2015 9:00 CW/DC 5/22/2015 8:54:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-059

SAMPLE INFORMATION

Sample Number: 1505154-059 Customer Sample Number:
Location: H19 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: 5/21/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/22/2015 8:54:58 AM Received By: TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/17/2015
Report Number: M- W1505154-060

SAMPLE INFORMATION

Sample Number: 1505154-060 Customer Sample Number:
Location: H20 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/21/2015 9:00 CW/DC 5/22/2015 8:54:58 AM TPasquale

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/17/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-001

SAMPLE INFORMATION

Sample Number: 1505033-001 Customer Sample Number:
Location: 01 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-002

SAMPLE INFORMATION

Sample Number: 1505033-002 Customer Sample Number:
Location: 01F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-003

SAMPLE INFORMATION

Sample Number: 1505033-003
Location: 02
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:15:04 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Robert P. Hoffa, Laboratory Manager

6/25/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-004

SAMPLE INFORMATION

Sample Number: 1505033-004 Customer Sample Number:
Location: 02F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: 5/5/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:15:04 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	15.6 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	37.9 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	11.3 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-004

SAMPLE INFORMATION

Sample Number: 1505033-004 Customer Sample Number:
Location: 02F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-005

SAMPLE INFORMATION

Sample Number: 1505033-005
Location: 03
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015	Collection Time: 9:00	Sampler: CW/DC	Received Date and Time: 5/6/2015 11:15:04 AM	Received By: LGallimore
------------------------------	--------------------------	-------------------	---	----------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	24.5 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.13 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	92.9 ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	66.6 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	10.8 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.71 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-005

SAMPLE INFORMATION


Sample Number: 1505033-005
Location: 03
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:15:04 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/25/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-006

SAMPLE INFORMATION

Sample Number: 1505033-006 Customer Sample Number:
Location: 03F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-007

SAMPLE INFORMATION

Sample Number: 1505033-007
Location: 04
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:15:04 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	24.0 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.06 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	92.6 ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	56.8 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	15.1 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.66 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-007

SAMPLE INFORMATION

Sample Number: 1505033-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-008

SAMPLE INFORMATION

Sample Number: 1505033-008 Customer Sample Number:
Location: 04F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: 5/5/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:15:04 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	14.9 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	37.9 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.93 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-008

SAMPLE INFORMATION

Sample Number: 1505033-008 Customer Sample Number:
Location: 04F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-009

SAMPLE INFORMATION

Sample Number: 1505033-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: 5/5/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:15:04 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	22.6 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	80.9 ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	56.1 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	9.25 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.12 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-009

SAMPLE INFORMATION

Sample Number: 1505033-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/25/2015
Report Number: M- W1505033-010

SAMPLE INFORMATION

Sample Number: 1505033-010 Customer Sample Number:
Location: 05F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/25/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-011

SAMPLE INFORMATION


Sample Number: 1505033-011
Location: 06
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:15:04 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/25/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-012

SAMPLE INFORMATION

Sample Number: 1505033-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: 5/5/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:15:04 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-013

SAMPLE INFORMATION

Sample Number: 1505033-013
Location: 07
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015	Collection Time: 9:00	Sampler: CW/DC	Received Date and Time: 5/6/2015 11:15:04 AM	Received By: LGallimore
------------------------------	--------------------------	-------------------	---	----------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	21.8 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	72.7 ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	43.1 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	10.3 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.17 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-013

SAMPLE INFORMATION

Sample Number: 1505033-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-014

SAMPLE INFORMATION

Sample Number: 1505033-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/25/2015
Report Number: M- W1505033-015

SAMPLE INFORMATION

Sample Number: 1505033-015
Location: 08
LPR 3121 MLK AVE SE (UNFILTERED)
Customer Sample Number:
Type: Dist.
Collection Date: 5/5/2015
Collection Time: 9:00
Sampler: CW/DC
Received Date and Time: 5/6/2015 11:15:04 AM
Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/25/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-016

SAMPLE INFORMATION

Sample Number: 1505033-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: 5/5/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:15:04 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	14.6 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	33.5 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.84 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-016

SAMPLE INFORMATION

Sample Number: 1505033-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-017

SAMPLE INFORMATION

Sample Number: 1505033-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: 5/5/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:15:04 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	22.5 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	74.6 ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	46.4 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	19.5 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.89 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-017

SAMPLE INFORMATION

Sample Number: 1505033-017
Location: 09
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:15:04 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Robert P. Hoffa, Laboratory Manager

6/25/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-018

SAMPLE INFORMATION

Sample Number: 1505033-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: 5/5/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:15:04 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	14.4 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	32.6 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	6.80 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-018

SAMPLE INFORMATION

Sample Number: 1505033-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: 5/5/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:15:04 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-019

SAMPLE INFORMATION

Sample Number: 1505033-019
Location: 10
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015	Collection Time: 9:00	Sampler: CW/DC	Received Date and Time: 5/6/2015 11:15:04 AM	Received By: LGallimore
------------------------------	--------------------------	-------------------	---	----------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	22.7 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	75.0 ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	42.9 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.87 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.75 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-019

SAMPLE INFORMATION


Sample Number: 1505033-019
Location: 10
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:15:04 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/25/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-020

SAMPLE INFORMATION

Sample Number: 1505033-020 Customer Sample Number:
Location: 10F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: 5/5/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:15:04 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-021


SAMPLE INFORMATION

Sample Number: 1505033-021
Location: 11
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:15:04 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: 
Robert P. Hoffa, Laboratory Manager

6/25/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-022

SAMPLE INFORMATION

Sample Number: 1505033-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: 5/5/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:15:04 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-023

SAMPLE INFORMATION

Sample Number: 1505033-023
Location: 12
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015	Collection Time: 9:00	Sampler: CW/DC	Received Date and Time: 5/6/2015 11:15:04 AM	Received By: LGallimore
------------------------------	--------------------------	-------------------	---	----------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	23.8 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.23 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	97.3 ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	56.3 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	52.8 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.61 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-023

SAMPLE INFORMATION

Sample Number: 1505033-023 Customer Sample Number:
Location: 12 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-024

SAMPLE INFORMATION

Sample Number: 1505033-024 Customer Sample Number:
Location: 12F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-025

SAMPLE INFORMATION

Sample Number: 1505033-025
Location: 13
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015	Collection Time: 9:00	Sampler: CW/DC	Received Date and Time: 5/6/2015 11:15:04 AM	Received By: LGallimore
------------------------------	--------------------------	-------------------	---	----------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	19.8 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.20 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	101 ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	37.4 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.24 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	11.4 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-025

SAMPLE INFORMATION

Sample Number: 1505033-025 Customer Sample Number:
Location: 13 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-026

SAMPLE INFORMATION

Sample Number: 1505033-026 Customer Sample Number:
Location: 13F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: 5/5/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:15:04 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	11.7 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	24.9 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	6.73 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-026

SAMPLE INFORMATION

Sample Number: 1505033-026 Customer Sample Number:
Location: 13F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-027

SAMPLE INFORMATION

Sample Number: 1505033-027
Location: 14
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015	Collection Time: 9:00	Sampler: CW/DC	Received Date and Time: 5/6/2015 11:15:04 AM	Received By: LGallimore
------------------------------	--------------------------	-------------------	---	----------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	18.7 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.19 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	98.8 ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	18.3 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.44 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	16.6 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-027

SAMPLE INFORMATION

Sample Number: 1505033-027 Customer Sample Number:
Location: 14 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-028

SAMPLE INFORMATION

Sample Number: 1505033-028 Customer Sample Number:
Location: 14F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: 5/5/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:15:04 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	12.8 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.83 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.9 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-028

SAMPLE INFORMATION

Sample Number: 1505033-028 Customer Sample Number:
Location: 14F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-029

SAMPLE INFORMATION

Sample Number: 1505033-029
Location: 15
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:15:04 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	17.7 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.15 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	93.8 ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	14.6 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.38 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	15.9 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-029

SAMPLE INFORMATION

Sample Number: 1505033-029
Location: 15
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:15:04 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Robert P. Hoffa, Laboratory Manager

6/25/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-030

SAMPLE INFORMATION

Sample Number: 1505033-030
Customer Sample Number:
Location: 15F
Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: 5/5/2015
Collection Time: 9:00
Sampler: CW/DC
Received Date and Time: 5/6/2015 11:15:04 AM
Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: 
Robert P. Hoffa, Laboratory Manager
6/25/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-031

SAMPLE INFORMATION

Sample Number: 1505033-031
Location: 16
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015	Collection Time: 9:00	Sampler: CW/DC	Received Date and Time: 5/6/2015 11:15:04 AM	Received By: LGallimore
------------------------------	--------------------------	-------------------	---	----------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	19.4 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.16 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	98.5 ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	16.2 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	6.84 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	16.7 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-031


SAMPLE INFORMATION

Sample Number: 1505033-031
Location: 16
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:15:04 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: 
Robert P. Hoffa, Laboratory Manager

6/25/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-032

SAMPLE INFORMATION

Sample Number: 1505033-032 Customer Sample Number:
Location: 16F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: 5/5/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:15:04 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	11.5 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.44 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.10 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-032

SAMPLE INFORMATION

Sample Number: 1505033-032 Customer Sample Number:
Location: 16F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-033

SAMPLE INFORMATION

Sample Number: 1505033-033
Location: 17
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:15:04 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	22.7 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.38 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	123 ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	22.3 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	6.20 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	16.2 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-033

SAMPLE INFORMATION

Sample Number: 1505033-033 Customer Sample Number:
Location: 17 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-034

SAMPLE INFORMATION

Sample Number: 1505033-034 Customer Sample Number:
Location: 17F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: 5/5/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:15:04 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	10.7 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	13.8 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.91 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-034

SAMPLE INFORMATION

Sample Number: 1505033-034 Customer Sample Number:
Location: 17F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: 5/5/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:15:04 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-035

SAMPLE INFORMATION

Sample Number: 1505033-035
Location: 18
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:15:04 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	20.7 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.35 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	116 ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	18.5 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.39 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	15.8 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-035

SAMPLE INFORMATION

Sample Number: 1505033-035 Customer Sample Number:
Location: 18 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-036

SAMPLE INFORMATION

Sample Number: 1505033-036 Customer Sample Number:
Location: 18F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: 5/5/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:15:04 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	10.7 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	11.9 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.25 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-036

SAMPLE INFORMATION

Sample Number: 1505033-036 Customer Sample Number:
Location: 18F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-037

SAMPLE INFORMATION

Sample Number: 1505033-037 Customer Sample Number:
Location: 19 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/25/2015
Report Number: M- W1505033-038

SAMPLE INFORMATION

Sample Number: 1505033-038 Customer Sample Number:
Location: 19F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/25/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-039

SAMPLE INFORMATION

Sample Number: 1505033-039
Location: 20
LPR 3121 MLK AVE SE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:15:04 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	24.7 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.38 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	128 ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	14.3 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.99 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	6.14 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-039

SAMPLE INFORMATION

Sample Number: 1505033-039 Customer Sample Number:
Location: 20 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-040

SAMPLE INFORMATION

Sample Number: 1505033-040
Location: 20F
LPR 3121 MLK AVE SE (FILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 5/5/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:15:04 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	14.5 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/2/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	8.66 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.62 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.2 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-040

SAMPLE INFORMATION

Sample Number: 1505033-040 Customer Sample Number:
Location: 20F Type: Dist.
LPR 3121 MLK AVE SE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-041

SAMPLE INFORMATION

Sample Number: 1505033-041 Customer Sample Number:
Location: H1 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-042

SAMPLE INFORMATION

Sample Number: 1505033-042 Customer Sample Number:
Location: H2 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: 5/5/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:15:04 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	186 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	28.8 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8 10 X dilution	ug/L	ug/L	100 ug/L	1730 ug/L	6/3/2015	RHoffa
Copper	EPA 200.8 10 X dilution	ug/L	ug/L	2.0 ug/L	636 ug/L	6/3/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	70.5 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	149 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-042

SAMPLE INFORMATION

Sample Number: 1505033-042 Customer Sample Number:
Location: H2 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-043

SAMPLE INFORMATION

Sample Number: 1505033-043 Customer Sample Number:
Location: H3 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-044

SAMPLE INFORMATION

Sample Number: 1505033-044 Customer Sample Number:
Location: H4 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-045

SAMPLE INFORMATION

Sample Number: 1505033-045 Customer Sample Number:
Location: H5 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-046

SAMPLE INFORMATION

Sample Number: 1505033-046 Customer Sample Number:
Location: H6 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-047

SAMPLE INFORMATION

Sample Number: 1505033-047 Customer Sample Number:
Location: H7 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-048

SAMPLE INFORMATION

Sample Number: 1505033-048 Customer Sample Number:
Location: H8 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: 5/5/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:15:04 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	186 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	25.6 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8 10 X dilution	ug/L	ug/L	100 ug/L	2070 ug/L	6/3/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	398 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	22.3 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	189 ug/L	6/2/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-048

SAMPLE INFORMATION

Sample Number: 1505033-048 Customer Sample Number:
Location: H8 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-049

SAMPLE INFORMATION

Sample Number: 1505033-049 Customer Sample Number:
Location: H9 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-050

SAMPLE INFORMATION

Sample Number: 1505033-050 Customer Sample Number:
Location: H10 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-051

SAMPLE INFORMATION

Sample Number: 1505033-051 Customer Sample Number:
Location: H11 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-052

SAMPLE INFORMATION

Sample Number: 1505033-052 Customer Sample Number:
Location: H12 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-053

SAMPLE INFORMATION

Sample Number: 1505033-053 Customer Sample Number:
Location: H13 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/25/2015
Report Number: M- W1505033-054

SAMPLE INFORMATION

Sample Number: 1505033-054 Customer Sample Number:
Location: H14 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/25/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment: 10x dilution rph 6/3/15 1326

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-055

SAMPLE INFORMATION

Sample Number: 1505033-055 Customer Sample Number:
Location: H15 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: 5/5/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:15:04 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	320 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	55.7 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8 10 X dilution	ug/L	ug/L	100 ug/L	3640 ug/L	6/3/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	289 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	23.7 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8 10 X dilution	ug/L	ug/L	2.0 ug/L	1630 ug/L	6/3/2015	RHoffa

Comment: 10x dilution rph 6/3/15 1327

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-055

SAMPLE INFORMATION

Sample Number: 1505033-055 Customer Sample Number:
Location: H15 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment: 10x dilution rph 6/3/15 1327

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-056

SAMPLE INFORMATION

Sample Number: 1505033-056 Customer Sample Number:
Location: H16 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: 5/5/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:15:04 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment: 10x dilution rph 6/3/15 1328

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-057

SAMPLE INFORMATION

Sample Number: 1505033-057 Customer Sample Number:
Location: H17 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: 5/5/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:15:04 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	370 ug/L	6/2/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	67.6 ug/L	6/2/2015	RHoffa
Iron	EPA 200.8 10 X dilution	ug/L	ug/L	100 ug/L	3990 ug/L	6/3/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	235 ug/L	6/2/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	23.1 ug/L	6/2/2015	RHoffa
Lead	EPA 200.8 10 X dilution	ug/L	ug/L	2.0 ug/L	1860 ug/L	6/3/2015	RHoffa

Comment: 10x dilution rph 6/3/15 1332

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-057

SAMPLE INFORMATION

Sample Number: 1505033-057 Customer Sample Number:
Location: H17 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: 5/5/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:15:04 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment: 10x dilution rph 6/3/15 1332

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-058

SAMPLE INFORMATION

Sample Number: 1505033-058 Customer Sample Number:
Location: H18 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: 5/5/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:15:04 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment: 10 X dilution

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-059

SAMPLE INFORMATION

Sample Number: 1505033-059 Customer Sample Number:
Location: H19 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: 5/5/2015 Collection Time: 9:00 Sampler: CW/DC Received Date and Time: 5/6/2015 11:15:04 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	343 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	67.6 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8 10 x dilution	ug/L	ug/L	100 ug/L	3940 ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	252 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	28.1 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8 10X dilution	ug/L	ug/L	2.0 ug/L	1570 ug/L	6/9/2015	RHoffa

Comment: 10X dilution

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-059

SAMPLE INFORMATION

Sample Number: 1505033-059 Customer Sample Number:
Location: H19 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment: 10X dilution

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/25/2015
Report Number: M- W1505033-060

SAMPLE INFORMATION

Sample Number: 1505033-060 Customer Sample Number:
Location: H20 Type: Dist.
LPR 3121 MLK AVE SE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/5/2015 9:00 CW/DC 5/6/2015 11:15:04 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/25/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment: 10x dilution rph 6/3/15 1333

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-001

SAMPLE INFORMATION

Sample Number: 1505144-001
Location: 1
LPR 3111 MLK AVE SE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	61.4 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.92 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	34.2 ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	85.3 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	101 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.41 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1505144-001

SAMPLE INFORMATION

Sample Number: 1505144-001 Customer Sample Number:
Location: 1 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/20/2015 9:00 IC/YT 5/21/2015 11:35:01 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1505144-002

SAMPLE INFORMATION

Sample Number: 1505144-002 Customer Sample Number:
Location: 1F Type: Dist.
LPR 3111 MLK AVE SE FILTERED
Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-003

SAMPLE INFORMATION

Sample Number: 1505144-003 Customer Sample Number:
Location: 02 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/20/2015 9:00 IC/YT 5/21/2015 11:35:01 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1505144-004

SAMPLE INFORMATION

Sample Number: 1505144-004 Customer Sample Number:
Location: 02F Type: Dist.
LPR 3111 MLK AVE SE FILTERED
Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1505144-005

SAMPLE INFORMATION

Sample Number: 1505144-005 Customer Sample Number:
Location: 03 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/20/2015 9:00 IC/YT 5/21/2015 11:35:01 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-006

SAMPLE INFORMATION

Sample Number: 1505144-006 Customer Sample Number:
Location: 03F Type: Dist.
LPR 3111 MLK AVE SE FILTERED
Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-007

SAMPLE INFORMATION

Sample Number: 1505144-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/20/2015 9:00 IC/YT 5/21/2015 11:35:01 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1505144-008

SAMPLE INFORMATION

Sample Number: 1505144-008 Customer Sample Number:
Location: 04F Type: Dist.
LPR 3111 MLK AVE SE FILTERED
Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-009

SAMPLE INFORMATION

Sample Number: 1505144-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	47.9 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.25 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	49.7 ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	29.2 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.55 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.44 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-009

SAMPLE INFORMATION

Sample Number: 1505144-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/20/2015 9:00 IC/YT 5/21/2015 11:35:01 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1505144-010

SAMPLE INFORMATION

Sample Number: 1505144-010 Customer Sample Number:
Location: 05F Type: Dist.
LPR 3111 MLK AVE SE FILTERED
Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-011

SAMPLE INFORMATION


Sample Number: 1505144-011
Location: 06
LPR 3111 MLK AVE SE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1505144-012

SAMPLE INFORMATION

Sample Number: 1505144-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 3111 MLK AVE SE FILTERED
Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-013

SAMPLE INFORMATION


Sample Number: 1505144-013
Location: 07
LPR 3111 MLK AVE SE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1505144-014

SAMPLE INFORMATION

Sample Number: 1505144-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 3111 MLK AVE SE FILTERED
Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-015

SAMPLE INFORMATION


Sample Number: 1505144-015
Location: 08
LPR 3111 MLK AVE SE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-016

SAMPLE INFORMATION

Sample Number: 1505144-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 3111 MLK AVE SE FILTERED
Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	32.1 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.77 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	19.1 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.97 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-016

SAMPLE INFORMATION


Sample Number: 1505144-016
Location: 08F
LPR 3111 MLK AVE SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-017

SAMPLE INFORMATION

Sample Number: 1505144-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/20/2015 9:00 IC/YT 5/21/2015 11:35:01 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-018

SAMPLE INFORMATION

Sample Number: 1505144-018
Location: 09F
LPR 3111 MLK AVE SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	30.8 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.72 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	18.1 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.28 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.41 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1505144-018

SAMPLE INFORMATION

Sample Number: 1505144-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 3111 MLK AVE SE FILTERED
Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-019

SAMPLE INFORMATION

Sample Number: 1505144-019 Customer Sample Number:
Location: 10 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/20/2015 9:00 IC/YT 5/21/2015 11:35:01 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-020

SAMPLE INFORMATION


Sample Number: 1505144-020
Location: 10F
LPR 3111 MLK AVE SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-021

SAMPLE INFORMATION


Sample Number: 1505144-021
Location: 11
LPR 3111 MLK AVE SE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-022

SAMPLE INFORMATION

Sample Number: 1505144-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 3111 MLK AVE SE FILTERED
Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	32.6 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.78 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	26.0 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.48 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.74 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1505144-022

SAMPLE INFORMATION

Sample Number: 1505144-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 3111 MLK AVE SE FILTERED
Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1505144-023

SAMPLE INFORMATION

Sample Number: 1505144-023 Customer Sample Number:
Location: 12 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/20/2015 9:00 IC/YT 5/21/2015 11:35:01 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-024

SAMPLE INFORMATION

Sample Number: 1505144-024
Location: 12F
LPR 3111 MLK AVE SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	32.9 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.76 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	24.5 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.71 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-024

SAMPLE INFORMATION

Sample Number: 1505144-024
Location: 12F
LPR 3111 MLK AVE SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Robert P. Hoffa, Laboratory Manager

6/29/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-025

SAMPLE INFORMATION

Sample Number: 1505144-025 Customer Sample Number:
Location: 13 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	43.9 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.13 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	56.4 ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	28.8 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.25 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	6.82 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1505144-025

SAMPLE INFORMATION

Sample Number: 1505144-025 Customer Sample Number:
Location: 13 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/20/2015 9:00 IC/YT 5/21/2015 11:35:01 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-026

SAMPLE INFORMATION

Sample Number: 1505144-026 Customer Sample Number:
Location: 13F Type: Dist.
LPR 3111 MLK AVE SE FILTERED
Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	31.3 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.70 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	21.1 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.31 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-026

SAMPLE INFORMATION

Sample Number: 1505144-026 Customer Sample Number:
Location: 13F Type: Dist.
LPR 3111 MLK AVE SE FILTERED
Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1505144-028

SAMPLE INFORMATION

Sample Number: 1505144-028 Customer Sample Number:
Location: 14F Type: Dist.
LPR 3111 MLK AVE SE FILTERED
Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-029

SAMPLE INFORMATION


Sample Number: 1505144-029
Location: 15
LPR 3111 MLK AVE SE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-030

SAMPLE INFORMATION

Sample Number: 1505144-030
Location: 15F
LPR 3111 MLK AVE SE FILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 5/20/2015
Collection Time: 9:00
Sampler: IC/YT
Received Date and Time: 5/21/2015 11:35:01 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	33.8 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.77 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	14.8 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.85 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-030

SAMPLE INFORMATION

Sample Number: 1505144-030 Customer Sample Number:
Location: 15F Type: Dist.
LPR 3111 MLK AVE SE FILTERED
Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-031

SAMPLE INFORMATION

Sample Number: 1505144-031
Location: 16
LPR 3111 MLK AVE SE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Robert P. Hoffa, Laboratory Manager

6/29/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-032

SAMPLE INFORMATION

Sample Number: 1505144-032 Customer Sample Number:
Location: 16F Type: Dist.
LPR 3111 MLK AVE SE FILTERED
Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1505144-033

SAMPLE INFORMATION

Sample Number: 1505144-033 Customer Sample Number:
Location: 17 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/20/2015 9:00 IC/YT 5/21/2015 11:35:01 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-034

SAMPLE INFORMATION


Sample Number: 1505144-034
Location: 17F
LPR 3111 MLK AVE SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-035

SAMPLE INFORMATION

Sample Number: 1505144-035 Customer Sample Number:
Location: 18 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	41.5 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.05 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	44.4 ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	15.7 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.16 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.36 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-035


SAMPLE INFORMATION

Sample Number: 1505144-035
Location: 18
LPR 3111 MLK AVE SE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: 
Robert P. Hoffa, Laboratory Manager

6/29/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-036

SAMPLE INFORMATION


Sample Number: 1505144-036
Location: 18F
LPR 3111 MLK AVE SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1505144-037

SAMPLE INFORMATION

Sample Number: 1505144-037 Customer Sample Number:
Location: 19 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-038

SAMPLE INFORMATION

Sample Number: 1505144-038
Location: 19F
LPR 3111 MLK AVE SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	33.9 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.82 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	12.2 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.21 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-038

SAMPLE INFORMATION


Sample Number: 1505144-038
Location: 19F
LPR 3111 MLK AVE SE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-039

SAMPLE INFORMATION


Sample Number: 1505144-039
Location: 20
LPR 3111 MLK AVE SE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1505144-040

SAMPLE INFORMATION

Sample Number: 1505144-040 Customer Sample Number:
Location: 20F Type: Dist.
LPR 3111 MLK AVE SE FILTERED
Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-041

SAMPLE INFORMATION

Sample Number: 1505144-041
Location: H1
LPR 3111 MLK AVE SE UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 5/20/2015
Collection Time: 9:00
Sampler: IC/YT
Received Date and Time: 5/21/2015 11:35:01 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	47.3 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.62 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	105 ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	30.2 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	13.6 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	384 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-041

SAMPLE INFORMATION

Sample Number: 1505144-041 Customer Sample Number:
Location: H1 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-042

SAMPLE INFORMATION

Sample Number: 1505144-042 Customer Sample Number:
Location: H2 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-043

SAMPLE INFORMATION

Sample Number: 1505144-043 Customer Sample Number:
Location: H3 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	42.4 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.12 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	58.9 ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	21.5 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.71 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	54.2 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1505144-043

SAMPLE INFORMATION

Sample Number: 1505144-043 Customer Sample Number:
Location: H3 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/20/2015 9:00 IC/YT 5/21/2015 11:35:01 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-044

SAMPLE INFORMATION

Sample Number: 1505144-044 Customer Sample Number:
Location: H4 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/20/2015 9:00 IC/YT 5/21/2015 11:35:01 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-045

SAMPLE INFORMATION

Sample Number: 1505144-045 Customer Sample Number:
Location: H5 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/20/2015 9:00 IC/YT 5/21/2015 11:35:01 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-046

SAMPLE INFORMATION

Sample Number: 1505144-046
Location: H6
LPR 3111 MLK AVE SE UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 5/20/2015
Collection Time: 9:00
Sampler: IC/YT
Received Date and Time: 5/21/2015 11:35:01 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	45.6 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.37 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	71.8 ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	19.7 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.25 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	34.3 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-046

SAMPLE INFORMATION

Sample Number: 1505144-046 Customer Sample Number:
Location: H6 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-047

SAMPLE INFORMATION

Sample Number: 1505144-047 Customer Sample Number:
Location: H7 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	49.3 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.40 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	79.5 ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	18.5 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.79 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	28.0 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-047

SAMPLE INFORMATION

Sample Number: 1505144-047 Customer Sample Number:
Location: H7 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/20/2015 9:00 IC/YT 5/21/2015 11:35:01 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-048

SAMPLE INFORMATION

Sample Number: 1505144-048 Customer Sample Number:
Location: H8 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/20/2015 9:00 IC/YT 5/21/2015 11:35:01 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-049

SAMPLE INFORMATION

Sample Number: 1505144-049 Customer Sample Number:
Location: H9 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-050

SAMPLE INFORMATION

Sample Number: 1505144-050 Customer Sample Number:
Location: H10 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/20/2015 9:00 IC/YT 5/21/2015 11:35:01 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-051

SAMPLE INFORMATION

Sample Number: 1505144-051 Customer Sample Number:
Location: H11 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/20/2015 9:00 IC/YT 5/21/2015 11:35:01 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-052

SAMPLE INFORMATION

Sample Number: 1505144-052 Customer Sample Number:
Location: H12 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/20/2015 9:00 IC/YT 5/21/2015 11:35:01 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-053

SAMPLE INFORMATION

Sample Number: 1505144-053 Customer Sample Number:
Location: H13 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/20/2015 9:00 IC/YT 5/21/2015 11:35:01 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-054

SAMPLE INFORMATION

Sample Number: 1505144-054
Location: H14
LPR 3111 MLK AVE SE UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 5/20/2015
Collection Time: 9:00
Sampler: IC/YT
Received Date and Time: 5/21/2015 11:35:01 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	46.1 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.23 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	68.3 ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	271 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	8.25 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	15.6 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-054

SAMPLE INFORMATION

Sample Number: 1505144-054 Customer Sample Number:
Location: H14 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: 5/20/2015 Collection Time: 9:00 Sampler: IC/YT Received Date and Time: 5/21/2015 11:35:01 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1505144-055

SAMPLE INFORMATION

Sample Number: 1505144-055 Customer Sample Number:
Location: H15 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/20/2015 9:00 IC/YT 5/21/2015 11:35:01 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-056

SAMPLE INFORMATION

Sample Number: 1505144-056 Customer Sample Number:
Location: H16 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/20/2015 9:00 IC/YT 5/21/2015 11:35:01 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1505144-057

SAMPLE INFORMATION

Sample Number: 1505144-057 Customer Sample Number:
Location: H17 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/20/2015 9:00 IC/YT 5/21/2015 11:35:01 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1505144-058

SAMPLE INFORMATION

Sample Number: 1505144-058 Customer Sample Number:
Location: H18 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/20/2015 9:00 IC/YT 5/21/2015 11:35:01 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1505144-059

SAMPLE INFORMATION

Sample Number: 1505144-059 Customer Sample Number:
Location: H19 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/20/2015 9:00 IC/YT 5/21/2015 11:35:01 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1505144-060

SAMPLE INFORMATION

Sample Number: 1505144-060 Customer Sample Number:
Location: H20 Type: Dist.
LPR 3111 MLK AVE SE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/20/2015 9:00 IC/YT 5/21/2015 11:35:01 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506007-001

SAMPLE INFORMATION

Sample Number: 1506007-001 Customer Sample Number:
Location: 1 Type: Dist.
LPR 1244 GIRARD ST., NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/1/2015 7:30 CW 6/1/2015 11:16:39 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506007-002

SAMPLE INFORMATION

Sample Number: 1506007-002 Customer Sample Number:
Location: 1F Type: Dist.
LPR 1244 GIRARD ST., NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/1/2015 7:30 CW 6/1/2015 11:16:39 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506007-003

SAMPLE INFORMATION

Sample Number: 1506007-003
Location: 02
LPR 1244 GIRARD ST., NE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/1/2015 Collection Time: 7:30 Sampler: CW Received Date and Time: 6/1/2015 11:16:39 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	39.5 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.65 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	90.2 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	19.4 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.01 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506007-003

SAMPLE INFORMATION

Sample Number: 1506007-003 Customer Sample Number:
Location: 02 Type: Dist.
LPR 1244 GIRARD ST., NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/1/2015 7:30 CW 6/1/2015 11:16:39 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506007-005

SAMPLE INFORMATION

Sample Number: 1506007-005 Customer Sample Number:
Location: 03 Type: Dist.
LPR 1244 GIRARD ST., NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/1/2015 7:30 CW 6/1/2015 11:16:39 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506007-006

SAMPLE INFORMATION

Sample Number: 1506007-006 Customer Sample Number:
Location: 03F Type: Dist.
LPR 1244 GIRARD ST., NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/1/2015 7:30 CW 6/1/2015 11:16:39 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506007-007

SAMPLE INFORMATION

Sample Number: 1506007-007
Location: 04
LPR 1244 GIRARD ST., NE UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 6/1/2015
Collection Time: 7:30
Sampler: CW
Received Date and Time: 6/1/2015 11:16:39 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	41.1 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.29 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	10.4 ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	50.1 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.33 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506007-007

SAMPLE INFORMATION

Sample Number: 1506007-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 1244 GIRARD ST., NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/1/2015 7:30 CW 6/1/2015 11:16:39 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506007-008

SAMPLE INFORMATION

Sample Number: 1506007-008 Customer Sample Number:
Location: 04F Type: Dist.
LPR 1244 GIRARD ST., NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/1/2015 7:30 CW 6/1/2015 11:16:39 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506007-009

SAMPLE INFORMATION

Sample Number: 1506007-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 1244 GIRARD ST., NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/1/2015 7:30 CW 6/1/2015 11:16:39 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506007-010

SAMPLE INFORMATION

Sample Number: 1506007-010 Customer Sample Number:
Location: 05F Type: Dist.
LPR 1244 GIRARD ST., NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/1/2015 7:30 CW 6/1/2015 11:16:39 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506007-011

SAMPLE INFORMATION

Sample Number: 1506007-011 Customer Sample Number:
Location: 06 Type: Dist.
LPR 1244 GIRARD ST., NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/1/2015 7:30 CW 6/1/2015 11:16:39 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506007-012

SAMPLE INFORMATION

Sample Number: 1506007-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 1244 GIRARD ST., NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/1/2015 7:30 CW 6/1/2015 11:16:39 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506007-013

SAMPLE INFORMATION

Sample Number: 1506007-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 1244 GIRARD ST., NE UNFILTERED
Collection Date: 6/1/2015 Collection Time: 7:30 Sampler: CW Received Date and Time: 6/1/2015 11:16:39 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	40.4 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.32 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	118 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.62 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.2 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506007-013

SAMPLE INFORMATION

Sample Number: 1506007-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 1244 GIRARD ST., NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/1/2015 7:30 CW 6/1/2015 11:16:39 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506007-014

SAMPLE INFORMATION

Sample Number: 1506007-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 1244 GIRARD ST., NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/1/2015 7:30 CW 6/1/2015 11:16:39 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506007-015

SAMPLE INFORMATION

Sample Number: 1506007-015 Customer Sample Number:
Location: 08 Type: Dist.
LPR 1244 GIRARD ST., NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/1/2015 7:30 CW 6/1/2015 11:16:39 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506007-016

SAMPLE INFORMATION

Sample Number: 1506007-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 1244 GIRARD ST., NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/1/2015 7:30 CW 6/1/2015 11:16:39 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506007-017

SAMPLE INFORMATION

Sample Number: 1506007-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 1244 GIRARD ST., NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/1/2015 7:30 CW 6/1/2015 11:16:39 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506007-018

SAMPLE INFORMATION

Sample Number: 1506007-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 1244 GIRARD ST., NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/1/2015 7:30 CW 6/1/2015 11:16:39 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506007-019

SAMPLE INFORMATION

Sample Number: 1506007-019 Customer Sample Number:
Location: 10 Type: Dist.
LPR 1244 GIRARD ST., NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/1/2015 7:30 CW 6/1/2015 11:16:39 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506007-020

SAMPLE INFORMATION

Sample Number: 1506007-020 Customer Sample Number:
Location: 10F Type: Dist.
LPR 1244 GIRARD ST., NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/1/2015 7:30 CW 6/1/2015 11:16:39 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506007-021

SAMPLE INFORMATION

Sample Number: 1506007-021 Customer Sample Number:
Location: 11 Type: Dist.
LPR 1244 GIRARD ST., NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/1/2015 7:30 CW 6/1/2015 11:16:39 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506007-022

SAMPLE INFORMATION

Sample Number: 1506007-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 1244 GIRARD ST., NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/1/2015 7:30 CW 6/1/2015 11:16:39 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506007-023

SAMPLE INFORMATION

Sample Number: 1506007-023
Location: 12
LPR 1244 GIRARD ST., NE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/1/2015 Collection Time: 7:30 Sampler: CW Received Date and Time: 6/1/2015 11:16:39 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa*
Robert P. Hoffa, Laboratory Manager

6/29/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506007-024

SAMPLE INFORMATION

Sample Number: 1506007-024
Customer Sample Number:
Location: 12F
Type: Dist.
LPR 1244 GIRARD ST., NE FILTERED
Collection Date: 6/1/2015
Collection Time: 7:30
Sampler: CW
Received Date and Time: 6/1/2015 11:16:39 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	35.1 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	92.9 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.49 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506007-024

SAMPLE INFORMATION

Sample Number: 1506007-024 Customer Sample Number:
Location: 12F Type: Dist.
LPR 1244 GIRARD ST., NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/1/2015 7:30 CW 6/1/2015 11:16:39 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506007-025

SAMPLE INFORMATION

Sample Number: 1506007-025
Customer Sample Number:
Location: H1
Type: Dist.
LPR 1244 GIRARD ST., NE UNFILTERED
Collection Date: 6/1/2015
Collection Time: 7:30
Sampler: CW
Received Date and Time: 6/1/2015 11:16:39 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	44.8 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.70 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	67.8 ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	117 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	6.76 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506007-025

SAMPLE INFORMATION

Sample Number: 1506007-025 Customer Sample Number:
Location: H1 Type: Dist.
LPR 1244 GIRARD ST., NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/1/2015 7:30 CW 6/1/2015 11:16:39 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506007-027

SAMPLE INFORMATION

Sample Number: 1506007-027 Customer Sample Number:
Location: H3 Type: Dist.
LPR 1244 GIRARD ST., NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/1/2015 7:30 CW 6/1/2015 11:16:39 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506007-028

SAMPLE INFORMATION

Sample Number: 1506007-028 Customer Sample Number:
Location: H4 Type: Dist.
LPR 1244 GIRARD ST., NE UNFILTERED
Collection Date: 6/1/2015 Collection Time: 7:30 Sampler: CW Received Date and Time: 6/1/2015 11:16:39 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	47.4 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.66 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	83.6 ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	66.6 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.21 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506007-028

SAMPLE INFORMATION

Sample Number: 1506007-028 Customer Sample Number:
Location: H4 Type: Dist.
LPR 1244 GIRARD ST., NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/1/2015 7:30 CW 6/1/2015 11:16:39 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506007-029

SAMPLE INFORMATION

Sample Number: 1506007-029 Customer Sample Number:
Location: H5 Type: Dist.
LPR 1244 GIRARD ST., NE UNFILTERED
Collection Date: 6/1/2015 Collection Time: 7:30 Sampler: CW Received Date and Time: 6/1/2015 11:16:39 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	48.0 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.74 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	92.4 ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	56.1 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.30 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506007-029

SAMPLE INFORMATION

Sample Number: 1506007-029 Customer Sample Number:
Location: H5 Type: Dist.
LPR 1244 GIRARD ST., NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/1/2015 7:30 CW 6/1/2015 11:16:39 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506007-030

SAMPLE INFORMATION

Sample Number: 1506007-030 Customer Sample Number:
Location: H6 Type: Dist.
LPR 1244 GIRARD ST., NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/1/2015 7:30 CW 6/1/2015 11:16:39 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506007-031

SAMPLE INFORMATION

Sample Number: 1506007-031 Customer Sample Number:
Location: H7 Type: Dist.
LPR 1244 GIRARD ST., NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/1/2015 7:30 CW 6/1/2015 11:16:39 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	49.0 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.56 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	44.0 ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	98.5 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	7.89 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506007-031

SAMPLE INFORMATION

Sample Number: 1506007-031 Customer Sample Number:
Location: H7 Type: Dist.
LPR 1244 GIRARD ST., NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/1/2015 7:30 CW 6/1/2015 11:16:39 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506007-032

SAMPLE INFORMATION

Sample Number: 1506007-032 Customer Sample Number:
Location: H8 Type: Dist.
LPR 1244 GIRARD ST., NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/1/2015 7:30 CW 6/1/2015 11:16:39 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506007-033

SAMPLE INFORMATION

Sample Number: 1506007-033 Customer Sample Number:
Location: H9 Type: Dist.
LPR 1244 GIRARD ST., NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/1/2015 7:30 CW 6/1/2015 11:16:39 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506007-034

SAMPLE INFORMATION

Sample Number: 1506007-034 Customer Sample Number:
Location: H10 Type: Dist.
LPR 1244 GIRARD ST., NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/1/2015 7:30 CW 6/1/2015 11:16:39 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506007-035

SAMPLE INFORMATION

Sample Number: 1506007-035 Customer Sample Number:
Location: H11 Type: Dist.
LPR 1244 GIRARD ST., NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/1/2015 7:30 CW 6/1/2015 11:16:39 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506007-036

SAMPLE INFORMATION

Sample Number: 1506007-036 Customer Sample Number:
Location: H12 Type: Dist.
LPR 1244 GIRARD ST., NE UNFILTERED

Collection Date: 6/1/2015 Collection Time: 7:30 Sampler: CW Received Date and Time: 6/1/2015 11:16:39 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	48.9 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.43 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	15.5 ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	27.6 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.30 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506007-036

SAMPLE INFORMATION

Sample Number: 1506007-036 Customer Sample Number:
Location: H12 Type: Dist.
LPR 1244 GIRARD ST., NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/1/2015 7:30 CW 6/1/2015 11:16:39 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-001

SAMPLE INFORMATION

Sample Number: 1506019-001 Customer Sample Number:
Location: 1 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	55.0 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.38 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	38.7 ug/L	6/18/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	41.9 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	30.6 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.50 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-001

SAMPLE INFORMATION

Sample Number: 1506019-001 Customer Sample Number:
Location: 1 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-002

SAMPLE INFORMATION

Sample Number: 1506019-002 Customer Sample Number:
Location: 1F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	40.6 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/18/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	34.7 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	24.5 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.29 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-002

SAMPLE INFORMATION

Sample Number: 1506019-002 Customer Sample Number:
Location: 1F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-003

SAMPLE INFORMATION


Sample Number: 1506019-003
Location: 02
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-004

SAMPLE INFORMATION

Sample Number: 1506019-004 Customer Sample Number:
Location: 02F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:

Robert P. Hoffa
Robert P. Hoffa, Laboratory Manager

6/29/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-005

SAMPLE INFORMATION

Sample Number: 1506019-005 Customer Sample Number:
Location: 03 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-006

SAMPLE INFORMATION

Sample Number: 1506019-006 Customer Sample Number:
Location: 03F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-007

SAMPLE INFORMATION

Sample Number: 1506019-007 Customer Sample Number:
Location: 04 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-008

SAMPLE INFORMATION

Sample Number: 1506019-008 Customer Sample Number:
Location: 04F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-009

SAMPLE INFORMATION

Sample Number: 1506019-009 Customer Sample Number:
Location: 05 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-010

SAMPLE INFORMATION

Sample Number: 1506019-010 Customer Sample Number:
Location: 05F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-011

SAMPLE INFORMATION

Sample Number: 1506019-011
Location: 06
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	39.2 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.22 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	16.9 ug/L	6/18/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	22.6 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.64 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.24 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-011

SAMPLE INFORMATION

Sample Number: 1506019-011 Customer Sample Number:
Location: 06 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-012

SAMPLE INFORMATION

Sample Number: 1506019-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	30.4 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/18/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	20.5 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	4.06 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.67 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-012

SAMPLE INFORMATION

Sample Number: 1506019-012 Customer Sample Number:
Location: 06F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-013

SAMPLE INFORMATION

Sample Number: 1506019-013 Customer Sample Number:
Location: 07 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:

Robert P. Hoffa
Robert P. Hoffa, Laboratory Manager

6/29/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-014

SAMPLE INFORMATION

Sample Number: 1506019-014 Customer Sample Number:
Location: 07F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-015

SAMPLE INFORMATION

Sample Number: 1506019-015 Customer Sample Number:
Location: 08 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:

Robert P. Hoffa
Robert P. Hoffa, Laboratory Manager

6/29/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-016

SAMPLE INFORMATION

Sample Number: 1506019-016 Customer Sample Number:
Location: 08F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-017

SAMPLE INFORMATION

Sample Number: 1506019-017 Customer Sample Number:
Location: 09 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-018

SAMPLE INFORMATION

Sample Number: 1506019-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	28.1 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	19.9 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.64 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.92 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-018

SAMPLE INFORMATION

Sample Number: 1506019-018 Customer Sample Number:
Location: 09F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-019

SAMPLE INFORMATION

Sample Number: 1506019-019
Location: 10
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
6/2/2015	7:00	CW	6/2/2015 10:40:35 AM	JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	35.9 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.51 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	13.7 ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	135 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.69 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	16.0 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-019

SAMPLE INFORMATION


Sample Number: 1506019-019
Location: 10
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-020

SAMPLE INFORMATION

Sample Number: 1506019-020
Location: 10F
LPR 411 7TH ST NE (FILTERED)
Customer Sample Number:
Type: Dist.
Collection Date: 6/2/2015
Collection Time: 7:00
Sampler: CW
Received Date and Time: 6/2/2015 10:40:35 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	26.8 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	116 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.89 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	5.68 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-020

SAMPLE INFORMATION

Sample Number: 1506019-020 Customer Sample Number:
Location: 10F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-021

SAMPLE INFORMATION

Sample Number: 1506019-021 Customer Sample Number:
Location: 11 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-022

SAMPLE INFORMATION

Sample Number: 1506019-022 Customer Sample Number:
Location: 11F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-023

SAMPLE INFORMATION


Sample Number: 1506019-023
Location: 12
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-024

SAMPLE INFORMATION

Sample Number: 1506019-024 Customer Sample Number:
Location: 12F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-025

SAMPLE INFORMATION

Sample Number: 1506019-025
Location: 13
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	39.4 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.80 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	13.6 ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	162 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.07 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.98 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-025

SAMPLE INFORMATION

Sample Number: 1506019-025 Customer Sample Number:
Location: 13 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-026

SAMPLE INFORMATION

Sample Number: 1506019-026 Customer Sample Number:
Location: 13F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	31.1 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.02 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	123 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.51 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.95 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-026

SAMPLE INFORMATION

Sample Number: 1506019-026 Customer Sample Number:
Location: 13F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-027

SAMPLE INFORMATION

Sample Number: 1506019-027 Customer Sample Number:
Location: 14 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-028

SAMPLE INFORMATION

Sample Number: 1506019-028 Customer Sample Number:
Location: 14F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	30.3 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.02 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	141 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	5.04 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.38 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-028

SAMPLE INFORMATION

Sample Number: 1506019-028 Customer Sample Number:
Location: 14F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-029

SAMPLE INFORMATION


Sample Number: 1506019-029
Location: 15
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-030

SAMPLE INFORMATION

Sample Number: 1506019-030
Location: 15F
LPR 411 7TH ST NE (FILTERED)
Customer Sample Number:
Type: Dist.
Collection Date: 6/2/2015
Collection Time: 7:00
Sampler: CW
Received Date and Time: 6/2/2015 10:40:35 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	28.3 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.0 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	127 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.01 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.10 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-030

SAMPLE INFORMATION

Sample Number: 1506019-030 Customer Sample Number:
Location: 15F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-031

SAMPLE INFORMATION

Sample Number: 1506019-031
Location: 16
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	40.2 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.83 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	13.7 ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	177 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.47 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.20 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-031

SAMPLE INFORMATION

Sample Number: 1506019-031 Customer Sample Number:
Location: 16 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:

Robert P. Hoffa
Robert P. Hoffa, Laboratory Manager

6/29/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-032

SAMPLE INFORMATION

Sample Number: 1506019-032 Customer Sample Number:
Location: 16F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	29.6 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.02 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	149 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.83 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.10 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-032

SAMPLE INFORMATION

Sample Number: 1506019-032 Customer Sample Number:
Location: 16F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-033

SAMPLE INFORMATION

Sample Number: 1506019-033
Location: 17
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	40.0 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.69 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	12.8 ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	143 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	1.90 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.91 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-033

SAMPLE INFORMATION


Sample Number: 1506019-033
Location: 17
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-034

SAMPLE INFORMATION

Sample Number: 1506019-034 Customer Sample Number:
Location: 17F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-035

SAMPLE INFORMATION

Sample Number: 1506019-035
Location: 18
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date: 6/2/2015	Collection Time: 7:00	Sampler: CW	Received Date and Time: 6/2/2015 10:40:35 AM	Received By: JCross
------------------------------	--------------------------	----------------	---	------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	44.6 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.74 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	14.5 ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	89.6 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	1.83 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.92 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-035

SAMPLE INFORMATION

Sample Number: 1506019-035 Customer Sample Number:
Location: 18 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-036

SAMPLE INFORMATION

Sample Number: 1506019-036 Customer Sample Number:
Location: 18F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-037

SAMPLE INFORMATION

Sample Number: 1506019-037 Customer Sample Number:
Location: 19 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-038

SAMPLE INFORMATION

Sample Number: 1506019-038 Customer Sample Number:
Location: 19F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-039

SAMPLE INFORMATION

Sample Number: 1506019-039
Location: 20
LPR 411 7TH ST NE (UNFILTERED)

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
6/2/2015	7:00	CW	6/2/2015 10:40:35 AM	JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	47.2 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.73 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	16.1 ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	44.0 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	1.77 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.86 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-039

SAMPLE INFORMATION

Sample Number: 1506019-039 Customer Sample Number:
Location: 20 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number:M- W1506019-040

SAMPLE INFORMATION

Sample Number: 1506019-040
Location: 20F
LPR 411 7TH ST NE (FILTERED)
Customer Sample Number:
Type: Dist.
Collection Date: 6/2/2015
Collection Time: 7:00
Sampler: CW
Received Date and Time: 6/2/2015 10:40:35 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	38.6 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.01 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	41.0 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.42 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.8 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-040

SAMPLE INFORMATION

Sample Number: 1506019-040 Customer Sample Number:
Location: 20F Type: Dist.
LPR 411 7TH ST NE (FILTERED)
Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-041

SAMPLE INFORMATION

Sample Number: 1506019-041 Customer Sample Number:
Location: H1 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	63.9 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.98 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	46.7 ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	43.0 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	15.4 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	7.40 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-041

SAMPLE INFORMATION

Sample Number: 1506019-041 Customer Sample Number:
Location: H1 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-042

SAMPLE INFORMATION

Sample Number: 1506019-042 Customer Sample Number:
Location: H2 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-043

SAMPLE INFORMATION

Sample Number: 1506019-043 Customer Sample Number:
Location: H3 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-044

SAMPLE INFORMATION

Sample Number: 1506019-044 Customer Sample Number:
Location: H4 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number:M- W1506019-045

SAMPLE INFORMATION

Sample Number: 1506019-045 Customer Sample Number:
Location: H5 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	49.3 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.76 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	18.5 ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	25.7 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.34 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.84 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-045

SAMPLE INFORMATION

Sample Number: 1506019-045 Customer Sample Number:
Location: H5 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-046

SAMPLE INFORMATION

Sample Number: 1506019-046 Customer Sample Number:
Location: H6 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-047

SAMPLE INFORMATION

Sample Number: 1506019-047 Customer Sample Number:
Location: H7 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	47.3 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.68 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	16.7 ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	23.2 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.04 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.40 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-047

SAMPLE INFORMATION

Sample Number: 1506019-047 Customer Sample Number:
Location: H7 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-048

SAMPLE INFORMATION

Sample Number: 1506019-048 Customer Sample Number:
Location: H8 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-049

SAMPLE INFORMATION

Sample Number: 1506019-049 Customer Sample Number:
Location: H9 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	48.3 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.70 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	17.2 ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	23.3 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.27 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.36 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-049

SAMPLE INFORMATION

Sample Number: 1506019-049 Customer Sample Number:
Location: H9 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:

Robert P. Hoffa
Robert P. Hoffa, Laboratory Manager

6/29/2015
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-050

SAMPLE INFORMATION

Sample Number: 1506019-050 Customer Sample Number:
Location: H10 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	47.9 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.69 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	17.0 ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	22.7 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	3.19 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.28 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-050

SAMPLE INFORMATION

Sample Number: 1506019-050 Customer Sample Number:
Location: H10 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-051

SAMPLE INFORMATION

Sample Number: 1506019-051 Customer Sample Number:
Location: H11 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	47.0 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.70 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	15.8 ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	21.9 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.16 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	2.58 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-051

SAMPLE INFORMATION

Sample Number: 1506019-051 Customer Sample Number:
Location: H11 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-052

SAMPLE INFORMATION

Sample Number: 1506019-052 Customer Sample Number:
Location: H12 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-053

SAMPLE INFORMATION

Sample Number: 1506019-053 Customer Sample Number:
Location: H13 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-054

SAMPLE INFORMATION

Sample Number: 1506019-054 Customer Sample Number:
Location: H14 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-055

SAMPLE INFORMATION

Sample Number: 1506019-055 Customer Sample Number:
Location: H15 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: 6/2/2015 Collection Time: 7:00 Sampler: CW Received Date and Time: 6/2/2015 10:40:35 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	48.4 ug/L	6/9/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.74 ug/L	6/9/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	16.6 ug/L	6/9/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	22.4 ug/L	6/9/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	2.54 ug/L	6/9/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.38 ug/L	6/9/2015	RHoffa

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-055

SAMPLE INFORMATION

Sample Number: 1506019-055 Customer Sample Number:
Location: H15 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-056

SAMPLE INFORMATION

Sample Number: 1506019-056 Customer Sample Number:
Location: H16 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-057

SAMPLE INFORMATION

Sample Number: 1506019-057 Customer Sample Number:
Location: H17 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 6/29/2015
Report Number: M- W1506019-058

SAMPLE INFORMATION

Sample Number: 1506019-058 Customer Sample Number:
Location: H18 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By: *Robert P. Hoffa* 6/29/2015
Robert P. Hoffa, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-059

SAMPLE INFORMATION

Sample Number: 1506019-059 Customer Sample Number:
Location: H19 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001


Report Date: 6/29/2015
Report Number: M- W1506019-060

SAMPLE INFORMATION

Sample Number: 1506019-060 Customer Sample Number:
Location: H20 Type: Dist.
LPR 411 7TH ST NE (UNFILTERED)
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/2/2015 7:00 CW 6/2/2015 10:40:35 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Laboratory Manager

6/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

DC Water - Other Research

DC Water collected samples from a residence that reported discolored water.

The samples were analyzed by the Washington Aqueduct.

This attached sample analysis data contains personal information of DC Water's customers, such as names and home addresses, the disclosure of which would constitute a violation of D.C. Code § 2-534(a)(2) and 5 U.S.C. § 552(b)(6). If EPA is requested to produce the sampling analysis data in whole or in part, in order to maintain confidentiality, the personal information must be redacted from the documents produced.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/29/2015
Report Number: M- W1504179-001

SAMPLE INFORMATION

Sample Number: 1504179-001
Location: 1757 P ST NW-KITCHEN

Customer Sample Number:
Type: Dist. Project: COM

Collection Date: 4/23/2015 Collection Time: 11:00 Sampler: MS Received Date and Time: 4/24/2015 8:58:52 AM Received By: ASanders

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Lithium	EPA 200.8	ug/L	ug/L	0.2 ug/L	3.87 ug/L	4/29/2015	RHoffa
Beryllium	EPA 200.8	4 ug/L	ug/L	0.2 ug/L	ND ug/L	4/29/2015	RHoffa
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	26.0 ug/L	4/29/2015	RHoffa
Chromium	EPA 200.8	100 ug/L	ug/L	2 ug/L	ND ug/L	4/29/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.6 ug/L	4/29/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	4/29/2015	RHoffa
Cobalt	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.3 ug/L	4/29/2015	RHoffa
Nickel	EPA 200.8	ug/L	ug/L	0.5 ug/L	1.19 ug/L	4/29/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	17.1 ug/L	4/29/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	47.7 ug/L	4/29/2015	RHoffa
Arsenic	EPA 200.8	10 ug/L	ug/L	0.2 ug/L	0.4 ug/L	4/29/2015	RHoffa

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/29/2015
Report Number: M- W1504179-001

SAMPLE INFORMATION

Sample Number: 1504179-001
Location: 1757 P ST NW-KITCHEN

Customer Sample Number:
Type: Dist. Project: COM

Collection Date: 4/23/2015 Collection Time: 11:00 Sampler: MS Received Date and Time: 4/24/2015 8:58:52 AM Received By: ASanders

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Selenium	EPA 200.8	50 ug/L	ug/L	1 ug/L	ND ug/L	4/29/2015	RHoffa
Strontium	EPA 200.8	ug/L	ug/L	0.2 ug/L	127 ug/L	4/29/2015	RHoffa
Molybdenum	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	4/29/2015	RHoffa
Silver	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	4/29/2015	RHoffa
Cadmium	EPA 200.8	5 ug/L	ug/L	0.2 ug/L	ND ug/L	4/29/2015	RHoffa
Antimony	EPA 200.8	6 ug/L	ug/L	0.2 ug/L	ND ug/L	4/29/2015	RHoffa
Barium	EPA 200.8	2000 ug/L	ug/L	0.2 ug/L	33.3 ug/L	4/29/2015	RHoffa
Thallium	EPA 200.8	2 ug/L	ug/L	0.5 ug/L	ND ug/L	4/29/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	4/29/2015	RHoffa
Thorium	EPA 200.8	ug/L	ug/L	0.5 ug/L	ND ug/L	4/29/2015	RHoffa
Uranium	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	4/29/2015	RHoffa

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/29/2015
Report Number: M- W1504179-001

SAMPLE INFORMATION

Sample Number: 1504179-001

Customer Sample Number:

Location: 1757 P ST NW-KITCHEN

Type: Dist. Project: COM

Collection Date:
4/23/2015

Collection Time:
11:00


Sampler:
MS

Received Date and Time:
4/24/2015 8:58:52 AM

Received By:
ASanders

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/29/2015
Report Number: M- W1504179-002

SAMPLE INFORMATION

Sample Number: 1504179-002

Customer Sample Number:

Location: 1757 P ST NW-TOILET TANK

Type: Dist. Project: COM

Collection Date:
4/23/2015

Collection Time:
16:00

Sampler:
IC

Received Date and Time:
4/24/2015 8:58:52 AM

Received By:
ASanders

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Lithium	EPA 200.8	ug/L	ug/L	0.2 ug/L	1.87 ug/L	4/29/2015	RHoffa
Beryllium	EPA 200.8	4 ug/L	ug/L	0.2 ug/L	ND ug/L	4/29/2015	RHoffa
Aluminum	EPA 200.8	ug/L	ug/L	10 ug/L	26.8 ug/L	4/29/2015	RHoffa
Chromium	EPA 200.8	100 ug/L	ug/L	2 ug/L	ND ug/L	4/29/2015	RHoffa
Manganese	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.7 ug/L	4/29/2015	RHoffa
Iron	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	4/29/2015	RHoffa
Cobalt	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	4/29/2015	RHoffa
Nickel	EPA 200.8	ug/L	ug/L	0.5 ug/L	0.9 ug/L	4/29/2015	RHoffa
Copper	EPA 200.8	ug/L	ug/L	0.2 ug/L	4.16 ug/L	4/29/2015	RHoffa
Zinc	EPA 200.8	ug/L	ug/L	0.5 ug/L	10.2 ug/L	4/29/2015	RHoffa
Arsenic	EPA 200.8	10 ug/L	ug/L	0.2 ug/L	0.4 ug/L	4/29/2015	RHoffa

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/29/2015
Report Number: M- W1504179-002

SAMPLE INFORMATION

Sample Number: 1504179-002

Customer Sample Number:

Location: 1757 P ST NW-TOILET TANK

Type: Dist. Project: COM

Collection Date:
4/23/2015

Collection Time:
16:00

Sampler:
IC

Received Date and Time:
4/24/2015 8:58:52 AM

Received By:
ASanders

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Selenium	EPA 200.8	50 ug/L	ug/L	1 ug/L	ND ug/L	4/29/2015	RHoffa
Strontium	EPA 200.8	ug/L	ug/L	0.2 ug/L	134 ug/L	4/29/2015	RHoffa
Molybdenum	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.5 ug/L	4/29/2015	RHoffa
Silver	EPA 200.8	ug/L	ug/L	10 ug/L	ND ug/L	4/29/2015	RHoffa
Cadmium	EPA 200.8	5 ug/L	ug/L	0.2 ug/L	ND ug/L	4/29/2015	RHoffa
Antimony	EPA 200.8	6 ug/L	ug/L	0.2 ug/L	ND ug/L	4/29/2015	RHoffa
Barium	EPA 200.8	2000 ug/L	ug/L	0.2 ug/L	35.2 ug/L	4/29/2015	RHoffa
Thallium	EPA 200.8	2 ug/L	ug/L	0.5 ug/L	ND ug/L	4/29/2015	RHoffa
Lead	EPA 200.8	ug/L	ug/L	0.2 ug/L	0.4 ug/L	4/29/2015	RHoffa
Thorium	EPA 200.8	ug/L	ug/L	0.5 ug/L	ND ug/L	4/29/2015	RHoffa
Uranium	EPA 200.8	ug/L	ug/L	0.2 ug/L	ND ug/L	4/29/2015	RHoffa

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/29/2015
Report Number: M- W1504179-002

SAMPLE INFORMATION

Sample Number: 1504179-002

Customer Sample Number:

Location: 1757 P ST NW-TOILET TANK

Type: Dist. Project: COM

Collection Date:
4/23/2015

Collection Time:
16:00


Sampler:
IC

Received Date and Time:
4/24/2015 8:58:52 AM

Received By:
ASanders

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Robert P. Hoffa, Acting Laboratory Manager

4/29/2015

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

Attachment 2

Other Addition Non-Regulated Monitoring Data

Customer Service Samples

DC Water operates a program where customers request a lead sampling kit on an annual basis. The kit comes with bottles and instructions on how to take first and second draw samples. Customers collect their own samples and contact DC Water to deliver the bottles to the Washington Aqueduct. Results are then reported back to the customer through DC Water's Customer Service Program.

This attached sample analysis data contains personal information of DC Water's customers, such as names and home addresses, the disclosure of which would constitute a violation of D.C. Code § 2-534(a)(2) and 5 U.S.C. § 552(b)(6). If EPA is requested to produce the sampling analysis data in whole or in part, in order to maintain confidentiality, the personal information must be redacted from the documents produced.

Post Lead Service Line Replacement Samples

DC Water operates a program where lead sampling kits are dropped off to customers that have had a partial or full lead service line replacement. Samples are typically dropped off 4.5 months after the replacement to determine if it is necessary for customers to continue filtering their water. The kit comes with bottles and instructions on how to take first and second draw samples. Customers collect their own samples and contact DC Water to deliver the bottles to the Washington Aqueduct. Results are then reported back to the customer through DC Water's Customer Service Program.

This attached sample analysis data contains personal information of DC Water's customers, such as names and home addresses, the disclosure of which would constitute a violation of D.C. Code § 2-534(a)(2) and 5 U.S.C. § 552(b)(6). If EPA is requested to produce the sampling analysis data in whole or in part, in order to maintain confidentiality, the personal information must be redacted from the documents produced.

Lead Profile Information

DC Water surveys the plumbing of customers' homes and collects consecutive samples to identify the sources of lead. The homes are those that had elevated lead from previous samples collected for compliance monitoring or from other programs.

This attached sample analysis data contains personal information of DC Water's customers, such as names and home addresses, the disclosure of which would constitute a violation of D.C. Code § 2-534(a)(2) and 5 U.S.C. § 552(b)(6). If EPA is requested to produce the sampling analysis data in whole or in part, in order to maintain confidentiality, the personal information must be redacted from the documents produced.

Attachment 3

Customer Letter Distribution Certification



Certification of Consumer Notification of Tap Results

Water System Name: DC Water and Sewer Authority (DC Water)

PWSID: DC000002

Monitoring Period to which the notice applies: January 2015 – June 2015

Dates results were received from laboratory: See Attached Table C.6 from Report

Dates results were provided to customers: See Attached Table C.6 from Report

The water system names above hereby certifies that its lead consumer notice has been provided to each person it serves at the specific sampling site from which the sample was tested. The water system also certifies that these results and the following information were provided to such persons within 30 days of receiving the test results from the laboratory:

- X Individual tap results from lead tap water monitoring carried out under the requirements of §141.86.
- X An explanation of the health effects of lead.
- X Steps that consumers can take to reduce exposure to lead in drinking water.
- X Contact information for your water utility.
- X The maximum contaminant level goals and action levels for lead, and the definitions of these two term from §141.153(c).

Certified by:

Name Jessica Edwards-Brandt
 Title Manager, Water Quality, Drinking Water Division
 Phone # 202-364-3123 Date July 9, 2015

Notices were distributed to customers by mail.

Sincerely,

Jessica Edwards-Brandt
Manager, Drinking Water Division



Month, day, year

«First_name» «Last_Name»

«Address»

Washington, DC «Zip_Code»

Dear «First_name» «Last_Name»:

Thank you for participating in DC Water’s Lead and Copper Compliance Monitoring Program. Your participation helps us assess the effectiveness of the U.S. Army Corps of Engineers Washington Aqueduct corrosion control treatment to minimize corrosion of lead service pipes, household plumbing and fixtures that may contribute to lead and copper concentrations in drinking water.

Below are the test results from the two water samples that you collected from your household tap:

- First draw: Measures lead release from household plumbing and fixtures, especially potential sources near the tap where the sample is collected. This sample is required by the Environmental Protection Agency (EPA).
- Second draw: Measures lead release from the lead service pipe and household plumbing. DC Water voluntarily collects this sample to assess the contribution of lead in water from the lead service line.

Sample	Lead Level (ppb)	Copper Level (ppb)
First Draw		
Second Draw		

Service Line Material

Public Space: Lead

Private Property: Lead

If this information is inaccurate, please contact the Drinking Water Division at 202-612-3440.

DC Water recommends that you filter your water to minimize potential lead exposure if lead is present in your drinking water, if you have pipes or plumbing fixtures that contain lead, or if you don’t know the material type. If you are pregnant, nursing or have children under age six, use cold, filtered tap water for drinking and cooking until all sources of lead are removed. This includes water used for making infant formula, beverages and ice.

The potential for lead in drinking water varies among homes in the District. Drinking water is essentially lead-free when it leaves the Washington Aqueduct treatment plant, but lead can enter water when it comes in contact with pipes or plumbing fixtures that contain lead. As noted above, your property has a lead service pipe, which connects the water main in the street to household plumbing. DC Water operates a lead service replacement program and will replace the public portion of the service line during a water main replacement, or if you agree to replace the portion on your private property.

Under the authority of the Safe Drinking Water Act, EPA set a Maximum Contaminant Level Goal (MCLG) for lead at zero and for copper at 1,300 parts per billion (ppb). The MCLG is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. EPA also set an action level for lead at 15 ppb and for copper at 1,300 ppb. The action level is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. These requirements are triggered if more than 10 percent of all first draw samples collected during any monitoring period exceed the action levels. Your lead and copper results may be higher or lower than the action levels, which does not reflect DC Water’s compliance with the LCR. DC Water will notify all customers if the District’s water exceeds the lead or copper action level.

Lead can pose significant health risks if too much of it enters the body. The greatest risk of lead exposure is to infants, young children and pregnant women. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of the body. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead from other sources (such as lead-based paint and contaminated soil) can increase a person's overall exposure, which adds to the effects of lead in water.

The District Department of the Environment (DDOE) offers information on blood lead testing for young children, pregnant women and nursing mothers. For more information on minimizing lead exposure, contact DDOE at 202-654-6036 or visit www.ddoe.dc.gov or visit EPA's website at www.epa.gov/lead.

DC Water strongly encourages residents to take the following steps to reduce lead exposure:

Remove lead sources

- Replace your lead service pipe with copper. For more information about lead pipe replacement, contact the Drinking Water Division at 202-612-3440.
- Replace household galvanized plumbing. When lead is released from a lead service pipe and passes through galvanized plumbing (particularly over decades of use), lead can accumulate on the inside, corroded walls of this plumbing. Lead release from galvanized pipes can continue even after a lead service pipe is replaced.
- Install lead-free plumbing fixtures certified to meet NSF Standard 61 Annex G (NSF 61-G). Effective in 2014, fixtures that are labeled "lead-free" cannot contain more than 0.25 percent lead. Flush cold water taps, with the aerator removed, at highest flow rate for 5 minutes once a day for 3 days after installing new household pipes or fixtures.

Use filtered tap water

- Be sure to select a filter certified to meet NSF Standard 53 for lead removal. The filter package should specifically list the device as certified for removing the contaminant "lead."
- We recommend devices that are installed at your faucet tap (also known as point-of-use) or pitcher-style filters. Visit the NSF International website for certified drinking water filters at www.nsf.org/Certified/DWTU or call 1-800-673-8010.
- Be sure to routinely replace filter cartridges according to the manufacturer's instructions.

Do not use your hot water tap for drinking and cooking

- Always use cold tap water, then heat water if necessary. Boiling water does not reduce lead levels.
- Hot tap water can cause a greater amount of lead to release from plumbing. Always use cold tap water, including water used for making ice, beverages and infant formula.

Run the cold water tap when water is not used for several hours

- Run your water before using it for drinking or cooking. Once you notice a temperature change, continue running your water for 2 more minutes to receive fresh water from the water main.
- Lead and other metals can dissolve in water when it sits in pipes for a few hours.

Remove and clean faucet aerators

- Lead particles and sediment can collect in the aerator screen located at the tip of your faucet.

For more information, contact the Drinking Water Division at 202-612-3440 or visit www.dewater.com/lead.

Sincerely,



Jessica Edwards-Brandt
Manager, Drinking Water Division



Month, day, year

«First_name» «Last_Name»

«Address»

Washington, DC «Zip_Code»

Dear «First_name» «Last_Name»:

Thank you for participating in DC Water’s Lead and Copper Compliance Monitoring Program. Your participation helps us assess the effectiveness of the U.S. Army Corps of Engineers Washington Aqueduct corrosion control treatment to minimize corrosion of lead service pipes, household plumbing and fixtures that may contribute to lead and copper concentrations in drinking water.

Below are the test results from the two water samples that you collected from your household tap:

- First draw: Measures lead release from household plumbing and fixtures, especially potential sources near the tap where the sample is collected. This sample is required by the Environmental Protection Agency (EPA).
- Second draw: Measures lead release from the lead service pipe and household plumbing. DC Water voluntarily collects this sample to assess the contribution of lead in water from the lead service line.

Sample	Lead Level (ppb)	Copper Level (ppb)
First Draw		
Second Draw		

Service Line Material

Public Space: Lead

Private Property: Non-lead

If this information is inaccurate, please contact the Drinking Water Division at 202-612-3440.

DC Water recommends that you filter your water to minimize potential lead exposure if lead is present in your drinking water, if you have pipes or plumbing fixtures that contain lead, or if you don’t know the material type. If you are pregnant, nursing or have children under age six, use cold, filtered tap water for drinking and cooking until all sources of lead are removed. This includes water used for making infant formula, beverages and ice.

The potential for lead in drinking water varies among homes in the District. Drinking water is essentially lead-free when it leaves the Washington Aqueduct treatment plant, but lead can enter water when it comes in contact with pipes or plumbing fixtures that contain lead. As noted above, your property has a lead service pipe, which connects the water main in the street to household plumbing. DC Water operates a lead service replacement program and will replace the public portion of the service line during a water main replacement, or if you agree to replace the portion on your private property.

Under the authority of the Safe Drinking Water Act, EPA set a Maximum Contaminant Level Goal (MCLG) for lead at zero and for copper at 1,300 parts per billion (ppb). The MCLG is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. EPA also set an action level for lead at 15 ppb and for copper at 1,300 ppb. The action level is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. These requirements are triggered if more than 10 percent of all first draw samples collected during any monitoring period exceed the action levels. Your lead and copper results may be higher or lower than the action levels, which does not reflect DC Water’s compliance with the LCR. DC Water will notify all customers if the District’s water exceeds the lead or copper action level.

Lead can pose significant health risks if too much of it enters the body. The greatest risk of lead exposure is to infants, young children and pregnant women. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of the body. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead from other sources (such as lead-based paint and contaminated soil) can increase a person's overall exposure, which adds to the effects of lead in water.

The District Department of the Environment (DDOE) offers information on blood lead testing for young children, pregnant women and nursing mothers. For more information on minimizing lead exposure, contact DDOE at 202-654-6036 or visit www.ddoe.dc.gov or visit EPA's website at www.epa.gov/lead.

DC Water strongly encourages residents to take the following steps to reduce lead exposure:

Remove lead sources

- Replace your lead service pipe with copper. For more information about lead pipe replacement, contact the Drinking Water Division at 202-612-3440.
- Replace household galvanized plumbing. When lead is released from a lead service pipe and passes through galvanized plumbing (particularly over decades of use), lead can accumulate on the inside, corroded walls of this plumbing. Lead release from galvanized pipes can continue even after a lead service pipe is replaced.
- Install lead-free plumbing fixtures certified to meet NSF Standard 61 Annex G (NSF 61-G). Effective in 2014, fixtures that are labeled "lead-free" cannot contain more than 0.25 percent lead. Flush cold water taps, with the aerator removed, at highest flow rate for 5 minutes once a day for 3 days after installing new household pipes or fixtures.

Use filtered tap water

- Be sure to select a filter certified to meet NSF Standard 53 for lead removal. The filter package should specifically list the device as certified for removing the contaminant "lead."
- We recommend devices that are installed at your faucet tap (also known as point-of-use) or pitcher-style filters. Visit the NSF International website for certified drinking water filters at www.nsf.org/Certified/DWTU or call 1-800-673-8010.
- Be sure to routinely replace filter cartridges according to the manufacturer's instructions.

Do not use your hot water tap for drinking and cooking

- Always use cold tap water, then heat water if necessary. Boiling water does not reduce lead levels.
- Hot tap water can cause a greater amount of lead to release from plumbing. Always use cold tap water, including water used for making ice, beverages and infant formula.

Run the cold water tap when water is not used for several hours

- Run your water before using it for drinking or cooking. Once you notice a temperature change, continue running your water for 2 more minutes to receive fresh water from the water main.
- Lead and other metals can dissolve in water when it sits in pipes for a few hours.

Remove and clean faucet aerators

- Lead particles and sediment can collect in the aerator screen located at the tip of your faucet.

For more information, contact the Drinking Water Division at 202-612-3440 or visit www.dewater.com/lead.

Sincerely,



Jessica Edwards-Brandt
Manager, Drinking Water Division



Month, day, year

«First_name» «Last_Name»

«Address»

Washington, DC «Zip_Code»

Dear «First_name» «Last_Name»:

Thank you for participating in DC Water’s Lead and Copper Compliance Monitoring Program. Your participation helps us assess the effectiveness of the U.S. Army Corps of Engineers Washington Aqueduct corrosion control treatment to minimize corrosion of lead service pipes, household plumbing and fixtures that may contribute to lead and copper concentrations in drinking water.

Below are the test results from the two water samples that you collected from your household tap:

- First draw: Measures lead release from household plumbing and fixtures, especially potential sources near the tap where the sample is collected. This sample is required by the Environmental Protection Agency (EPA).
- Second draw: Measures lead release from the lead service pipe and household plumbing. DC Water voluntarily collects this sample to assess the contribution of lead in water from the lead service line.

Sample	Lead Level (ppb)	Copper Level (ppb)
First Draw		
Second Draw		

Service Line Material

Public Space: Non-lead

Private Property: Lead

If this information is inaccurate, please contact the Drinking Water Division at 202-612-3440.

DC Water recommends that you filter your water to minimize potential lead exposure if lead is present in your drinking water, if you have pipes or plumbing fixtures that contain lead, or if you don’t know the material type. If you are pregnant, nursing or have children under age six, use cold, filtered tap water for drinking and cooking until all sources of lead are removed. This includes water used for making infant formula, beverages and ice.

The potential for lead in drinking water varies among homes in the District. Drinking water is essentially lead-free when it leaves the Washington Aqueduct treatment plant, but lead can enter water when it comes in contact with pipes or plumbing fixtures that contain lead. As noted above, your property has a lead service pipe, which connects the water main in the street to household plumbing. DC Water operates a lead service replacement program and will replace the public portion of the service line during a water main replacement, or if you agree to replace the portion on your private property.

Under the authority of the Safe Drinking Water Act, EPA set a Maximum Contaminant Level Goal (MCLG) for lead at zero and for copper at 1,300 parts per billion (ppb). The MCLG is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. EPA also set an action level for lead at 15 ppb and for copper at 1,300 ppb. The action level is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. These requirements are triggered if more than 10 percent of all first draw samples collected during any monitoring period exceed the action levels. Your lead and copper results may be higher or lower than the action levels, which does not reflect DC Water’s compliance with the LCR. DC Water will notify all customers if the District’s water exceeds the lead or copper action level.

Lead can pose significant health risks if too much of it enters the body. The greatest risk of lead exposure is to infants, young children and pregnant women. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of the body. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead from other sources (such as lead-based paint and contaminated soil) can increase a person's overall exposure, which adds to the effects of lead in water.

The District Department of the Environment (DDOE) offers information on blood lead testing for young children, pregnant women and nursing mothers. For more information on minimizing lead exposure, contact DDOE at 202-654-6036 or visit www.ddoe.dc.gov or visit EPA's website at www.epa.gov/lead.

DC Water strongly encourages residents to take the following steps to reduce lead exposure:

Remove lead sources

- Replace your lead service pipe with copper. For more information about lead pipe replacement, contact the Drinking Water Division at 202-612-3440.
- Replace household galvanized plumbing. When lead is released from a lead service pipe and passes through galvanized plumbing (particularly over decades of use), lead can accumulate on the inside, corroded walls of this plumbing. Lead release from galvanized pipes can continue even after a lead service pipe is replaced.
- Install lead-free plumbing fixtures certified to meet NSF Standard 61 Annex G (NSF 61-G). Effective in 2014, fixtures that are labeled "lead-free" cannot contain more than 0.25 percent lead. Flush cold water taps, with the aerator removed, at highest flow rate for 5 minutes once a day for 3 days after installing new household pipes or fixtures.

Use filtered tap water

- Be sure to select a filter certified to meet NSF Standard 53 for lead removal. The filter package should specifically list the device as certified for removing the contaminant "lead."
- We recommend devices that are installed at your faucet tap (also known as point-of-use) or pitcher-style filters. Visit the NSF International website for certified drinking water filters at www.nsf.org/Certified/DWTU or call 1-800-673-8010.
- Be sure to routinely replace filter cartridges according to the manufacturer's instructions.

Do not use your hot water tap for drinking and cooking

- Always use cold tap water, then heat water if necessary. Boiling water does not reduce lead levels.
- Hot tap water can cause a greater amount of lead to release from plumbing. Always use cold tap water, including water used for making ice, beverages and infant formula.

Run the cold water tap when water is not used for several hours

- Run your water before using it for drinking or cooking. Once you notice a temperature change, continue running your water for 2 more minutes to receive fresh water from the water main.
- Lead and other metals can dissolve in water when it sits in pipes for a few hours.

Remove and clean faucet aerators

- Lead particles and sediment can collect in the aerator screen located at the tip of your faucet.

For more information, contact the Drinking Water Division at 202-612-3440 or visit www.dewater.com/lead.

Sincerely,



Jessica Edwards-Brandt
Manager, Drinking Water Division