

Attachment 2

Other Addition Non-Regulated Monitoring Data

Customer Collected Filtered Samples

DC Water operates a program where customers request a lead sampling kit to test their in-line point-of-use filtered water. The test kit comes with a 1-L bottle and instructions on how to take a sample. Customers collect their own sample and contact DC Water to deliver the bottle to the Washington Aqueduct. Results are then reported back to the customer through DC Water's Customer Service Program.



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 1/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-CUSTFILT- 1912124-001

Sample Location: 1610 Myrtle St NW
Customer Sample Number: 3048151
Date / Time Collected: 12/9/2019 10:00 AM

Customer Program Code: CUSTFILT
Laboratory Sample Number: 1912124-001
Date / Time Received: 12/13/2019 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/26/2019	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 4/10/2020

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-CUSTFILT- 2003172-001

Sample Location: 1st Draw 2411 Observatory PI NW

Customer Sample Number:

Date / Time Collected: 3/15/2020 2:25 PM

Customer Program Code: CUSTFILT

Laboratory Sample Number: 2003172-001

Date / Time Received: 3/20/2020 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		4/1/2020	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Customer Collected Profiles

DC Water operates a program when customers request a lead sampling kit without knowledge of their service line material. The profile kit comes with ten bottles and instructions on how to collect samples. Customers collect their own samples and contact DC Water to deliver the bottles to the Washington Aqueduct. Results are then reported back to the customer through DC Water's Customer Service Program.