

DISTRICT OF COLUMBIA WATER AND SEWER AUTHORITY I 3900 DONALDSON PLACE, NW I WASHINGTON, DC 20016

Lead and Copper Compliance Report January through June 2023

Table 1 summarizes the District of Columbia Water and Sewer Authority's (DC Water) Lead and Copper compliance sampling results for the monitoring period January through June 2023.

| Number of Samples | |
|--|-------|
| Lead and Copper | 106 |
| 90th Percentile First Draw Concentrations | |
| Lead mg/L | 0.002 |
| Copper mg/L | 0.099 |
| Service Line Materials | |
| Full Lead | 91 |
| Partial Lead | 15 |

Table 1. Lead and Copper Summary Data

The appendices and attachments contain the following information and data:

- Appendix A: Lead and Copper Compliance Sampling Data
 - Table A.1 First Draw Lead Sampling Results
 - Table A.2 First Draw Copper Sampling Results
- Appendix B: Additional Monitoring Data:
 - Table B.1 Second Draw Lead Sampling Results
 - Table B.2 Second Draw Copper Sampling Results
- Appendix C: Additional Sampling Information:
 - Table C.1 Sample Kit Distribution
 - Table C.2 Sample Kits Not Returned
 - Table C.3 Samples Returned but Rejected and Samples Invalidated for Compliance Analysis
 - Table C.4 Deviations from Sample Kit Distribution Order
 - Table C.5 Sites with Compliance Sampling Results from January 2022 December 2022 and No Results in January – June 2023
 - Table C.6 Customer Notification of Sampling Analysis Results



- Appendix D: Sample Pool
 - Table D.1 Sample Pool for July to December 2023 Sampling Period
 - Table D.2 Changes to the Sample Pool
- Appendix E: Invalidated Samples
- Attachment 1: Washington Aqueduct Laboratory Test Results for 1st and 2nd Draw
- Attachment 2: Other Samples Analyzed for Lead:
 - Customer Requested Tests
 - Post-Lead Service Line Replacement Tests
 - Customer Collected Lead Profiles
 - Customer Collected Filtered Samples
 - Lead Pipe Loops
 - Special Samples
- Attachment 3: Certification of Consumer Tap Results for January through June 2023 and Customer Letters



DISTRICT OF COLUMBIA WATER AND SEWER AUTHORITY I 3900 DONALDSON PLACE, NW I WASHINGTON, DC 20016

Appendix A: Lead and Copper Compliance Sampling Data

| No | Address | Pipe Material | Collection Date | Lead 1st draw (ppb) |
|----|---------------------------|---------------|-----------------|---------------------|
| 1 | 1115 C St NE | Lead | 3/1/2023 | 0 |
| 2 | 1225 C St SE | Lead | 5/3/2023 | 0 |
| 3 | 1332 Ritchie Pl NE | Partial Lead | 3/2/2023 | 0 |
| 4 | 1354 D St SE | Partial Lead | 3/2/2023 | 0 |
| 5 | 1415 F St NE | Lead | 4/13/2023 | 0 |
| 6 | 15 Milmarson Pl NW | Partial Lead | 2/1/2023 | 0 |
| 7 | 22 Bates St NW | Lead | 5/3/2023 | 0 |
| 8 | 2717 O ST NW | Lead | 3/2/2023 | 0 |
| 9 | 2923 Cathedral AVE NW | Partial Lead | 2/10/2023 | 0 |
| 10 | 3036 P St NW | Partial Lead | 1/31/2023 | 0 |
| 11 | 3074 Clinton St NE | Lead | 3/1/2023 | 0 |
| 12 | 313 10TH ST SE | Partial Lead | 6/13/2023 | 0 |
| 13 | 36 Florida Ave NW | Partial Lead | 2/2/2023 | 0 |
| 14 | 3617 17th St NE | Lead | 4/27/2023 | 0 |
| 15 | 3741 McKinley St NW | Lead | 6/14/2023 | 0 |
| 16 | 408 16th St SE | Lead | 3/2/2023 | 0 |
| 17 | 414 DOUGLAS ST NE | Partial Lead | 3/2/2023 | 0 |
| 18 | 419 12th St SE | Lead | 4/5/2023 | 0 |
| 19 | 423 GALLATIN ST NW | Lead | 3/3/2023 | 0 |
| 20 | 423 Shepherd St NW | Lead | 3/2/2023 | 0 |
| 21 | 4312 14th St NW | Lead | 4/4/2023 | 0 |
| 22 | 4428 9th St NW | Lead | 4/10/2023 | 0 |
| 23 | 4507 Arkansas Ave NW | Lead | 4/6/2023 | 0 |
| 24 | 4926 Glenbrook Rd NW | Partial Lead | 2/1/2023 | 0 |
| 25 | 517 5th St NE | Lead | 5/7/2023 | 0 |
| 26 | 5309 14th St NW | Lead | 4/7/2023 | 0 |
| 27 | 728 FARRAGUT ST NW | Lead | 2/1/2023 | 0 |
| 28 | 827 9th St NE | Lead | 4/7/2023 | 0 |
| 29 | 1413 West Virginia Ave NE | Lead | 6/15/2023 | 0.2 |
| 30 | 3608 17th St NE | Lead | 6/1/2023 | 0.2 |
| 31 | 5603 14th St NW | Lead | 5/3/2023 | 0.2 |
| 32 | 6125 29th St NW | Lead | 4/27/2023 | 0.2 |
| 33 | 904 Delafield Pl NW | Lead | 5/8/2023 | 0.2 |
| 34 | 105 14th St NE | Lead | 6/5/2023 | 0.3 |

Table A.1 First Draw Lead Sampling Results

| No | Address | Pipe Material | Collection Date | Lead 1st draw (ppb) |
|----|--------------------------|---------------|-----------------|---------------------|
| 35 | 1120 C St NE | Lead | 4/10/2023 | 0.3 |
| 36 | 1247 GIRARD ST NE | Lead | 3/1/2023 | 0.3 |
| 37 | 1620 Webster St NW | Lead | 2/1/2023 | 0.3 |
| 38 | 228 V ST NE | Lead | 1/31/2023 | 0.3 |
| 39 | 3004 25th St NE | Lead | 6/20/2023 | 0.3 |
| 40 | 3112 PARK PL NW | Lead | 4/7/2023 | 0.3 |
| 41 | 3206 38th St NW | Lead | 2/1/2023 | 0.3 |
| 42 | 3511 IDAHO AVE NW | Lead | 5/4/2023 | 0.3 |
| 43 | 3567 Holmead Pl NW | Lead | 3/1/2023 | 0.3 |
| 44 | 4425 14th St NE | Lead | 2/1/2023 | 0.3 |
| 45 | 4507 13TH ST NW | Lead | 4/9/2023 | 0.3 |
| 46 | 5223 KANSAS AVE NW | Partial Lead | 1/31/2023 | 0.3 |
| 47 | 559 23rd PL NE | Lead | 2/28/2023 | 0.3 |
| 48 | 1411 Delafield Pl NW | Lead | 4/10/2023 | 0.4 |
| 49 | 1416 Montague St NW | Lead | 5/3/2023 | 0.4 |
| 50 | 1501 Harvard St NW | Lead | 5/25/2023 | 0.4 |
| 51 | 1534 East Capitol St NE | Lead | 5/8/2023 | 0.4 |
| 52 | 3420 34th St NW | Lead | 3/1/2023 | 0.4 |
| 53 | 5010 Klingle St NW | Lead | 4/6/2023 | 0.4 |
| 54 | 540 5th St SE | Lead | 4/23/2023 | 0.4 |
| 55 | 5520 CAROLINA PL NW | Lead | 3/1/2023 | 0.4 |
| 56 | 5600 NEBRASKA AVE NW | Lead | 3/3/2023 | 0.4 |
| 57 | 1254 Hamlin St NE | Lead | 4/7/2023 | 0.5 |
| 58 | 1420 INGRAHAM ST NW | Partial Lead | 2/1/2023 | 0.5 |
| 59 | 1441 Ives PI SE | Lead | 6/14/2023 | 0.5 |
| 60 | 18 Milmarson Pl NW | Lead | 4/5/2023 | 0.5 |
| 61 | 2010 Klingle Rd NW | Lead | 4/17/2023 | 0.5 |
| 62 | 3206 5th St SE | Lead | 4/6/2023 | 0.5 |
| 63 | 3629 Everett St NW | Lead | 3/2/2023 | 0.5 |
| 64 | 48 Channing St NW | Lead | 5/3/2023 | 0.5 |
| 65 | 519 Rittenhouse St NW | Lead | 4/5/2023 | 0.5 |
| 66 | 521 9th St SE | Lead | 6/7/2023 | 0.5 |
| 67 | 5242 Colorado Ave NW | Lead | 4/18/2023 | 0.5 |
| 68 | 905 Kent Pl NE | Lead | 1/31/2023 | 0.5 |
| 69 | 1211 Carrollsburg PI SW | Partial Lead | 2/3/2023 | 0.6 |
| 70 | 1519 Olive St NE | Lead | 2/1/2023 | 0.6 |
| 71 | 1721 Webster St NW | Lead | 4/29/2023 | 0.6 |
| 72 | 4215 39th St NW | Partial Lead | 1/31/2023 | 0.6 |
| 73 | 1020 INDEPENDENCE AVE SE | Lead | 1/31/2023 | 0.7 |
| 74 | 1306 Girard St NE | Lead | 4/1/2023 | 0.7 |
| 75 | 1635 WEBSTER ST NW | Lead | 2/2/2023 | 0.7 |
| 76 | 3030 44TH ST NW | Partial Lead | 3/1/2023 | 0.7 |

| No | Address | Pipe Material | Collection Date | Lead 1st draw (ppb) |
|-----|---------------------------|---------------|-----------------|---------------------|
| 77 | 3248 Q St NW | Lead | 3/2/2023 | 0.7 |
| 78 | 4418 14th St NE | Lead | 2/10/2023 | 0.7 |
| 79 | 811 L St NE | Lead | 6/6/2023 | 0.7 |
| 80 | 1148 Abbey Pl NE | Lead | 5/2/2023 | 0.8 |
| 81 | 1648 ARGONNE PL NW | Lead | 3/1/2023 | 0.8 |
| 82 | 307 South Carolina Ave SE | Lead | 4/5/2023 | 0.8 |
| 83 | 4316 15th St NW | Lead | 3/7/2023 | 0.8 |
| 84 | 1621 C St SE | Lead | 4/5/2023 | 0.9 |
| 85 | 1346 F St NE | Lead | 1/31/2023 | 1.0 |
| 86 | 114 3rd St SE | Lead | 6/8/2023 | 1.2 |
| 87 | 3822 Albemarle St NW | Lead | 3/2/2023 | 1.2 |
| 88 | 4221 4th St NW | Lead | 6/5/2023 | 1.2 |
| 89 | 1418 TRINIDAD AVE NE | Lead | 6/16/2023 | 1.4 |
| 90 | 1427 Ives PI SE | Lead | 6/17/2023 | 1.4 |
| 91 | 318 14TH PL NE | Lead | 4/6/2023 | 1.4 |
| 92 | 3727 T St NW | Lead | 2/1/2023 | 1.4 |
| 93 | 4310 Chesapeake St NW | Lead | 6/26/2023 | 1.5 |
| 94 | 525 9TH ST SE | Lead | 3/2/2023 | 1.5 |
| 95 | 114 MADISON ST NW | Lead | 3/1/2023 | 1.6 |
| 96 | 1372 C St NE | Lead | 6/12/2023 | 1.7 |
| 97 | 5427 Nevada Ave NW | Lead | 3/1/2023 | 1.8 |
| 98 | 812 Van Buren ST NW | Lead | 6/9/2023 | 1.8 |
| 99 | 3107 Cathedral Ave NW | Lead | 4/5/2023 | 2.2 |
| 100 | 1408 DECATUR ST NW | Lead | 3/1/2023 | 2.6 |
| 101 | 4610 Iowa Ave NW | Lead | 5/6/2023 | 4.3 |
| 102 | 702 9th St SE | Lead | 1/31/2023 | 4.4 |
| 103 | 1353 JEFFERSON ST NW | Partial Lead | 2/1/2023 | 8.9 |
| 104 | 1328 TRINIDAD AVE NE | Lead | 6/14/2023 | 22.3 |
| 105 | 232 33rd St NE | Lead | 6/16/2023 | 79.3 |
| 106 | 219 Underwood St NW | Lead | 6/3/2023 | 360 |

Notes:

- 1) All addresses met Tier 1 criteria under 40 CFR 141.86(a)(3) as single family structures that are served by a lead service line based on DC Water's customer information and service line inventory records at the date of sample collection.
- 2) Service line material listings are representative of the pipe material known at the time the sample was collected.
- 3) Results expressed as "0" may have been reported by the laboratory as less than 0.0002 mg/L or nondetect.

Pipe Material Collection Date Copper 1st draw (ppb) No Address 1 728 FARRAGUT ST NW Lead 2/1/2023 3.8 2 4.0 Lead 4/13/2023 1415 F St NE 3 4.1 4312 14th St NW Lead 4/4/2023 4 4.3 4428 9th St NW Lead 4/10/2023 5 318 14TH PL NE Lead 4/6/2023 5.5 6 4507 13TH ST NW Lead 4/9/2023 6.4 7 18 Milmarson Pl NW Lead 4/5/2023 6.6 8 1519 Olive St NE Lead 6.7 2/1/2023 9 4316 15th St NW Lead 3/7/2023 6.7 Lead 7.2 10 2717 O ST NW 3/2/2023 Lead 7.2 11 3617 17th St NE 4/27/2023 7.3 12 5427 Nevada Ave NW Lead 3/1/2023 7.4 13 1332 Ritchie Pl NE Partial Lead 3/2/2023 14 1413 West Virginia Ave NE Lead 6/15/2023 7.7 15 3206 5th St SE Lead 4/6/2023 8.0 904 Delafield Pl NW Lead 8.0 16 5/8/2023 17 3608 17th St NE Lead 6/1/2023 8.3 8.5 18 702 9th St SE Lead 1/31/2023 19 1148 Abbey PI NE Lead 5/2/2023 8.5 9.2 20 48 Channing St NW Lead 5/3/2023 21 423 Shepherd St NW Lead 9.4 3/2/2023 22 1408 DECATUR ST NW Lead 10.3 3/1/2023 23 827 9th St NE Lead 4/7/2023 10.3 24 1346 F St NE Lead 11.1 1/31/2023 25 1534 East Capitol St NE Lead 5/8/2023 11.5 26 **1635 WEBSTER ST NW** Lead 2/2/2023 12.0 27 3822 Albemarle St NW Lead 3/2/2023 12.1 28 5603 14th St NW Lead 5/3/2023 13.9 29 1306 Girard St NE Lead 4/1/2023 14.6 30 3206 38th St NW Lead 2/1/2023 15.0 31 3074 Clinton St NE Lead 3/1/2023 15.1 15.2 32 1441 Ives PI SE Lead 6/14/2023 16.1 33 525 9TH ST SE Lead 3/2/2023 34 16.6 **1020 INDEPENDENCE AVE SE** Lead 1/31/2023 16.9 35 **5223 KANSAS AVE NW** Partial Lead 1/31/2023 36 1420 INGRAHAM ST NW Partial Lead 2/1/2023 17.0 17.4 37 905 Kent Pl NE Lead 1/31/2023 18.6 38 1427 Ives PI SE Lead 6/17/2023 219 Underwood St NW Lead 18.8 39 6/3/2023 40 812 Van Buren ST NW Lead 6/9/2023 18.9

Table A.2 First Draw Copper Results

| No | Address | Pipe Material | Collection Date | Copper 1st draw (ppb) |
|----|---------------------------|---------------|------------------------|-----------------------|
| 41 | 228 V ST NE | Lead | 1/31/2023 | 20.7 |
| 42 | 2923 Cathedral AVE NW | Partial Lead | 2/10/2023 | 21.0 |
| 43 | 423 GALLATIN ST NW | Lead | 3/3/2023 | 21.9 |
| 44 | 22 Bates St NW | Lead | 5/3/2023 | 22.5 |
| 45 | 1721 Webster St NW | Lead | 4/29/2023 | 22.8 |
| 46 | 5520 CAROLINA PL NW | Lead | 3/1/2023 | 23.3 |
| 47 | 1115 C St NE | Lead | 3/1/2023 | 24.4 |
| 48 | 3030 44TH ST NW | Partial Lead | 3/1/2023 | 24.9 |
| 49 | 1648 ARGONNE PL NW | Lead | 3/1/2023 | 26.3 |
| 50 | 811 L St NE | Lead | 6/6/2023 | 26.7 |
| 51 | 3248 Q St NW | Lead | 3/2/2023 | 27.6 |
| 52 | 307 South Carolina Ave SE | Lead | 4/5/2023 | 29.9 |
| 53 | 5010 Klingle St NW | Lead | 4/6/2023 | 30.1 |
| 54 | 1621 C St SE | Lead | 4/5/2023 | 31.0 |
| 55 | 3567 Holmead Pl NW | Lead | 3/1/2023 | 31.8 |
| 56 | 3727 T St NW | Lead | 2/1/2023 | 31.9 |
| 57 | 559 23rd PL NE | Lead | 2/28/2023 | 32.1 |
| 58 | 4507 Arkansas Ave NW | Lead | 4/6/2023 | 32.4 |
| 59 | 540 5th St SE | Lead | 4/23/2023 | 36.4 |
| 60 | 521 9th St SE | Lead | 6/7/2023 | 39.2 |
| 61 | 105 14th St NE | Lead | 6/5/2023 | 39.3 |
| 62 | 3741 McKinley St NW | Lead | 6/14/2023 | 41.1 |
| 63 | 1328 TRINIDAD AVE NE | Lead | 6/14/2023 | 41.6 |
| 64 | 313 10TH ST SE | Partial Lead | 6/13/2023 | 42.1 |
| 65 | 4310 Chesapeake St NW | Lead | 6/26/2023 | 43.5 |
| 66 | 1354 D St SE | Partial Lead | 3/2/2023 | 43.9 |
| 67 | 3036 P St NW | Partial Lead | 1/31/2023 | 44.8 |
| 68 | 4221 4th St NW | Lead | 6/5/2023 | 45.1 |
| 69 | 5309 14th St NW | Lead | 4/7/2023 | 45.4 |
| 70 | 1620 Webster St NW | Lead | 2/1/2023 | 45.5 |
| 71 | 419 12th St SE | Lead | 4/5/2023 | 46.9 |
| 72 | 6125 29th St NW | Lead | 4/27/2023 | 49.0 |
| 73 | 3112 PARK PL NW | Lead | 4/7/2023 | 49.2 |
| 74 | 1501 Harvard St NW | Lead | 5/25/2023 | 50.3 |
| 75 | 5242 Colorado Ave NW | Lead | 4/18/2023 | 51.8 |
| 76 | 1120 C St NE | Lead | 4/10/2023 | 53.9 |
| 77 | 4425 14th St NE | Lead | 2/1/2023 | 54.6 |
| 78 | 4418 14th St NE | Lead | 2/10/2023 | 56.2 |
| 79 | 408 16th St SE | Lead | 3/2/2023 | 56.7 |
| 80 | 414 DOUGLAS ST NE | Partial Lead | 3/2/2023 | 60.4 |
| 81 | 1418 TRINIDAD AVE NE | Lead | 6/16/2023 | 63.1 |
| 82 | 2010 Klingle Rd NW | Lead | 4/17/2023 | 63.2 |

7

| No | Address | Pipe Material | Collection Date | Copper 1st draw (ppb) |
|-----|-------------------------|---------------|------------------------|-----------------------|
| 83 | 114 MADISON ST NW | Lead | 3/1/2023 | 66.2 |
| 84 | 3107 Cathedral Ave NW | Lead | 4/5/2023 | 66.6 |
| 85 | 1225 C St SE | Lead | 5/3/2023 | 68.7 |
| 86 | 3420 34th St NW | Lead | 3/1/2023 | 69.4 |
| 87 | 1247 GIRARD ST NE | Lead | 3/1/2023 | 71.9 |
| 88 | 15 Milmarson Pl NW | Partial Lead | 2/1/2023 | 72.1 |
| 89 | 1254 Hamlin St NE | Lead | 4/7/2023 | 72.1 |
| 90 | 1416 Montague St NW | Lead | 5/3/2023 | 85.3 |
| 91 | 3004 25th St NE | Lead | 6/20/2023 | 87.9 |
| 92 | 4215 39th St NW | Partial Lead | 1/31/2023 | 89.2 |
| 93 | 5600 NEBRASKA AVE NW | Lead | 3/3/2023 | 90.4 |
| 94 | 3629 Everett St NW | Lead | 3/2/2023 | 95.8 |
| 95 | 4926 Glenbrook Rd NW | Partial Lead | 2/1/2023 | 98.8 |
| 96 | 1211 Carrollsburg Pl SW | Partial Lead | 2/3/2023 | 99.3 |
| 97 | 519 Rittenhouse St NW | Lead | 4/5/2023 | 103 |
| 98 | 1372 C St NE | Lead | 6/12/2023 | 109 |
| 99 | 3511 IDAHO AVE NW | Lead | 5/4/2023 | 109 |
| 100 | 517 5th St NE | Lead | 5/7/2023 | 113 |
| 101 | 114 3rd St SE | Lead | 6/8/2023 | 130 |
| 102 | 36 Florida Ave NW | Partial Lead | 2/2/2023 | 169 |
| 103 | 4610 Iowa Ave NW | Lead | 5/6/2023 | 192 |
| 104 | 1411 Delafield Pl NW | Lead | 4/10/2023 | 192 |
| 105 | 1353 JEFFERSON ST NW | Partial Lead | 2/1/2023 | 210 |
| 106 | 232 33rd St NE | Lead | 6/16/2023 | 445 |

Notes:

- 1) All addresses met Tier 1 criteria under 40 CFR 141.86(a)(3) as single family structures that are served by a lead service line based on DC Water's customer information and service line inventory records on the date of sample collection.
- 2) Service line material listings are representative of the pipe material known at the time the sample was collected.

Appendix B: Additional Monitoring Data

Tables B.1 and B.2 present results from the second draw samples collected during the period of the Lead and Copper Rule compliance sampling. Additional monitoring data presented in Attachment 2 to this report contains sample data collected from other DC Water programs that focused on lead, copper, or other metals that included lead sample results. A description of the program followed by the data set is included in Attachment 2.

| No | Address | Pipe Material | Collection Date | Lead 2nd draw (ppb) |
|----|-------------------------|---------------|-----------------|---------------------|
| 1 | 1115 C St NE | Lead | 3/1/2023 | 0 |
| 2 | 1225 C St SE | Lead | 5/3/2023 | 0 |
| 3 | 1332 Ritchie Pl NE | Partial Lead | 3/2/2023 | 0 |
| 4 | 1354 D St SE | Partial Lead | 3/2/2023 | 0 |
| 5 | 1534 East Capitol St NE | Lead | 5/8/2023 | 0 |
| 6 | 1620 Webster St NW | Lead | 2/1/2023 | 0 |
| 7 | 22 Bates St NW | Lead | 5/3/2023 | 0 |
| 8 | 2923 Cathedral AVE NW | Partial Lead | 2/10/2023 | 0 |
| 9 | 3036 P St NW | Partial Lead | 1/31/2023 | 0 |
| 10 | 3074 Clinton St NE | Lead | 3/1/2023 | 0 |
| 11 | 3567 Holmead Pl NW | Lead | 3/1/2023 | 0 |
| 12 | 36 Florida Ave NW | Partial Lead | 2/2/2023 | 0 |
| 13 | 408 16th St SE | Lead | 3/2/2023 | 0 |
| 14 | 419 12th St SE | Lead | 4/5/2023 | 0 |
| 15 | 423 Shepherd St NW | Lead | 3/2/2023 | 0 |
| 16 | 4507 Arkansas Ave NW | Lead | 4/6/2023 | 0 |
| 17 | 4926 Glenbrook Rd NW | Partial Lead | 2/1/2023 | 0 |
| 18 | 517 5th St NE | Lead | 5/7/2023 | 0 |
| 19 | 5223 KANSAS AVE NW | Partial Lead | 1/31/2023 | 0 |
| 20 | 5242 Colorado Ave NW | Lead | 4/18/2023 | 0 |
| 21 | 5309 14th St NW | Lead | 4/7/2023 | 0 |
| 22 | 559 23rd PL NE | Lead | 2/28/2023 | 0 |
| 23 | 728 FARRAGUT ST NW | Lead | 2/1/2023 | 0 |
| 24 | 827 9th St NE | Lead | 4/7/2023 | 0 |
| 25 | 1519 Olive St NE | Lead | 2/1/2023 | 0.2 |
| 26 | 414 DOUGLAS ST NE | Partial Lead | 3/2/2023 | 0.2 |
| 27 | 423 GALLATIN ST NW | Lead | 3/3/2023 | 0.2 |
| 28 | 5520 CAROLINA PL NW | Lead | 3/1/2023 | 0.2 |
| 29 | 1247 GIRARD ST NE | Lead | 3/1/2023 | 0.3 |
| 30 | 1635 WEBSTER ST NW | Lead | 2/2/2023 | 0.3 |
| 31 | 1721 Webster St NW | Lead | 4/29/2023 | 0.3 |
| 32 | 4428 9th St NW | Lead | 4/10/2023 | 0.3 |
| 33 | 1306 Girard St NE | Lead | 4/1/2023 | 0.4 |

Table B.1 Second Draw Lead Sampling Results

| No | Address | Pipe Material | Collection Date | Lead 2nd draw (ppb) |
|----|---------------------------|---------------|-----------------|---------------------|
| 34 | 1416 Montague St NW | Lead | 5/3/2023 | 0.4 |
| 35 | 1501 Harvard St NW | Lead | 5/25/2023 | 0.4 |
| 36 | 3206 38th St NW | Lead | 2/1/2023 | 0.4 |
| 37 | 4425 14th St NE | Lead | 2/1/2023 | 0.4 |
| 38 | 5010 Klingle St NW | Lead | 4/6/2023 | 0.4 |
| 39 | 1120 C St NE | Lead | 4/10/2023 | 0.5 |
| 40 | 1408 DECATUR ST NW | Lead | 3/1/2023 | 0.5 |
| 41 | 1413 West Virginia Ave NE | Lead | 6/15/2023 | 0.5 |
| 42 | 313 10TH ST SE | Partial Lead | 6/13/2023 | 0.5 |
| 43 | 3420 34th St NW | Lead | 3/1/2023 | 0.5 |
| 44 | 521 9th St SE | Lead | 6/7/2023 | 0.5 |
| 45 | 540 5th St SE | Lead | 4/23/2023 | 0.5 |
| 46 | 905 Kent Pl NE | Lead | 1/31/2023 | 0.5 |
| 47 | 1415 F St NE | Lead | 4/13/2023 | 0.6 |
| 48 | 3112 PARK PL NW | Lead | 4/7/2023 | 0.6 |
| 49 | 4312 14th St NW | Lead | 4/4/2023 | 0.6 |
| 50 | 4507 13TH ST NW | Lead | 4/9/2023 | 0.6 |
| 51 | 48 Channing St NW | Lead | 5/3/2023 | 0.6 |
| 52 | 1254 Hamlin St NE | Lead | 4/7/2023 | 0.7 |
| 53 | 2010 Klingle Rd NW | Lead | 4/17/2023 | 0.7 |
| 54 | 2717 O ST NW | Lead | 3/2/2023 | 0.7 |
| 55 | 318 14TH PL NE | Lead | 4/6/2023 | 0.7 |
| 56 | 4316 15th St NW | Lead | 3/7/2023 | 0.7 |
| 57 | 702 9th St SE | Lead | 1/31/2023 | 0.7 |
| 58 | 904 Delafield Pl NW | Lead | 5/8/2023 | 0.7 |
| 59 | 15 Milmarson Pl NW | Partial Lead | 2/1/2023 | 0.8 |
| 60 | 3004 25th St NE | Lead | 6/20/2023 | 0.8 |
| 61 | 5603 14th St NW | Lead | 5/3/2023 | 0.8 |
| 62 | 811 L St NE | Lead | 6/6/2023 | 0.8 |
| 63 | 18 Milmarson Pl NW | Lead | 4/5/2023 | 0.9 |
| 64 | 3030 44TH ST NW | Partial Lead | 3/1/2023 | 0.9 |
| 65 | 3822 Albemarle St NW | Lead | 3/2/2023 | 1.0 |
| 66 | 525 9TH ST SE | Lead | 3/2/2023 | 1.0 |
| 67 | 6125 29th St NW | Lead | 4/27/2023 | 1.0 |
| 68 | 1441 Ives PI SE | Lead | 6/14/2023 | 1.1 |
| 69 | 1648 ARGONNE PL NW | Lead | 3/1/2023 | 1.1 |
| 70 | 3608 17th St NE | Lead | 6/1/2023 | 1.1 |
| 71 | 3206 5th St SE | Lead | 4/6/2023 | 1.2 |
| 72 | 3617 17th St NE | Lead | 4/27/2023 | 1.2 |
| 73 | 5600 NEBRASKA AVE NW | Lead | 3/3/2023 | 1.2 |
| 74 | 228 V ST NE | Lead | 1/31/2023 | 1.3 |
| 75 | 3511 IDAHO AVE NW | Lead | 5/4/2023 | 1.4 |

10

| No | Address | Pipe Material | Collection Date | Lead 2nd draw (ppb) |
|-----|---------------------------------|---------------|-----------------|---------------------|
| 76 | 3107 Cathedral Ave NW | Lead | 4/5/2023 | 1.5 |
| 77 | 3248 Q St NW | Lead | 3/2/2023 | 1.5 |
| 78 | 3629 Everett St NW | Lead | 3/2/2023 | 1.5 |
| 79 | 3741 McKinley St NW | Lead | 6/14/2023 | 1.5 |
| 80 | 4310 Chesapeake St NW | Lead | 6/26/2023 | 1.5 |
| 81 | 114 3rd St SE | Lead | 6/8/2023 | 1.6 |
| 82 | 105 14th St NE | Lead | 6/5/2023 | 1.7 |
| 83 | 1353 JEFFERSON ST NW | Partial Lead | 2/1/2023 | 1.7 |
| 84 | 1411 Delafield Pl NW | Lead | 4/10/2023 | 1.7 |
| 85 | 4610 Iowa Ave NW | Lead | 5/6/2023 | 1.7 |
| 86 | 4418 14th St NE | Lead | 2/10/2023 | 1.8 |
| 87 | 5427 Nevada Ave NW | Lead | 3/1/2023 | 1.8 |
| 88 | 1621 C St SE | Lead | 4/5/2023 | 1.9 |
| 89 | 4215 39th St NW | Partial Lead | 1/31/2023 | 2.0 |
| 90 | 519 Rittenhouse St NW | Lead | 4/5/2023 | 2.0 |
| 91 | 114 MADISON ST NW | Lead | 3/1/2023 | 2.1 |
| 92 | 1346 F St NE | Lead | 1/31/2023 | 2.3 |
| 93 | 1020 INDEPENDENCE AVE SE | Lead | 1/31/2023 | 2.5 |
| 94 | 4221 4th St NW | Lead | 6/5/2023 | 2.5 |
| 95 | 232 33rd St NE | Lead | 6/16/2023 | 3.0 |
| 96 | 812 Van Buren ST NW | Lead | 6/9/2023 | 3.1 |
| 97 | 1211 Carrollsburg PI SW | Partial Lead | 2/3/2023 | 3.2 |
| 98 | 307 South Carolina Ave SE | Lead | 4/5/2023 | 3.3 |
| 99 | 1418 TRINIDAD AVE NE | Lead | 6/16/2023 | 3.5 |
| 100 | 3727 T St NW | Lead | 2/1/2023 | 3.7 |
| 101 | 1148 Abbey Pl NE | Lead | 5/2/2023 | 4.9 |
| 102 | 219 Underwood St NW | Lead | 6/3/2023 | 7.3 |
| 103 | 1427 Ives PI SE | Lead | 6/17/2023 | 8.5 |
| 104 | 1328 TRINIDAD AVE NE | Lead | 6/14/2023 | 8.6 |

Notes:

- 1) Service line material listings are representative of the pipe material known at the time the sample was collected.
- 2) Results expressed as "0" may have been reported by the laboratory as less than 0.0002 mg/L or nondetect.
- The second draw samples were rejected due to sampling error: 1420 Ingraham St NW and 1372 C St NE.

| No | Address | Pipe Material | Collection Date | Copper 2nd draw (ppb) |
|----|---------------------------|---------------|------------------------|-----------------------|
| 1 | 1620 Webster St NW | Lead | 2/1/2023 | 3.4 |
| 2 | 318 14TH PL NE | Lead | 4/6/2023 | 3.5 |
| 3 | 728 FARRAGUT ST NW | Lead | 2/1/2023 | 3.5 |
| 4 | 1408 DECATUR ST NW | Lead | 3/1/2023 | 4.2 |
| 5 | 702 9th St SE | Lead | 1/31/2023 | 4.2 |
| 6 | 1519 Olive St NE | Lead | 2/1/2023 | 4.3 |
| 7 | 812 Van Buren ST NW | Lead | 6/9/2023 | 4.3 |
| 8 | 4316 15th St NW | Lead | 3/7/2023 | 4.6 |
| 9 | 5427 Nevada Ave NW | Lead | 3/1/2023 | 4.6 |
| 10 | 1306 Girard St NE | Lead | 4/1/2023 | 4.7 |
| 11 | 5223 KANSAS AVE NW | Partial Lead | 1/31/2023 | 5.3 |
| 12 | 3036 P St NW | Partial Lead | 1/31/2023 | 5.5 |
| 13 | 904 Delafield Pl NW | Lead | 5/8/2023 | 5.5 |
| 14 | 1020 INDEPENDENCE AVE SE | Lead | 1/31/2023 | 5.7 |
| 15 | 1621 C St SE | Lead | 4/5/2023 | 5.7 |
| 16 | 1534 East Capitol St NE | Lead | 5/8/2023 | 5.8 |
| 17 | 307 South Carolina Ave SE | Lead | 4/5/2023 | 5.8 |
| 18 | 1346 F St NE | Lead | 1/31/2023 | 5.9 |
| 19 | 4507 Arkansas Ave NW | Lead | 4/6/2023 | 6.1 |
| 20 | 5603 14th St NW | Lead | 5/3/2023 | 6.1 |
| 21 | 1332 Ritchie Pl NE | Partial Lead | 3/2/2023 | 6.3 |
| 22 | 3206 38th St NW | Lead | 2/1/2023 | 6.4 |
| 23 | 4428 9th St NW | Lead | 4/10/2023 | 6.4 |
| 24 | 1148 Abbey Pl NE | Lead | 5/2/2023 | 6.6 |
| 25 | 3206 5th St SE | Lead | 4/6/2023 | 6.6 |
| 26 | 1115 C St NE | Lead | 3/1/2023 | 7.1 |
| 27 | 1635 WEBSTER ST NW | Lead | 2/2/2023 | 7.1 |
| 28 | 408 16th St SE | Lead | 3/2/2023 | 7.3 |
| 29 | 1415 F St NE | Lead | 4/13/2023 | 8.0 |
| 30 | 48 Channing St NW | Lead | 5/3/2023 | 8.0 |
| 31 | 228 V ST NE | Lead | 1/31/2023 | 8.4 |
| 32 | 5520 CAROLINA PL NW | Lead | 3/1/2023 | 8.4 |
| 33 | 1413 West Virginia Ave NE | Lead | 6/15/2023 | 8.6 |
| 34 | 22 Bates St NW | Lead | 5/3/2023 | 8.7 |
| 35 | 5010 Klingle St NW | Lead | 4/6/2023 | 9.0 |
| 36 | 1354 D St SE | Partial Lead | 3/2/2023 | 9.2 |
| 37 | 3727 T St NW | Lead | 2/1/2023 | 9.2 |
| 38 | 3741 McKinley St NW | Lead | 6/14/2023 | 9.2 |
| 39 | 2923 Cathedral AVE NW | Partial Lead | 2/10/2023 | 9.3 |
| 40 | 3112 PARK PL NW | Lead | 4/7/2023 | 9.3 |

Table B.2 Second Draw Copper Sampling Results

| No | Address | Pipe Material | Collection Date | Copper 2nd draw (ppb) |
|----|-------------------------|---------------|------------------------|-----------------------|
| 41 | 15 Milmarson Pl NW | Partial Lead | 2/1/2023 | 9.5 |
| 42 | 521 9th St SE | Lead | 6/7/2023 | 9.9 |
| 43 | 3608 17th St NE | Lead | 6/1/2023 | 10.0 |
| 44 | 3567 Holmead Pl NW | Lead | 3/1/2023 | 10.3 |
| 45 | 4418 14th St NE | Lead | 2/10/2023 | 10.5 |
| 46 | 3822 Albemarle St NW | Lead | 3/2/2023 | 10.6 |
| 47 | 423 Shepherd St NW | Lead | 3/2/2023 | 10.7 |
| 48 | 3629 Everett St NW | Lead | 3/2/2023 | 10.8 |
| 49 | 3248 Q St NW | Lead | 3/2/2023 | 11.0 |
| 50 | 4312 14th St NW | Lead | 4/4/2023 | 11.1 |
| 51 | 18 Milmarson Pl NW | Lead | 4/5/2023 | 11.2 |
| 52 | 519 Rittenhouse St NW | Lead | 4/5/2023 | 11.2 |
| 53 | 419 12th St SE | Lead | 4/5/2023 | 11.4 |
| 54 | 414 DOUGLAS ST NE | Partial Lead | 3/2/2023 | 11.7 |
| 55 | 525 9TH ST SE | Lead | 3/2/2023 | 11.7 |
| 56 | 1120 C St NE | Lead | 4/10/2023 | 12.0 |
| 57 | 3617 17th St NE | Lead | 4/27/2023 | 12.6 |
| 58 | 313 10TH ST SE | Partial Lead | 6/13/2023 | 13.0 |
| 59 | 1225 C St SE | Lead | 5/3/2023 | 13.5 |
| 60 | 4507 13TH ST NW | Lead | 4/9/2023 | 13.5 |
| 61 | 540 5th St SE | Lead | 4/23/2023 | 15.4 |
| 62 | 3107 Cathedral Ave NW | Lead | 4/5/2023 | 15.5 |
| 63 | 3074 Clinton St NE | Lead | 3/1/2023 | 15.9 |
| 64 | 4425 14th St NE | Lead | 2/1/2023 | 15.9 |
| 65 | 6125 29th St NW | Lead | 4/27/2023 | 15.9 |
| 66 | 1418 TRINIDAD AVE NE | Lead | 6/16/2023 | 16.8 |
| 67 | 1254 Hamlin St NE | Lead | 4/7/2023 | 16.9 |
| 68 | 3004 25th St NE | Lead | 6/20/2023 | 17.7 |
| 69 | 1328 TRINIDAD AVE NE | Lead | 6/14/2023 | 18.0 |
| 70 | 827 9th St NE | Lead | 4/7/2023 | 18.2 |
| 71 | 1441 Ives PI SE | Lead | 6/14/2023 | 18.5 |
| 72 | 5309 14th St NW | Lead | 4/7/2023 | 19.1 |
| 73 | 4221 4th St NW | Lead | 6/5/2023 | 19.8 |
| 74 | 4215 39th St NW | Partial Lead | 1/31/2023 | 20.0 |
| 75 | 5600 NEBRASKA AVE NW | Lead | 3/3/2023 | 20.5 |
| 76 | 1211 Carrollsburg Pl SW | Partial Lead | 2/3/2023 | 20.6 |
| 77 | 5242 Colorado Ave NW | Lead | 4/18/2023 | 20.9 |
| 78 | 1427 Ives PI SE | Lead | 6/17/2023 | 21.0 |
| 79 | 1501 Harvard St NW | Lead | 5/25/2023 | 21.0 |
| 80 | 4310 Chesapeake St NW | Lead | 6/26/2023 | 21.1 |
| 81 | 1648 ARGONNE PL NW | Lead | 3/1/2023 | 21.6 |
| 82 | 559 23rd PL NE | Lead | 2/28/2023 | 23.2 |

| No | Address | Pipe Material | Collection Date | Copper 2nd draw (ppb) |
|-----|----------------------|---------------|------------------------|-----------------------|
| 83 | 423 GALLATIN ST NW | Lead | 3/3/2023 | 23.7 |
| 84 | 114 MADISON ST NW | Lead | 3/1/2023 | 25.6 |
| 85 | 232 33rd St NE | Lead | 6/16/2023 | 25.8 |
| 86 | 3511 IDAHO AVE NW | Lead | 5/4/2023 | 26.9 |
| 87 | 4926 Glenbrook Rd NW | Partial Lead | 2/1/2023 | 28.4 |
| 88 | 3030 44TH ST NW | Partial Lead | 3/1/2023 | 28.9 |
| 89 | 2010 Klingle Rd NW | Lead | 4/17/2023 | 29.1 |
| 90 | 105 14th St NE | Lead | 6/5/2023 | 35.4 |
| 91 | 3420 34th St NW | Lead | 3/1/2023 | 35.6 |
| 92 | 1353 JEFFERSON ST NW | Partial Lead | 2/1/2023 | 39.9 |
| 93 | 1247 GIRARD ST NE | Lead | 3/1/2023 | 41.2 |
| 94 | 517 5th St NE | Lead | 5/7/2023 | 41.2 |
| 95 | 1416 Montague St NW | Lead | 5/3/2023 | 44.3 |
| 96 | 1411 Delafield Pl NW | Lead | 4/10/2023 | 46.3 |
| 97 | 36 Florida Ave NW | Partial Lead | 2/2/2023 | 50.6 |
| 98 | 219 Underwood St NW | Lead | 6/3/2023 | 57.4 |
| 99 | 905 Kent Pl NE | Lead | 1/31/2023 | 59.2 |
| 100 | 811 L St NE | Lead | 6/6/2023 | 63.7 |
| 101 | 1721 Webster St NW | Lead | 4/29/2023 | 67.6 |
| 102 | 2717 O ST NW | Lead | 3/2/2023 | 91.1 |
| 103 | 4610 Iowa Ave NW | Lead | 5/6/2023 | 92.3 |
| 104 | 114 3rd St SE | Lead | 6/8/2023 | 139 |

Notes:

- 1) Service line material listings are representative of the pipe material known at the time the sample was collected.
- 2) The second draw samples were rejected due to sampling error: 1420 Ingraham St NW and 1372 C St NE.

Appendix C: Additional Sampling Information

Table C.1 Sample Kit Distribution

| No. | Address | Sample Kit Distribution Date |
|-----|--------------------------|------------------------------|
| 1 | 1721 Webster St NW | 03-Jan-23 |
| 2 | 4316 15th St NW | 24-Jan-23 |
| 3 | 10 S St NW | 30-Jan-23 |
| 4 | 1020 INDEPENDENCE AVE SE | 30-Jan-23 |
| 5 | 1211 Carrollsburg Pl SW | 30-Jan-23 |
| 6 | 1346 F St NE | 30-Jan-23 |
| 7 | 1353 JEFFERSON ST NW | 30-Jan-23 |
| 8 | 1420 INGRAHAM ST NW | 30-Jan-23 |
| 9 | 15 Milmarson Pl NW | 30-Jan-23 |
| 10 | 1505 Buchanan St NW | 30-Jan-23 |
| 11 | 1519 Olive St NE | 30-Jan-23 |
| 12 | 1620 Webster St NW | 30-Jan-23 |
| 13 | 1635 WEBSTER ST NW | 30-Jan-23 |
| 14 | 1649 HARVARD ST NW | 30-Jan-23 |
| 15 | 1706 NEW JERSEY AVE NW | 30-Jan-23 |
| 16 | 1808 KEARNY ST NE | 30-Jan-23 |
| 17 | 1826 Jackson St NE | 30-Jan-23 |
| 18 | 2007 37TH ST NW | 30-Jan-23 |
| 19 | 2036 17TH ST NW | 30-Jan-23 |
| 20 | 228 V ST NE | 30-Jan-23 |
| 21 | 231 K St NE | 30-Jan-23 |
| 22 | 2923 Cathedral AVE NW | 30-Jan-23 |
| 23 | 3036 P St NW | 30-Jan-23 |
| 24 | 313 10TH ST SE | 30-Jan-23 |
| 25 | 3206 38th St NW | 30-Jan-23 |
| 26 | 3211 Central Ave NE | 30-Jan-23 |
| 27 | 3301 BROWN St NW | 30-Jan-23 |
| 28 | 36 Florida Ave NW | 30-Jan-23 |
| 29 | 3727 T St NW | 30-Jan-23 |
| 30 | 4215 39th St NW | 30-Jan-23 |
| 31 | 4418 14th St NE | 30-Jan-23 |
| 32 | 4425 14th St NE | 30-Jan-23 |
| 33 | 4926 Glenbrook Rd NW | 30-Jan-23 |
| 34 | 5223 KANSAS AVE NW | 30-Jan-23 |
| 35 | 5404 39TH ST NW | 30-Jan-23 |
| 36 | 619 12th St NE | 30-Jan-23 |
| 37 | 702 9th St SE | 30-Jan-23 |
| 38 | 728 FARRAGUT ST NW | 30-Jan-23 |

| No. | Address | Sample Kit Distribution Date |
|-----|------------------------|------------------------------|
| 39 | 905 Kent Pl NE | 30-Jan-23 |
| 40 | 4316 15th St NW | 08-Feb-23 |
| 41 | 4418 14th St NE | 09-Feb-23 |
| 42 | 1115 C St NE | 28-Feb-23 |
| 43 | 114 MADISON ST NW | 28-Feb-23 |
| 44 | 1247 GIRARD ST NE | 28-Feb-23 |
| 45 | 132 11th St SE | 28-Feb-23 |
| 46 | 1332 Ritchie Pl NE | 28-Feb-23 |
| 47 | 1354 D St SE | 28-Feb-23 |
| 48 | 1408 DECATUR ST NW | 28-Feb-23 |
| 49 | 15 14th St SE | 28-Feb-23 |
| 50 | 1648 ARGONNE PL NW | 28-Feb-23 |
| 51 | 219 Underwood St NW | 28-Feb-23 |
| 52 | 2414 Observatory Pl NW | 28-Feb-23 |
| 53 | 2717 11th St NW | 28-Feb-23 |
| 54 | 2717 O ST NW | 28-Feb-23 |
| 55 | 3030 44TH ST NW | 28-Feb-23 |
| 56 | 305 7th St NE | 28-Feb-23 |
| 57 | 3074 Clinton St NE | 28-Feb-23 |
| 58 | 3114 15th St NE | 28-Feb-23 |
| 59 | 317 TENNESSEE AVE NE | 28-Feb-23 |
| 60 | 3248 Q St NW | 28-Feb-23 |
| 61 | 338 14th St SE | 28-Feb-23 |
| 62 | 3420 34th St NW | 28-Feb-23 |
| 63 | 3567 Holmead Pl NW | 28-Feb-23 |
| 64 | 3629 Everett St NW | 28-Feb-23 |
| 65 | 3743 W ST NW | 28-Feb-23 |
| 66 | 3822 Albemarle St NW | 28-Feb-23 |
| 67 | 408 16th St SE | 28-Feb-23 |
| 68 | 414 DOUGLAS ST NE | 28-Feb-23 |
| 69 | 423 GALLATIN ST NW | 28-Feb-23 |
| 70 | 423 Shepherd St NW | 28-Feb-23 |
| 71 | 4233 JENIFER ST NW | 28-Feb-23 |
| 72 | 4536 Lowell St NW | 28-Feb-23 |
| 73 | 5019 16TH ST NW | 28-Feb-23 |
| 74 | 511 Tennessee Ave NE | 28-Feb-23 |
| 75 | 523 12th ST NE | 28-Feb-23 |
| 76 | 525 9TH ST SE | 28-Feb-23 |
| 77 | 5427 Nevada Ave NW | 28-Feb-23 |
| 78 | 5520 CAROLINA PL NW | 28-Feb-23 |
| 79 | 559 23rd PL NE | 28-Feb-23 |
| 80 | 5600 NEBRASKA AVE NW | 28-Feb-23 |

16

| No. | Address | Sample Kit Distribution Date |
|-----|---------------------------|------------------------------|
| 81 | 1721 Webster St NW | 10-Mar-23 |
| 82 | 114 3rd St SE | 15-Mar-23 |
| 83 | 1306 Girard St NE | 31-Mar-23 |
| 84 | 1120 C St NE | 04-Apr-23 |
| 85 | 120 Kentucky Ave SE | 04-Apr-23 |
| 86 | 1254 Hamlin St NE | 04-Apr-23 |
| 87 | 1310 Locust Rd NW | 04-Apr-23 |
| 88 | 1411 Delafield Pl NW | 04-Apr-23 |
| 89 | 1417 Crittenden St NW | 04-Apr-23 |
| 90 | 1620 Underwood St NW | 04-Apr-23 |
| 91 | 1621 C St SE | 04-Apr-23 |
| 92 | 1627 Newton St NW | 04-Apr-23 |
| 93 | 18 Milmarson Pl NW | 04-Apr-23 |
| 94 | 2010 Klingle Rd NW | 04-Apr-23 |
| 95 | 2326 20th St NW | 04-Apr-23 |
| 96 | 307 South Carolina Ave SE | 04-Apr-23 |
| 97 | 3107 Cathedral Ave NW | 04-Apr-23 |
| 98 | 3112 PARK PL NW | 04-Apr-23 |
| 99 | 318 14TH PL NE | 04-Apr-23 |
| 100 | 3206 5th St SE | 04-Apr-23 |
| 101 | 3608 17th St NE | 04-Apr-23 |
| 102 | 3617 17th St NE | 04-Apr-23 |
| 103 | 3721 PORTER ST NW | 04-Apr-23 |
| 104 | 419 12th St SE | 04-Apr-23 |
| 105 | 4221 4th St NW | 04-Apr-23 |
| 106 | 4312 14th St NW | 04-Apr-23 |
| 107 | 4428 9th St NW | 04-Apr-23 |
| 108 | 4507 Arkansas Ave NW | 04-Apr-23 |
| 109 | 5010 Klingle St NW | 04-Apr-23 |
| 110 | 519 Rittenhouse St NW | 04-Apr-23 |
| 111 | 521 5th St NE | 04-Apr-23 |
| 112 | 521 9th St SE | 04-Apr-23 |
| 113 | 5242 Colorado Ave NW | 04-Apr-23 |
| 114 | 5309 14th St NW | 04-Apr-23 |
| 115 | 615 Webster St NW | 04-Apr-23 |
| 116 | 617 FERN PL NW | 04-Apr-23 |
| 117 | 6811 Laurel St NW | 04-Apr-23 |
| 118 | 7516 14th St NW | 04-Apr-23 |
| 119 | 813 E St SE | 04-Apr-23 |
| 120 | 827 9th St NE | 04-Apr-23 |
| 121 | 4507 13TH ST NW | 05-Apr-23 |
| 122 | 540 5th St SE | 05-Apr-23 |

| No. | Address | Sample Kit Distribution Date |
|-----|---------------------------|------------------------------|
| 123 | 1415 F St NE | 12-Apr-23 |
| 124 | 2010 Klingle Rd NW | 13-Apr-23 |
| 125 | 3741 McKinley St NW | 13-Apr-23 |
| 126 | 6125 29th St NW | 25-Apr-23 |
| 127 | 4610 Iowa Ave NW | 01-May-23 |
| 128 | 105 14th St NE | 02-May-23 |
| 129 | 1148 Abbey Pl NE | 02-May-23 |
| 130 | 1225 C St SE | 02-May-23 |
| 131 | 1416 Montague St NW | 02-May-23 |
| 132 | 1721 Webster St NW | 02-May-23 |
| 133 | 22 Bates St NW | 02-May-23 |
| 134 | 232 33rd St NE | 02-May-23 |
| 135 | 2416 I St NW | 02-May-23 |
| 136 | 3511 IDAHO AVE NW | 02-May-23 |
| 137 | 424 Farragut St NW | 02-May-23 |
| 138 | 4310 Chesapeake St NW | 02-May-23 |
| 139 | 48 Channing St NW | 02-May-23 |
| 140 | 517 5th St NE | 02-May-23 |
| 141 | 5603 14th St NW | 02-May-23 |
| 142 | 811 L St NE | 02-May-23 |
| 143 | 904 Delafield Pl NW | 02-May-23 |
| 144 | 1534 East Capitol St NE | 03-May-23 |
| 145 | 105 14th St NE | 10-May-23 |
| 146 | 114 3rd St SE | 15-May-23 |
| 147 | 1372 C St NE | 15-May-23 |
| 148 | 1413 West Virginia Ave NE | 22-May-23 |
| 149 | 1501 Harvard St NW | 24-May-23 |
| 150 | 812 Van Buren ST NW | 01-Jun-23 |
| 151 | 313 10TH ST SE | 12-Jun-23 |
| 152 | 1328 TRINIDAD AVE NE | 13-Jun-23 |
| 153 | 1423 TRINIDAD AVE NE | 13-Jun-23 |
| 154 | 1441 Ives PI SE | 13-Jun-23 |
| 155 | 3050 MONROE ST NE | 13-Jun-23 |
| 156 | 1418 TRINIDAD AVE NE | 14-Jun-23 |
| 157 | 1421 TRINIDAD AVE NE | 14-Jun-23 |
| 158 | 1427 Ives PI SE | 14-Jun-23 |
| 159 | 250 33RD ST NE | 14-Jun-23 |
| 160 | 1409 TRINIDAD AVE NE | 15-Jun-23 |
| 161 | 3004 25th St NE | 16-Jun-23 |

| No | Address | Sample Kit Distribution Date | |
|----|-------------------------------|------------------------------|--|
| 1 | 1706 NEW JERSEY AVE NW | 30-Jan-23 | |
| 2 | 1808 KEARNY ST NE | 30-Jan-23 | |
| 3 | 2036 17TH ST NW | 30-Jan-23 | |
| 4 | 231 K St NE | 30-Jan-23 | |
| 5 | 313 10TH ST SE | 30-Jan-23 | |
| 6 | 3211 Central Ave NE | 30-Jan-23 | |
| 7 | 3301 BROWN St NW | 30-Jan-23 | |
| 8 | 5404 39TH ST NW | 30-Jan-23 | |
| 9 | 619 12th St NE | 30-Jan-23 | |
| 10 | 2414 Observatory PI NW | 28-Feb-23 | |
| 11 | 317 TENNESSEE AVE NE | 28-Feb-23 | |
| 12 | 3743 W ST NW | 28-Feb-23 | |
| 13 | 4536 Lowell St NW | 28-Feb-23 | |
| 14 | 5019 16TH ST NW | 28-Feb-23 | |
| 15 | 511 Tennessee Ave NE | 28-Feb-23 | |
| 16 | 523 12th ST NE | E 28-Feb-23 | |
| 17 | 1721 Webster St NW | 10-Mar-23 | |
| 18 | 120 Kentucky Ave SE 04-Apr | | |
| 19 | 1417 Crittenden St NW 04-Apr- | | |
| 20 | 1620 Underwood St NW | 04-Apr-23 | |
| 21 | 2326 20th St NW | 04-Apr-23 | |
| 22 | 3721 PORTER ST NW | 04-Apr-23 | |
| 23 | 615 Webster St NW | 04-Apr-23 | |
| 24 | 617 FERN PL NW | 04-Apr-23 | |
| 25 | 6811 Laurel St NW | 04-Apr-23 | |
| 26 | 7516 14th St NW | 04-Apr-23 | |
| 27 | 2416 I St NW | 02-May-23 | |
| 28 | 424 Farragut St NW | 02-May-23 | |
| 29 | 1423 TRINIDAD AVE NE | 13-Jun-23 | |
| 30 | 3050 MONROE ST NE | 13-Jun-23 | |
| 31 | 1421 TRINIDAD AVE NE | 14-Jun-23 | |
| 32 | 250 33RD ST NE | 14-Jun-23 | |
| 33 | 1409 TRINIDAD AVE NE | 15-Jun-23 | |

Table C.2 Sample Kits Not Returned

Table C.3 Samples Returned but Rejected and Samples Invalidated for Compliance Analysis

| No | Address | Sample Kit Distribution Date | Reject Reason | |
|----|---------------------|---------------------------------|---|--|
| 1 | 10 S St NW | 30-Jan-23 | Icemaker could have used water during stagnation period | |
| 2 | 105 14th St NE | 02-May-23 | Icemaker could have used water during stagnation period | |
| 3 | 114 3rd St SE | 15-Mar-23 | Incomplete sample form | |
| 4 | 1310 Locust Rd NW | 04-Apr-23 | Full lead service line replacement | |
| 5 | 132 11th St SE | 28-Feb-23 | Icemaker could have used water during stagnation period; Samples invalidated (see Appendix E) | |
| 6 | 15 14th St SE | 28-Feb-23 | Test-pits revealed all copper pipe prior to sample collection; removed from Sample Pool | |
| 7 | 1505 Buchanan St NW | 30-Jan-23 | Icemaker could have used water during stagnation period | |
| 8 | 1627 Newton St NW | 04-Apr-23 | Customer reported the home is multi-family; removed from Sample Pool | |
| 9 | 1649 HARVARD ST NW | 30-Jan-23 | Stagnation period was less than 6 hours | |
| 10 | 1721 Webster St NW | 03-Jan-23 | Samples exceeded 14 day holding time | |
| 11 | 1826 Jackson St NE | 30-Jan-23 | Samples exceeded 14 day holding time | |
| 12 | 2007 37TH ST NW | 30-Jan-23 | Samples exceeded 14 day holding time | |
| 13 | 2010 Klingle Rd NW | 04-Apr-23 | Stagnation period was less than 6 hours | |
| 14 | 2717 11th St NW | 28-Feb-23 | Incomplete sample form | |
| 15 | 305 7th St NE | 28-Feb-23 | Incomplete sample form | |
| 16 | 3114 15th St NE | 28-Feb-23 | Icemaker could have used water during stagnation period; Samples invalidated (see Appendix E) | |
| 17 | 338 14th St SE | 28-Feb-23 | 1st draw bottle was leaking | |
| 18 | 4233 JENIFER ST NW | 28-Feb-23 | Test-pits revealed brass pipe prior to sample collection; Samples invalidated (see Appendix E) | |
| 19 | 4316 15th St NW | 24-Jan-23 | Stagnation period was less than 6 hours | |
| 20 | 4418 14th St NE | 30-Jan-23 | Stagnation period was less than 6 hours | |
| 21 | 521 5th St NE | 04-Apr-23 | Icemaker could have used water during stagnation period | |
| 22 | 813 E St SE | 04-Apr-23 | Incomplete sample form | |

Table C.4 Deviations from Sample Order

| No | Address | Deviation | |
|----|---------------------------|--|--|
| 1 | 1413 West Virginia Ave NE | Not available scheduled month; requested later date | |
| 2 | 1416 Montague St NW | Not available scheduled month; requested later date | |
| 3 | 3030 44TH ST NW | Not available scheduled month; requested later date | |
| 4 | 307 South Carolina Ave SE | Not available scheduled month; requested later date | |
| 5 | 311 Varnum St NW | Service line replacement prior to scheduled drop date | |
| 6 | 3126 38th St NW | House under renovation and vacant | |
| 7 | 3724 CHESAPEAKE ST NW | Not available scheduled month; requested next semester | |
| 8 | 4710 8th St NW | Not available scheduled month; requested next semester | |
| 9 | 5700 SHERIER PL NW | Not available scheduled month; requested next semester | |
| 10 | 6611 1st St NW | Service line replacement prior to scheduled drop date | |
| 11 | 744 9TH ST SE | Customer does not want to participate in program; removed from Sample Pool | |
| 12 | 912 15TH ST SE | Service line replacement prior to scheduled drop date | |
| 13 | 114 3rd St SE | New participant ¹ | |
| 14 | 1306 Girard St NE | New participant ¹ | |
| 15 | 1328 TRINIDAD AVE NE | New participant ² | |
| 16 | 1372 C St NE | New participant ¹ | |
| 17 | 1409 TRINIDAD AVE NE | New participant ² | |
| 18 | 1415 F St NE | New participant ¹ | |
| 19 | 1418 TRINIDAD AVE NE | New participant ² | |
| 20 | 1421 TAYLOR ST NW | New participant ¹ | |
| 21 | 1421 TRINIDAD AVE NE | New participant ² | |
| 22 | 1423 TRINIDAD AVE NE | New participant ² | |
| 23 | 1427 Ives PI SE | New participant ² | |
| 24 | 1441 Ives PI SE | New participant ² | |
| 25 | 1501 Harvard St NW | New participant ¹ | |
| 26 | 1534 East Capitol St NE | New participant ¹ | |
| 27 | 2301 Naylor Rd SE | New participant ¹ | |
| 28 | 250 33RD ST NE | New participant ¹ | |
| 29 | 2718 Hamlin St NE | New participant ¹ | |
| 30 | 3004 25th St NE | New participant ¹ | |
| 31 | 3050 MONROE ST NE | New participant ² | |
| 32 | 3248 Q St NW | New participant ¹ | |
| 33 | 3548 11th St NW | New participant ¹ | |
| 34 | 3741 McKinley St NW | New participant ¹ | |
| 35 | 4310 Chesapeake St NW | New participant ¹ | |
| 36 | 4316 15th St NW | New participant ¹ | |
| 37 | 4414 5th St NW | New participant ¹ | |

21

| No | Address | Deviation |
|----|---------------------|------------------------------|
| 38 | 4507 13TH ST NW | New participant ¹ |
| 39 | 4610 Iowa Ave NW | New participant ¹ |
| 40 | 540 5th St SE | New participant ¹ |
| 41 | 5510 9th St NW | New participant ¹ |
| 42 | 6125 29th St NW | New participant ¹ |
| 43 | 812 Van Buren ST NW | New participant ¹ |

Notes:

- 1) New participant¹: Customer contacted DC Water to request a lead test and agreed to participate in the Lead and Copper Monitoring Program. DC Water confirmed that the address met Tier 1 criteria under 40 CFR § 141.86(a)(3) as a single-family structure that is served by a full lead service line based on DC Water's customer information and service line inventory records.
- 2) New participant²: DC Water solicitated this customer to participate in the Lead and Copper Monitoring Program because we did not have enough samples from the sampling site in the established LCR Sample Pool. We selected blocks in the Southeast and Northeast areas to gain more geographic and equitable distribution and within the upcoming Lead Free DC By-block program that signed a lead service line replacement Agreement to remove the lead service line on their private property. DC Water confirmed that the address met Tier 1 criteria under 40 CFR § 141.86(a)(3) as a single-family structure that is served by a full lead service line based on DC Water's customer information and service line inventory records.

Table C.5 Sites with Compliance Results from January 2022 through December 2022 and
No Results in January through June 2023

| No. | Address | Reason | |
|-----|------------------------|--|--|
| 1 | 10 S St NW | Samples rejected; see Table C.3 | |
| 2 | 104 7th ST NE | Removed prior to this semester | |
| 3 | 1049 Quebec Pl NW | Removed prior to this semester | |
| 4 | 1123 Michigan Ave NE | Lead service line replacement prior to scheduled sampling; see Table C.4 | |
| 5 | 114 4th St NE | Removed prior to this semester | |
| 6 | 120 Kentucky Ave SE | Samples not returned; see Table C.2 | |
| 7 | 1310 Locust Rd NW | Samples rejected; see Table C.3 | |
| 8 | 132 11th St SE | Invalidated samples; see Table C.3 | |
| 9 | 1402 MORSE ST NE | Removed prior to this semester | |
| 10 | 1417 Crittenden St NW | Samples not returned; see Table C.2 | |
| 11 | 1421 TAYLOR ST NW | Inadvertently left out of Sample Pool for this semester; added to July-Dec Sample Pool; see Table D.1 | |
| 12 | 15 14th St SE | Samples rejected; see Table C.3 | |
| 13 | 1505 Buchanan St NW | Samples rejected; see Table C.3 | |
| 14 | 1528 Upshur St NW | Removed prior to this semester | |
| 15 | 1627 Newton St NW | Samples rejected; see Table C.3 | |
| 16 | 1630 NEW JERSEY AVE NW | Removed prior to this semester | |
| 17 | 1649 HARVARD ST NW | Samples rejected; see Table C.3 | |
| 18 | 1808 KEARNY ST NE | Samples not returned; see Table C.2 | |
| 19 | 1826 Jackson St NE | Samples rejected; see Table C.3 | |
| 20 | 2007 37TH ST NW | Samples rejected; see Table C.3 | |
| 21 | 2036 17TH ST NW | Samples not returned; see Table C.2 | |
| 22 | 231 K St NE | Samples not returned; see Table C.2 | |
| 23 | 2414 Observatory Pl NW | Samples not returned; see Table C.2 | |
| 24 | 2416 I St NW | Samples not returned; see Table C.2 | |
| 25 | 2435 33RD ST SE | Removed prior to this semester | |
| 26 | 2717 11th St NW | Samples rejected; see Table C.3 | |
| 27 | 2913 Brandywine St NW | Removed prior to this semester | |
| 28 | 3004 Alabama Ave SE | Removed prior to this semester | |
| 29 | 305 7th St NE | Samples rejected; see Table C.3 | |
| 30 | 311 Varnum St NW | Lead service line replacement prior to scheduled sampling; see Table C.4 | |
| 31 | 3114 15th St NE | Invalidated samples; see Table C.3 | |
| 32 | 3126 38th St NW | House under renovation and vacant; see Table C.4 | |
| 33 | 317 TENNESSEE AVE NE | Samples not returned; see Table C.2 | |
| 34 | 3211 Central Ave NE | Samples not returned; see Table C.2 | |
| 35 | 338 14th St SE | Samples rejected; see Table C.3 | |
| 36 | 3416 9th St NE | Removed prior to this semester | |
| 37 | 3724 CHESAPEAKE ST NW | Not available; see Table C.4 | |
| 38 | 3854 Beecher St NW | Removed prior to this semester | |

| No. | Address | Reason | |
|-----|-----------------------|--|--|
| 39 | 3916 KANSAS AVE NW | Removed prior to this semester | |
| 40 | 4118 Emery Pl NW | Removed prior to this semester | |
| 41 | 412 BRANDYWINE ST SE | Removed prior to this semester | |
| 42 | 4233 JENIFER ST NW | Invalidated samples; see Table C.3 | |
| 43 | 424 Farragut St NW | Samples not returned; see Table C.2 | |
| 44 | 4536 Lowell St NW | Samples not returned; see Table C.2 | |
| 45 | 4710 8th St NW | Not available; see Table C.4 | |
| 46 | 5121 Cathedral Ave NW | Removed prior to this semester | |
| 47 | 513 Montana Ave NE | Removed prior to this semester | |
| 48 | 521 5th St NE | Samples rejected; see Table C.3 | |
| 49 | 523 12th ST NE | Samples not returned; see Table C.2 | |
| 50 | 5404 39TH ST NW | Samples not returned; see Table C.2 | |
| 51 | 5700 SHERIER PL NW | Not available; see Table C.4 | |
| 52 | 5710 13th St NW | Removed prior to this semester | |
| 53 | 607 Lamont St NW | Removed prior to this semester | |
| 54 | 619 12th St NE | Samples not returned; see Table C.2 | |
| 55 | 633 Columbia Rd NW | Removed prior to this semester | |
| 56 | 6611 1st St NW | Lead service line replacement prior to scheduled sampling; see Table C.4 | |
| 57 | 6811 Laurel St NW | Samples not returned; see Table C.2 | |
| 58 | 744 9TH ST SE | No longer participating; see Table C.4 | |
| 59 | 804 Delafield Pl NW | Removed prior to this semester | |
| 60 | 813 E St SE | Samples rejected; see Table C.3 | |
| 61 | 904 Crittenden St NW | Removed prior to this semester | |
| 62 | 912 15TH ST SE | Lead service line replacement prior to scheduled sampling; see Table C.4 | |
| 63 | 915 9th St NE | Removed prior to this semester | |

| No | Address | Date received from Laboratory | Date Letter Sent to Customer |
|----|--------------------------|-------------------------------|------------------------------|
| 1 | 1020 INDEPENDENCE AVE SE | 3/9/2023 | 3/10/2023 |
| 2 | 1211 Carrollsburg Pl SW | 3/9/2023 | 3/10/2023 |
| 3 | 1346 F St NE | 3/9/2023 | 3/10/2023 |
| 4 | 1353 JEFFERSON ST NW | 3/9/2023 | 3/10/2023 |
| 5 | 1420 INGRAHAM ST NW | 3/9/2023 | 3/10/2023 |
| 6 | 15 Milmarson Pl NW | 3/9/2023 | 3/10/2023 |
| 7 | 1519 Olive St NE | 3/9/2023 | 3/10/2023 |
| 8 | 1620 Webster St NW | 3/9/2023 | 3/10/2023 |
| 9 | 1635 WEBSTER ST NW | 3/9/2023 | 3/10/2023 |
| 10 | 228 V ST NE | 3/9/2023 | 3/10/2023 |
| 11 | 2923 Cathedral AVE NW | 3/9/2023 | 3/10/2023 |
| 12 | 3036 P St NW | 3/9/2023 | 3/10/2023 |
| 13 | 3206 38th St NW | 3/9/2023 | 3/10/2023 |
| 14 | 36 Florida Ave NW | 3/9/2023 | 3/10/2023 |
| 15 | 3727 T St NW | 3/9/2023 | 3/10/2023 |
| 16 | 4215 39th St NW | 3/9/2023 | 3/10/2023 |
| 17 | 4418 14th St NE | 3/9/2023 | 3/10/2023 |
| 18 | 4425 14th St NE | 3/9/2023 | 3/10/2023 |
| 19 | 4926 Glenbrook Rd NW | 3/9/2023 | 3/10/2023 |
| 20 | 5223 KANSAS AVE NW | 3/9/2023 | 3/10/2023 |
| 21 | 702 9th St SE | 3/9/2023 | 3/10/2023 |
| 22 | 728 FARRAGUT ST NW | 3/9/2023 | 3/10/2023 |
| 23 | 905 Kent Pl NE | 3/9/2023 | 3/10/2023 |
| 24 | 1115 C St NE | 3/21/2023 | 3/21/2023 |
| 25 | 114 MADISON ST NW | 3/21/2023 | 3/21/2023 |
| 26 | 1247 GIRARD ST NE | 3/21/2023 | 3/21/2023 |
| 27 | 132 11th St SE | 3/21/2023 | 3/21/2023 |
| 28 | 1332 Ritchie Pl NE | 3/21/2023 | 3/21/2023 |
| 29 | 1354 D St SE | 3/21/2023 | 3/21/2023 |
| 30 | 1408 DECATUR ST NW | 3/21/2023 | 3/21/2023 |
| 31 | 1648 ARGONNE PL NW | 3/21/2023 | 3/21/2023 |
| 32 | 3030 44TH ST NW | 3/21/2023 | 3/21/2023 |
| 33 | 3074 Clinton St NE | 3/21/2023 | 3/21/2023 |
| 34 | 3114 15th St NE | 3/21/2023 | 3/21/2023 |
| 35 | 3248 Q St NW | 3/21/2023 | 3/21/2023 |
| 36 | 3420 34th St NW | 3/21/2023 | 3/21/2023 |
| 37 | 3567 Holmead Pl NW | 3/21/2023 | 3/21/2023 |
| 38 | 3629 Everett St NW | 3/21/2023 | 3/21/2023 |
| 39 | 3822 Albemarle St NW | 3/21/2023 | 3/21/2023 |
| 40 | 408 16th St SE | 3/21/2023 | 3/21/2023 |

Table C.6 Customer Notification of Results

| No | Address | Date received from Laboratory | Date Letter Sent to Customer |
|----|---------------------------|-------------------------------|------------------------------|
| 41 | 414 DOUGLAS ST NE | 3/21/2023 | 3/21/2023 |
| 42 | 423 GALLATIN ST NW | 3/21/2023 | 3/21/2023 |
| 43 | 423 Shepherd St NW | 3/21/2023 | 3/21/2023 |
| 44 | 4233 JENIFER ST NW | 3/21/2023 | 3/21/2023 |
| 45 | 5427 Nevada Ave NW | 3/21/2023 | 3/21/2023 |
| 46 | 5520 CAROLINA PL NW | 3/21/2023 | 3/21/2023 |
| 47 | 559 23rd PL NE | 3/21/2023 | 3/21/2023 |
| 48 | 5600 NEBRASKA AVE NW | 3/21/2023 | 3/21/2023 |
| 49 | 2717 O ST NW | 3/31/2023 | 4/1/2023 |
| 50 | 4316 15th St NW | 3/31/2023 | 4/1/2023 |
| 51 | 525 9TH ST SE | 3/31/2023 | 4/1/2023 |
| 52 | 1120 C St NE | 5/10/2023 | 5/10/2023 |
| 53 | 1254 Hamlin St NE | 5/10/2023 | 5/10/2023 |
| 54 | 1306 Girard St NE | 5/10/2023 | 5/10/2023 |
| 55 | 1411 Delafield Pl NW | 5/10/2023 | 5/10/2023 |
| 56 | 1415 F St NE | 5/10/2023 | 5/10/2023 |
| 57 | 1621 C St SE | 5/10/2023 | 5/10/2023 |
| 58 | 18 Milmarson Pl NW | 5/10/2023 | 5/10/2023 |
| 59 | 2010 Klingle Rd NW | 5/10/2023 | 5/10/2023 |
| 60 | 307 South Carolina Ave SE | 5/10/2023 | 5/10/2023 |
| 61 | 3107 Cathedral Ave NW | 5/10/2023 | 5/10/2023 |
| 62 | 3112 PARK PL NW | 5/10/2023 | 5/10/2023 |
| 63 | 318 14TH PL NE | 5/10/2023 | 5/10/2023 |
| 64 | 3206 5th St SE | 5/10/2023 | 5/10/2023 |
| 65 | 419 12th St SE | 5/10/2023 | 5/10/2023 |
| 66 | 4312 14th St NW | 5/10/2023 | 5/10/2023 |
| 67 | 4428 9th St NW | 5/10/2023 | 5/10/2023 |
| 68 | 4507 13TH ST NW | 5/10/2023 | 5/10/2023 |
| 69 | 4507 Arkansas Ave NW | 5/10/2023 | 5/10/2023 |
| 70 | 5010 Klingle St NW | 5/10/2023 | 5/10/2023 |
| 71 | 519 Rittenhouse St NW | 5/10/2023 | 5/10/2023 |
| 72 | 5242 Colorado Ave NW | 5/10/2023 | 5/10/2023 |
| 73 | 5309 14th St NW | 5/10/2023 | 5/10/2023 |
| 74 | 827 9th St NE | 5/10/2023 | 5/10/2023 |
| 75 | 1148 Abbey Pl NE | 6/20/2023 | 6/20/2023 |
| 76 | 1225 C St SE | 6/20/2023 | 6/20/2023 |
| 77 | 1416 Montague St NW | 6/20/2023 | 6/20/2023 |
| 78 | 1534 East Capitol St NE | 6/20/2023 | 6/20/2023 |
| 79 | 1721 Webster St NW | 6/20/2023 | 6/20/2023 |
| 80 | 22 Bates St NW | 6/20/2023 | 6/20/2023 |
| 81 | 3511 IDAHO AVE NW | 6/20/2023 | 6/20/2023 |
| 82 | 3617 17th St NE | 6/20/2023 | 6/20/2023 |

| No | Address | Date received from Laboratory | Date Letter Sent to Customer |
|-----|---------------------------|-------------------------------|------------------------------|
| 83 | 4610 Iowa Ave NW | 6/20/2023 | 6/20/2023 |
| 84 | 48 Channing St NW | 6/20/2023 | 6/20/2023 |
| 85 | 517 5th St NE | 6/20/2023 | 6/20/2023 |
| 86 | 540 5th St SE | 6/20/2023 | 6/20/2023 |
| 87 | 5603 14th St NW | 6/20/2023 | 6/20/2023 |
| 88 | 6125 29th St NW | 6/20/2023 | 6/20/2023 |
| 89 | 904 Delafield PI NW | 6/20/2023 | 6/20/2023 |
| 90 | 105 14th St NE | 7/3/2023 | 7/3/2023 |
| 91 | 114 3rd St SE | 7/3/2023 | 7/3/2023 |
| 92 | 1328 TRINIDAD AVE NE | 7/3/2023 | 7/3/2023 |
| 93 | 1372 C St NE | 7/3/2023 | 7/3/2023 |
| 94 | 1413 West Virginia Ave NE | 7/3/2023 | 7/3/2023 |
| 95 | 1418 TRINIDAD AVE NE | 7/3/2023 | 7/3/2023 |
| 96 | 1427 Ives PI SE | 7/3/2023 | 7/3/2023 |
| 97 | 1441 Ives PI SE | 7/3/2023 | 7/3/2023 |
| 98 | 1501 Harvard St NW | 7/3/2023 | 7/3/2023 |
| 99 | 219 Underwood St NW | 7/3/2023 | 7/3/2023 |
| 100 | 232 33rd St NE | 7/3/2023 | 7/3/2023 |
| 101 | 3004 25th St NE | 7/3/2023 | 7/3/2023 |
| 102 | 313 10TH ST SE | 7/3/2023 | 7/3/2023 |
| 103 | 3608 17th St NE | 7/3/2023 | 7/3/2023 |
| 104 | 3741 McKinley St NW | 7/3/2023 | 7/3/2023 |
| 105 | 4221 4th St NW | 7/3/2023 | 7/3/2023 |
| 106 | 4310 Chesapeake St NW | 7/3/2023 | 7/3/2023 |
| 107 | 521 9th St SE | 7/3/2023 | 7/3/2023 |
| 108 | 811 L St NE | 7/3/2023 | 7/3/2023 |
| 109 | 812 Van Buren ST NW | 7/3/2023 | 7/3/2023 |

Appendix D – Sample Pool

| No | Address | Pipe Material |
|----|---------------------------|---------------|
| 1 | 1247 GIRARD ST NE | Lead |
| 2 | 419 12th St SE | Lead |
| 3 | 4312 14th St NW | Lead |
| 4 | 521 5th St NE | Lead |
| 5 | 615 Webster St NW | Lead |
| 6 | 3617 17th St NE | Lead |
| 7 | 1417 Crittenden St NW | Lead |
| 8 | 5242 Colorado Ave NW | Lead |
| 9 | 3822 Albemarle St NW | Lead |
| 10 | 3420 34th St NW | Lead |
| 11 | 559 23rd PL NE | Lead |
| 12 | 3629 Everett St NW | Lead |
| 13 | 132 11th St SE | Lead |
| 14 | 6811 Laurel St NW | Lead |
| 15 | 2718 Hamlin St NE | Lead |
| 16 | 3206 5th St SE | Lead |
| 17 | 6125 29th St NW | Lead |
| 18 | 2301 Naylor Rd SE | Lead |
| 19 | 3741 McKinley St NW | Lead |
| 20 | 3074 Clinton St NE | Lead |
| 21 | 338 14th St SE | Lead |
| 22 | 1648 ARGONNE PL NW | Lead |
| 23 | 2717 O ST NW | Lead |
| 24 | 4536 Lowell St NW | Lead |
| 25 | 1115 C St NE | Lead |
| 26 | 408 16th St SE | Lead |
| 27 | 3567 Holmead Pl NW | Lead |
| 28 | 305 7th St NE | Lead |
| 29 | 307 South Carolina Ave SE | Lead |
| 30 | 3511 IDAHO AVE NW | Lead |
| 31 | 4428 9th St NW | Lead |
| 32 | 1254 Hamlin St NE | Lead |
| 33 | 1416 Montague St NW | Lead |
| 34 | 4221 4th St NW | Lead |
| 35 | 4507 Arkansas Ave NW | Lead |
| 36 | 521 9th St SE | Lead |
| 37 | 3107 Cathedral Ave NW | Lead |
| 38 | 5309 14th St NW | Lead |

Table D.1 Sample Pool for July – December 2023 Compliance Period

| No | Address | Pipe Material |
|----|---------------------------|---------------|
| 39 | 1621 C St SE | Lead |
| 40 | 3608 17th St NE | Lead |
| 41 | 1225 C St SE | Lead |
| 42 | 811 L St NE | Lead |
| 43 | 2010 Klingle Rd NW | Lead |
| 44 | 1148 Abbey PI NE | Lead |
| 45 | 827 9th St NE | Lead |
| 46 | 4710 8th St NW | Lead |
| 47 | 232 33rd St NE | Lead |
| 48 | 2416 I St NW | Lead |
| 49 | 5603 14th St NW | Lead |
| 50 | 1413 West Virginia Ave NE | Lead |
| 51 | 424 Farragut St NW | Lead |
| 52 | 105 14th St NE | Lead |
| 53 | 22 Bates St NW | Lead |
| 54 | 904 Delafield Pl NW | Lead |
| 55 | 3126 38th St NW | Lead |
| 56 | 517 5th St NE | Lead |
| 57 | 813 E St SE | Lead |
| 58 | 1408 DECATUR ST NW | Lead |
| 59 | 48 Channing St NW | Lead |
| 60 | 1505 Buchanan St NW | Lead |
| 61 | 525 9TH ST SE | Lead |
| 62 | 3050 MONROE ST NE | Lead |
| 63 | 1441 Ives PI SE | Lead |
| 64 | 619 12th St NE | Lead |
| 65 | 4418 14th St NE | Lead |
| 66 | 3211 Central Ave NE | Lead |
| 67 | 905 Kent Pl NE | Lead |
| 68 | 1427 Ives PI SE | Lead |
| 69 | 10 S St NW | Lead |
| 70 | 3727 T St NW | Lead |
| 71 | 812 Van Buren ST NW | Lead |
| 72 | 1418 TRINIDAD AVE NE | Lead |
| 73 | 250 33RD ST NE | Lead |
| 74 | 1328 TRINIDAD AVE NE | Lead |
| 75 | 1421 TRINIDAD AVE NE | Lead |
| 76 | 1346 F St NE | Lead |
| 77 | 3004 25th St NE | Lead |
| 78 | 1501 Harvard St NW | Lead |
| 79 | 1372 C St NE | Lead |
| 80 | 1020 INDEPENDENCE AVE SE | Lead |

29

| No | Address | Pipe Material |
|-----|-------------------------|---------------|
| 81 | 4610 Iowa Ave NW | Lead |
| 82 | 4425 14th St NE | Lead |
| 83 | 2036 17TH ST NW | Lead |
| 84 | 1534 East Capitol St NE | Lead |
| 85 | 1721 Webster St NW | Lead |
| 86 | 114 3rd St SE | Lead |
| 87 | 540 5th St SE | Lead |
| 88 | 1415 F St NE | Lead |
| 89 | 1519 Olive St NE | Lead |
| 90 | 5010 Klingle St NW | Lead |
| 91 | 3743 W ST NW | Lead |
| 92 | 423 Shepherd St NW | Lead |
| 93 | 2414 Observatory PI NW | Lead |
| 94 | 317 TENNESSEE AVE NE | Lead |
| 95 | 114 MADISON ST NW | Lead |
| 96 | 219 Underwood St NW | Lead |
| 97 | 5510 9th St NW | Lead |
| 98 | 3114 15th St NE | Lead |
| 99 | 3112 PARK PL NW | Lead |
| 100 | 3721 PORTER ST NW | Lead |
| 101 | 1120 C St NE | Lead |
| 102 | 18 Milmarson Pl NW | Lead |
| 103 | 702 9th St SE | Lead |
| 104 | 519 Rittenhouse St NW | Lead |
| 105 | 5427 Nevada Ave NW | Lead |
| 106 | 4507 13TH ST NW | Lead |
| 107 | 1649 HARVARD ST NW | Lead |
| 108 | 3548 11th St NW | Lead |
| 109 | 4414 5th ST NW | Lead |
| 110 | 5600 NEBRASKA AVE NW | Lead |
| 111 | 423 GALLATIN ST NW | Lead |
| 112 | 1421 TAYLOR ST NW | Lead |
| 113 | 4310 Chesapeake St NW | Lead |
| 114 | 1423 TRINIDAD AVE NE | Lead |
| 115 | 228 V ST NE | Lead |
| 116 | 2007 37TH ST NW | Lead |
| 117 | 1409 TRINIDAD AVE NE | Lead |
| 118 | 3206 38th St NW | Lead |
| 119 | 120 Kentucky Ave SE | Lead |
| 120 | 4926 Glenbrook Rd NW | Partial Lead |
| 121 | 414 DOUGLAS ST NE | Partial Lead |
| 122 | 5223 KANSAS AVE NW | Partial Lead |

| No | Address | Pipe Material |
|-----|-------------------------|---------------|
| 123 | 1420 INGRAHAM ST NW | Partial Lead |
| 124 | 313 10TH ST SE | Partial Lead |
| 125 | 3724 CHESAPEAKE ST NW | Partial Lead |
| 126 | 36 Florida Ave NW | Partial Lead |
| 127 | 2923 Cathedral AVE NW | Partial Lead |
| 128 | 15 Milmarson Pl NW | Partial Lead |
| 129 | 3036 P St NW | Partial Lead |
| 130 | 1354 D St SE | Partial Lead |
| 131 | 1211 Carrollsburg Pl SW | Partial Lead |
| 132 | 1332 Ritchie Pl NE | Partial Lead |
| 133 | 4215 39th St NW | Partial Lead |
| 134 | 1353 JEFFERSON ST NW | Partial Lead |
| 135 | 1808 KEARNY ST NE | Partial Lead |
| 136 | 3301 BROWN St NW | Partial Lead |
| 137 | 3030 44TH ST NW | Partial Lead |
| 138 | 5404 39TH ST NW | Partial Lead |
| 139 | 5700 SHERIER PL NW | Partial Lead |
| 140 | 2717 11th St NW | Partial Lead |
| 141 | 523 12th ST NE | Partial Lead |
| 142 | 231 K St NE | Partial Lead |

Table D.2 Sample Pool Site Changes

| No | Address | Change | Reason for Removal |
|----|------------------------|---------------------------------|--|
| 1 | 1123 Michigan Ave NE | Removed | Lead service line replacement on 1/13/2023 |
| 2 | 1310 Locust Rd NW | Removed | Lead service line replacement on 2/21/2023 |
| 3 | 1411 Delafield Pl NW | Removed | Lead service line replacement on 5/31/2023 |
| 4 | 15 14th St SE | Removed | No lead pipe found; excavation on 2/23/2023 revealed copper pipe |
| 5 | 1620 Underwood St NW | Removed | Did not return samples in last four sampling events |
| 6 | 1620 Webster St NW | Removed | Lead service line replacement on 5/18/2023 |
| 7 | 1627 Newton St NW | Removed | Multi-family residence |
| 8 | 1635 WEBSTER ST NW | Removed | Lead service line replacement on 5/22/2023 |
| 9 | 1706 NEW JERSEY AVE NW | Removed | Lead service line replacement on 1/11/2023 |
| 10 | 1826 Jackson St NE | Removed | Lead service line replacement on 5/12/2023 |
| 11 | 2326 20th St NW | Removed | Customer does not want to participate |
| 12 | 311 Varnum St NW | Removed | Lead service line replacement on 11/19/2022 |
| 13 | 318 14TH PL NE | Removed | Lead service line replacement on 4/14/2023 |
| 14 | 3248 Q St NW | Removed | Lead service line replacement on 4/25/2023 |
| 15 | 4233 JENIFER ST NW | Removed | No lead pipe found; excavation on 11/8/2022 revealed brass pipe |
| 16 | 4316 15th St NW | Removed | Lead service line replacement on 4/18/2023 |
| 17 | 5019 16TH ST NW | Removed | Did not return samples in last four sampling events |
| 18 | 511 Tennessee Ave NE | Removed | Did not return samples in last four sampling events |
| 19 | 5520 CAROLINA PL NW | Removed | Lead service line replacement on 5/15/2023 |
| 20 | 617 FERN PL NW | Removed | Did not return samples in last four sampling events |
| 21 | 6611 1st St NW | Removed | Lead service line replacement on 1/13/2023 |
| 22 | 728 FARRAGUT ST NW | Removed | No lead pipe found; excavation on 5/23/2023 revealed copper pipe |
| 23 | 744 9TH ST SE | Removed | Customer does not want to participate |
| 24 | 7516 14th St NW | Removed | Did not return samples in last four sampling events |
| 25 | 912 15TH ST SE | Removed | Lead service line replacement on 12/19/2022 |
| 26 | 1306 Girard St NE | Added this semester and removed | Lead service line replacement on 4/11/2023 |
| 27 | 114 3rd St SE | Added this semester | |
| 28 | 1328 TRINIDAD AVE NE | Added this semester | |
| 29 | 1372 C St NE | Added this semester | |
| 30 | 1409 TRINIDAD AVE NE | Added this semester | |
| 31 | 1415 F St NE | Added this semester | |
| 32 | 1418 TRINIDAD AVE NE | Added this semester | |
| 33 | 1421 TAYLOR ST NW | Added this semester | |
| 34 | 1421 TRINIDAD AVE NE | Added this semester | |
| 35 | 1423 TRINIDAD AVE NE | Added this semester | |
| 36 | 1427 Ives PI SE | Added this semester | |
| 37 | 1441 Ives Pl SE | Added this semester | |

| No | Address | Change | Reason for Removal |
|----|-------------------------|---------------------|--------------------|
| 38 | 1501 Harvard St NW | Added this semester | |
| 39 | 1534 East Capitol St NE | Added this semester | |
| 40 | 2301 Naylor Rd SE | Added this semester | |
| 41 | 250 33RD ST NE | Added this semester | |
| 42 | 2718 Hamlin St NE | Added this semester | |
| 43 | 3004 25th St NE | Added this semester | |
| 44 | 3050 MONROE ST NE | Added this semester | |
| 45 | 3248 Q St NW | Added this semester | |
| 46 | 3548 11th St NW | Added this semester | |
| 47 | 3741 McKinley St NW | Added this semester | |
| 48 | 4310 Chesapeake St NW | Added this semester | |
| 49 | 4316 15th St NW | Added this semester | |
| 50 | 4414 5th ST NW | Added this semester | |
| 51 | 4507 13TH ST NW | Added this semester | |
| 52 | 4610 Iowa Ave NW | Added this semester | |
| 53 | 540 5th St SE | Added this semester | |
| 54 | 5510 9th St NW | Added this semester | |
| 55 | 6125 29th St NW | Added this semester | |
| 56 | 812 Van Buren ST NW | Added this semester | |

Appendix E

Sample Invalidations

³⁴ dcwater.com

| From: | Gillespie-Marthaler, Leslie |
|--------------|--|
| То: | Maureen Schmelling; Anjuman Islam |
| Cc: | Crumlish, Karen; Richardson, William; Zirilli, Alysa; Libertz, Catherine |
| Subject: | DC Water LCR Invalidation Approvals |
| Date: | Friday, June 30, 2023 12:50:08 PM |
| Attachments: | <u>image001.png</u> <u>image005.png</u> <u>image006.png</u> <u>image007.png</u> |
| Importance: | High |

EXTERNAL EMAIL: This email was NOT sent by a DC Water Team Member. Use CAUTION before CLICKING a link or OPENING any attachment in this email. For additional analysis of this email message by the Cyber Team, please click the "Report Message" icon found in the upper right-hand corner of this message.

Good afternoon Maureen and Anjuman,

We have reviewed the request submitted by DC Water on June 26, 2023 to invalidate lead and copper results from three sites collected during the January to June 2023 monitoring period: 132 11th Street SE, 3114 15th Street NE, and 4233 Jenifer Street NW. Upon review of lead and copper sampling records and customer information submitted from 132 11th Street SE and 3114 15th Street NE, DC Water determined that proper sampling protocol was not followed as these locations did not adhere to the minimum required stagnation period. As outlined in 40 CFR 141.86(f), the primacy agency may invalidate a lead or copper tap sample meeting the conditions specified therein. Although insufficient stagnation time is not specifically included as a condition for invalidation, EPA believes that sampling results from these two sites should be invalidated because the required minimum stagnation time required by 40 CFR 141.86(b)(2) was not met. Therefore, DC Water shall not include these sample results in its 90th percentile lead and copper level calculations for the January to June 2023 compliance monitoring period. EPA suggests that DC Water make arrangements for thwith to provide the customers with another opportunity to sample following the proper stagnation period. Moreover, although this basis for invalidation is reflected in DC Water's approved 2023 Lead and Copper Rule (LCR) sampling plan, in order to avoid processing samples that were not collected according to protocol EPA recommends that DC Water carefully review the customer-submitted sample collection documentation before sending samples to the laboratory for analysis.

Regarding the sample collected from 4233 Jenifer Street NW, DC Water learned from its contractor's report which documented excavations along the length of the service line from the water main to the residence, that the service line does not meet Tier 1 criteria as it is not a lead service line. As stipulated in 40 CFR 141.86(f)(1)(ii), the primacy agency may invalidate a sample if it determines that the sample was taken from a site that did not meet the site selection criteria. Therefore, as the sample collected from 4233 Jenifer Street NW was from a site not meeting Tier 1 criteria, EPA approves the request to invalidate this sample. Therefore, DC Water shall not include this sample site's results in its 90th percentile lead and copper level calculations for the January to June 2023

compliance monitoring period. <u>In addition, this site will be removed from DC Water's LCR sample</u> <u>plan</u>. As DC Water continues with service line excavations for sites in its approved LCR sampling plan, upon receiving excavation reports EPA recommends prompt review to determine whether the site meets Tier 1 criteria and to help avoid invalidating samples that were not collected from high risk sites.

Based on DC Water's approved 2023 LCR plan, the loss of these three sites does not appear to impact the minimum number of required sample sites per 40 CFR §141.86(c); please notify our office if incorrect. If you have any questions, feel free to reach out to me or EPA Region 3 Drinking Water and Source Water Protection Branch Chief Karrie Crumlish at <u>crumlish.karen@epa.gov</u>.

Have a great 4th!

Thank you,

Leslie

Leslie Gillespie-Marthaler, Ph.D. (she/hers) Deputy Director, Water Division US EPA Mid-Atlantic Region Four Penn Center 1600 John F Kennedy Blvd Philadelphia, PA 19103-2852 Phone 215-814-2735 Email gillespiemarthaler.leslie@epa.gov





Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority Bureau of Water Services 301 Bryant Street, NW Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory 5900 MacArthur Blvd, NW Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Date: 3/21/2023

Sample Location:1st Draw13211th St. SECustomer Sample Number:3073773Sample Collected By:HOME OWNERDate / Time Collected:3/3/20235:00 AM

Report Number: LC-DC-LCR- 2303053-005 Customer Program Code: LCR

Laboratory Sample Number: 2303053-005 Date / Time Received: 3/7/2023 8:35:00 AM

| Analyte | Method | AL | MRL | Result | Units | Analysis Date | Analyst |
|---------|-----------|-------|--------|--------|-------|---------------|------------|
| Copper | EPA 200.8 | 1.3 | 0.0005 | 0.0386 | mg/L | 3/10/2023 | Lgallimore |
| Iron | EPA 200.8 | | 0.01 | 0.122 | mg/L | 3/10/2023 | Lgallimore |
| Lead | EPA 200.8 | 0.015 | 0.0002 | ND | mg/L | 3/10/2023 | Lgallimore |

Sample Location:2nd Draw13211th St. SECustomer Sample Number:3073773Sample Collected By:HOME OWNERDate / Time Collected:3/3/20235:00 AM

Customer Program Code: LCR Laboratory Sample Number: 2303053-006 Date / Time Received: 3/7/2023 8:35:00 AM

| Analyte | Method | AL | MRL | Result | Units | Analysis Date | Analyst |
|---------|-----------|-------|--------|--------|-------|---------------|------------|
| Copper | EPA 200.8 | 1.3 | 0.0005 | 0.0382 | mg/L | 3/10/2023 | Lgallimore |
| Iron | EPA 200.8 | | 0.01 | 0.0254 | mg/L | 3/10/2023 | Lgallimore |
| Lead | EPA 200.8 | 0.015 | 0.0002 | ND | mg/L | 3/10/2023 | Lgallimore |

ND = Non-Detect AL = Action Level MRL = Minimum Reporting Limit Iron results are for informational purposes only and cannot be used for compliance.

Washington Aqueduct Laboratory 5900 MacArthur Blvd, NW Washington, DC 20016 Phone (202) 345-5928 Fax (202) 587-9446



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority Bureau of Water Services 301 Bryant Street, NW Washington, DC 20001

7:45 AM

Laboratory Information

Washington Aqueduct Laboratory 5900 MacArthur Blvd, NW Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Date:3/21/2023Sample Location:1st Draw311415th St. NECustomer Sample Number:3104991Sample Collected By:HOME OWNER

Date / Time Collected: 3/2/2023

Customer Program Code: LCR Laboratory Sample Number: 2303053-007 Date / Time Received: 3/7/2023 8:35:00 AM

Report Number: LC-DC-LCR- 2303053-007

| Analyte | Method | AL | MRL | Result | Units | Analysis Date | Analyst |
|---------|-----------|-------|--------|--------|-------|---------------|------------|
| Copper | EPA 200.8 | 1.3 | 0.0005 | 0.0061 | mg/L | 3/10/2023 | Lgallimore |
| Iron | EPA 200.8 | | 0.01 | ND | mg/L | 3/10/2023 | Lgallimore |
| Lead | EPA 200.8 | 0.015 | 0.0002 | ND | mg/L | 3/10/2023 | Lgallimore |

Sample Location:2nd Draw311415th St. NECustomer Sample Number:3104991Sample Collected By:HOME OWNERDate / Time Collected:3/2/20237:48 AM

Customer Program Code: LCR Laboratory Sample Number: 2303053-008 Date / Time Received: 3/7/2023 8:35:00 AM

| Analyte | Method | AL | MRL | Result | Units | Analysis Date | Analyst |
|---------|-----------|-------|--------|--------|-------|---------------|------------|
| Copper | EPA 200.8 | 1.3 | 0.0005 | 0.0167 | mg/L | 3/10/2023 | Lgallimore |
| Iron | EPA 200.8 | | 0.01 | ND | mg/L | 3/10/2023 | Lgallimore |
| Lead | EPA 200.8 | 0.015 | 0.0002 | ND | mg/L | 3/10/2023 | Lgallimore |

ND = Non-Detect AL = Action Level MRL = Minimum Reporting Limit Iron results are for informational purposes only and cannot be used for compliance.

Washington Aqueduct Laboratory 5900 MacArthur Blvd, NW Washington, DC 20016 Phone (202) 345-5928 Fax (202) 587-9446



Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead, Copper, and Iron Report

Customer Information

District of Columbia Water and Sewer Authority Bureau of Water Services 301 Bryant Street, NW Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory 5900 MacArthur Blvd, NW Washington, DC 20016

Robert P. Hoffa

Robert P. Hoffa, Laboratory Manager

Report Date: 3/21/2023

Sample Location:1st Draw4233 Jenifer St NWCustomer Sample Number:3040167Sample Collected By:HOME OWNERDate / Time Collected:2/28/20236:58 AM

Report Number: LC-DC-LCR-2303017-001
Customer Program Code: LCR

Laboratory Sample Number: 2303017-001 Date / Time Received: 3/2/2023 7:40:00 AM

| Analyte | Method | AL | MRL | Result | Units | Analysis Date | Analyst |
|---------|-----------|-------|--------|--------|-------|---------------|------------|
| Copper | EPA 200.8 | 1.3 | 0.0005 | 0.0032 | mg/L | 3/10/2023 | LGallimore |
| Iron | EPA 200.8 | | 0.01 | ND | mg/L | 3/10/2023 | LGallimore |
| Lead | EPA 200.8 | 0.015 | 0.0002 | ND | mg/L | 3/10/2023 | LGallimore |

Sample Location:2nd Draw4233 Jenifer St NWCustomer Sample Number:3040167Sample Collected By:HOME OWNERDate / Time Collected:2/28/20236:59 AM

Customer Program Code: LCR Laboratory Sample Number: 2303017-002 Date / Time Received: 3/2/2023 7:40:00 AM

| Analyte | Method | AL | MRL | Result | Units | Analysis Date | Analyst |
|---------|-----------|-------|--------|--------|-------|---------------|------------|
| Copper | EPA 200.8 | 1.3 | 0.0005 | 0.0032 | mg/L | 3/10/2023 | LGallimore |
| Iron | EPA 200.8 | | 0.01 | ND | mg/L | 3/10/2023 | LGallimore |
| Lead | EPA 200.8 | 0.015 | 0.0002 | ND | mg/L | 3/10/2023 | LGallimore |

ND = Non-Detect AL = Action Level MRL = Minimum Reporting Limit Iron results are for informational purposes only and cannot be used for compliance.

Washington Aqueduct Laboratory 5900 MacArthur Blvd, NW Washington, DC 20016 Phone (202) 345-5928 Fax (202) 587-9446